

## **DRAFT GB DATA REGISTRATION CODE LEGAL TEXT**

### Key

- 1) Blue Text – From Grid Code
- 2) Black Text – Changes / Additional words
- 3) Orange/ Brown text – From RfG
- 4) Purple – From HVDC Code
- 5) Green – From DCC (not used in this document)
- 4) Highlighted Green text – Questions for Stakeholders / Consultation
- 5) Highlighted yellow text – Nomenclature / Table / Figure numbers – to be finalised when more detail has been added
- 6) The Baseline version is that issued with the mapping table on 9 November 2017. All updates from this version, including the comments received as part of the Workgroup Consultation, results of the legal drafting session held on 16<sup>th</sup>/17<sup>th</sup> November and the mapping session held on 20 November are in track change marked format. As part of the legal text session, it was agreed that one DRC should be developed rather than 2 as originally planned.

## DATA REGISTRATION CODE (DRC)

### CONTENTS

(This contents page does not form part of the Grid Code)

| <u>Paragraph No/Title</u>   | <u>Page Number</u> |
|---|--------------------|
| DRC.1 INTRODUCTION .....  | <u>5554</u>        |
| DRC.2 OBJECTIVE .....   | <u>5554</u>        |
| DRC.3 SCOPE.....  | <u>5554</u>        |
| DRC.4 DATA CATEGORIES AND STAGES IN REGISTRATION .....  | <u>5554</u>        |
| DRC.4.2 Standard Planning Data .....  | <u>7775</u>        |
| DRC.4.3 Detailed Planning Data.....   | <u>7775</u>        |
| DRC.4.4 Operational Data .....  | <u>7775</u>        |
| DRC.5 PROCEDURES AND RESPONSIBILITIES .....   | <u>7775</u>        |
| DRC.5.1 Responsibility For Submission And Updating Of Data .....  | <u>7775</u>        |
| DRC.5.2 Methods Of Submitting Data .....  | <u>7775</u>        |
| DRC.5.3 Changes To Existing Users Data .....  | <u>8886</u>        |
| DRC.5.4 Data Not Supplied .....   | <u>8886</u>        |
| DRC.5.5 Substituted Data.....   | <u>8886</u>        |
| DRC.6 DATA TO BE REGISTERED .....   | <u>8886</u>        |
| SCHEDULE 1 - GENERATING UNIT (OR CCGT MODULE), POWER PARK MODULE AND DC<br>CONVERTER TECHNICAL DATA .....   | <u>13131310</u>    |
| SCHEDULE 2 - GENERATION PLANNING PARAMETERS .....   | <u>40403334</u>    |
| SCHEDULE 3 - LARGE POWER STATION OUTAGE PROGRAMMES, OUTPUT USABLE AND<br>INFLEXIBILITY INFORMATION .....  | <u>44443634</u>    |
| SCHEDULE 4 - LARGE POWER STATION DROOP AND RESPONSE DATA .....  | <u>47473937</u>    |
| SCHEDULE 5 - EXISTING USERS SYSTEM DATA.....  | <u>48484038</u>    |
| SCHEDULE 6 - EXISTING USERS OUTAGE INFORMATION .....  | <u>58585048</u>    |
| SCHEDULE 7 - LOAD CHARACTERISTICS AT GRID SUPPLY POINTS .....   | <u>62625452</u>    |
| SCHEDULE 8 - DATA SUPPLIED BY BM PARTICIPANTS .....   | <u>63635553</u>    |
| SCHEDULE 9 - DATA SUPPLIED BY NGET TO EXISTING USERS.....   | <u>64645654</u>    |
| SCHEDULE 10 - DEMAND PROFILES AND ACTIVE ENERGY DATA .....  | <u>66665856</u>    |
| SCHEDULE 11 - CONNECTION POINT DATA .....   | <u>68686059</u>    |
| SCHEDULE 12 - DEMAND CONTROL.....   | <u>73736463</u>    |
| SCHEDULE 13 - FAULT INFEEED DATA .....  | <u>767667</u>      |
| SCHEDULE 13 - FAULT INFEEED DATA .....  | <u>777768</u>      |
| SCHEDULE 14 - FAULT INFEEED DATA (GENERATORS INCLUDING UNIT TRANSFORMERS AND<br>STATION TRANSFORMERS).....  | <u>787869</u>      |
| SCHEDULE 15 - MOTHBALLED GENERATING UNIT, MOTHBALLED POWER PARK MODULE,<br>MOTHBALLED DC CONVERTERS AT A DC CONVERTER STATION AND ALTERNATIVE FUEL<br>DATA) ..... | <u>84847475</u>    |

|   |                                     |
|---|-------------------------------------|
| SCHEDULE 16 - BLACK START INFORMATION .....           | <a href="#"><u>89877778</u></a>     |
| SCHEDULE 17 - ACCESS PERIOD DATA.....                 | <a href="#"><u>90887879</u></a>     |
| SCHEDULE 18 - OFFSHORE TRANSMISSION SYSTEM DATA.....  | <a href="#"><u>91897080</u></a>     |
| SCHEDULE 19 - EXISTING USER DATA FILE STRUCTURE ..... | <a href="#"><u>115113103104</u></a> |



DRC.1 INTRODUCTION

DRC.1.1 The **Data Registration Code ("DRC")** presents a unified listing of all data required by **NGET** from ~~Existing Users~~ and by ~~Existing Users~~ from **NGET**, from time to time under the **Grid Code**. The data which is specified in each section of the **Grid Code** is collated here in the **DRC**. Where there is any inconsistency in the data requirements under any particular section of the **Grid Code** and the **Data Registration Code** the provisions of the particular section of the **Grid Code** shall prevail.

DRC.1.2 The **DRC** identifies the section of the **Grid Code** under which each item of data is required from ~~Existing Users~~.

DRC.1.3 The Code under which any item of data is required specifies procedures and timings for the supply of that data, for routine updating and for recording temporary or permanent changes to that data. All timetables for the provision of data are repeated in the **DRC**.

DRC.1.4 Various sections of the **Grid Code** also specify information which ~~the Existing Users~~ will receive from **NGET**. This information is summarised in a single schedule in the **DRC** (Schedule 9).

DRC.1.5 The categorisation of data into **DPD I** and **DPD II** is indicated in the **DRC** below.

DRC.2 OBJECTIVE

The objective of the **DRC** is to:

DRC.2.1 List and collate all the data to be provided by each category of ~~Existing User~~ to **NGET** under the **Grid Code**.

DRC.2.2 List all the data to be provided by **NGET** to each category of ~~Existing User~~ under the **Grid Code**.

DRC.3 SCOPE

DRC.3.1 The **DRC** applies to **NGET** and to ~~Existing Users~~, which in this **DRC** means:-

- (a) ~~Existing Generators~~ (including those undertaking **OTSDUW** ~~and/or those in respect of who own and/or operate DC Connected Power Park Modules~~);
- (b) **Network Operators**;
- (c) **DC Converter Station owners** ~~and HVDC System Owners~~;
- (d) **Suppliers**;
- (e) **Non-Embedded Customers** (including, for the avoidance of doubt, a **Pumped Storage Generator** in that capacity);
- (f) **Externally Interconnected System Operators**;
- (g) **Interconnector Users**; and
- (h) **BM Participants**.

DRC.3.2 For the avoidance of doubt, the **DRC** ~~does not apply~~ to ~~both GC Code Users and EU Code Users~~ **New User's** for whom the requirements of the ~~EDRC~~ apply.

Formatted: Font: Not Bold

Formatted: Font: Bold

Formatted: Font: Bold

Formatted: Font: Bold

DRC.4 DATA CATEGORIES AND STAGES IN REGISTRATION

DRC.4.1.1 Within the **DRC** each data item is allocated to one of the following three categories:

- (a) **Standard Planning Data (SPD)**
- (b) **Detailed Planning Data (DPD)**
- (c) **Operational Data**



- DRC.4.2 Standard Planning Data (SPD)
- DRC.4.2.1 The **Standard Planning Data** listed and collated in this **DRC** is that data listed in Part 1 of the Appendix to the **PC**.
- DRC.4.2.2 **Standard Planning Data** will be provided to **NGET** in accordance with PC.4.4 and PC.A.1.2.
- DRC.4.3 Detailed Planning Data (DPD)
- DRC.4.3.1 The **Detailed Planning Data** listed and collated in this **DRC** is categorised as **DPD I** and **DPD II** and is that data listed in Part 2 of the Appendix to the **PC**.
- DRC.4.3.2 **Detailed Planning Data** will be provided to **NGET** in accordance with PC.4.4, PC.4.5 and PC.A.1.2.
- DRC.4.4 Operational Data
- DRC.4.4.1 **Operational Data** is data which is required by the **Operating Codes** and the **Balancing Codes**. Within the **DRC**, **Operational Data** is sub-categorised according to the Code under which it is required, namely **OC1**, **OC2**, **BC1** or **BC2**.
- DRC.4.4.2 **Operational Data** is to be supplied in accordance with timetables set down in the relevant **Operating Codes** and **Balancing Codes** and repeated in tabular form in the schedules to the **DRC**.
- DRC.5 PROCEDURES AND RESPONSIBILITIES
- DRC.5.1 Responsibility For Submission And Updating Of Data
- In accordance with the provisions of the various sections of the **Grid Code**, each ~~Existing~~ **User** must submit data as summarised in DRC.6 and listed and collated in the attached schedules.
- DRC.5.2 Methods Of Submitting Data
- DRC.5.2.1 Wherever possible the data schedules to the **DRC** are structured to serve as standard formats for data submission and such format must be used for the written submission of data to **NGET**.
- DRC.5.2.2 Data must be submitted to the **Transmission Control Centre** notified by **NGET** or to such other department or address as **NGET** may from time to time advise. The name of the person at the **User Site** who is submitting each schedule of data must be included.
- DRC.5.2.3 Where a computer data link exists between ~~a an Existing~~ **User** and **NGET**, data may be submitted via this link. **NGET** will, in this situation, provide computer files for completion by the **User** containing all the data in the corresponding **DRC** schedule.
- Data submitted can be in an electronic format using a proforma to be supplied by **NGET** or other format to be agreed annually in advance with **NGET**. In all cases the data must be complete and relate to, and relate only to, what is required by the relevant section of the **Grid Code**.
- DRC.5.2.4 Other modes of data transfer, such as magnetic tape, may be utilised if **NGET** gives its prior written consent.
- DRC.5.2.5 ~~Existing~~ **Generators**, **HVDC System Owners** and **DC Converter Station** owners submitting data for a **Power Generating Module**, **Generating Unit**, **DC Converter**, **HVDC System**, **Power Park Module** (including **DC Connected Power Park Modules**) or **CCGT Module** before the issue of a **Final Operational Notification** should submit the **DRC** data schedules and compliance information required under the **CP** electronically using the **User Data File Structure** unless otherwise agreed with **NGET**.

Formatted: Font: Not Bold

Formatted: Font: Bold

Formatted: Font: Bold

Formatted: Font: Bold

DRC.5.3 Changes To Users' Data

DRC.5.3.1 Whenever an ~~Existing~~ User becomes aware of a change to an item of data which is registered with NGET the ~~Existing~~ User must notify NGET in accordance with each section of the Grid Code. The method and timing of the notification to NGET is set out in each section of the Grid Code.

DRC.5.4 Data Not Supplied

DRC.5.4.1 ~~Existing~~ Users and NGET are obliged to supply data as set out in the individual sections of the Grid Code and repeated in the DRC. If an ~~Existing~~ User fails to supply data when required by any section of the Grid Code, NGET will estimate such data if and when, in the NGET's view, it is necessary to do so. If NGET fails to supply data when required by any section of the Grid Code, the ~~Existing~~ User to whom that data ought to have been supplied, will estimate such data if and when, in that ~~Existing~~ User's view, it is necessary to do so. Such estimates will, in each case, be based upon data supplied previously for the same Plant or Apparatus or upon corresponding data for similar Plant or Apparatus or upon such other information as NGET or that ~~Existing~~ User, as the case may be, deems appropriate.

DRC.5.4.2 NGET will advise an ~~Existing~~ User in writing of any estimated data it intends to use pursuant to DRC.5.4.1 relating directly to that User's Plant or Apparatus in the event of data not being supplied.

DRC.5.4.3 An ~~Existing~~ User will advise NGET in writing of any estimated data it intends to use pursuant to DRC.5.4.1 in the event of data not being supplied.

DRC.5.5 Substituted Data

DRC.5.5.1 In the case of PC.A.4 only, if the data supplied by an ~~Existing~~ User does not in NGET's reasonable opinion reflect the equivalent data recorded by NGET, NGET may estimate such data if and when, in the view of NGET, it is necessary to do so. Such estimates will, in each case, be based upon data supplied previously for the same Plant or Apparatus or upon corresponding data for similar Plant or Apparatus or upon such other information as NGET deems appropriate.

DRC.5.5.2 NGET will advise an ~~Existing~~ User in writing of any estimated data it intends to use pursuant to DRC.5.5.1 relating directly to that ~~Existing~~ User's Plant or Apparatus where it does not in NGET's reasonable opinion reflect the equivalent data recorded by NGET. Such estimated data will be used by NGET in place of the appropriate data submitted by the ~~Existing~~ User pursuant to PC.A.4 and as such shall be deemed to accurately represent the ~~Existing~~ User's submission until such time as the ~~Existing~~ User provides data to NGET's reasonable satisfaction.

DRC.6 DATA TO BE REGISTERED

DRC.6.1 Schedules 1 to 19 attached cover the following data areas.

DRC.6.1.1 Schedule 1 — Power Generating Module, Generating Unit (oOr CCGT Module), Power Park Module (including DC Connected Power Park Module and Power Park Unit), HVDC System aAnd DC Converter Technical Data.

Comprising **Power Generating Module, Generating Unit (and CCGT Module), Power Park Module (including DC Connected Power Park Module and Power Park Unit) and DC Converter** fixed electrical parameters.

Formatted: Font: Bold

Formatted: Font: Bold

DRC.6.1.2 Schedule 2 - Generation Planning Parameters

Comprising the **Genset** parameters required for **Operational Planning** studies.

DRC.6.1.3 Schedule 3 - Large Power Station Outage Programmes, Output Usable And Inflexibility Information.

Comprising generation outage planning, **Output Usable** and inflexibility information at timescales down to the daily **BM Unit Data** submission.



- DRC.6.1.4 Schedule 4 - Large Power Station Droop And Response Data.  
Comprising data on governor **Droop** settings and **Primary, Secondary and High Frequency Response** data for **Large Power Stations**.
- DRC.6.1.5 Schedule 5 – ~~Existing~~ User's System Data.  
Comprising electrical parameters relating to **Plant** and **Apparatus** connected to the **National Electricity Transmission System**.
- DRC.6.1.6 Schedule 6 – ~~Existing~~ Users Outage Information.  
Comprising the information required by **NGET** for outages on the ~~Existing-Users~~ **System**, including outages at **Power Stations** other than outages of **Gensets**
- DRC.6.1.7 Schedule 7 - Load Characteristics.  
Comprising the estimated parameters of load groups in respect of, for example, harmonic content and response to frequency.
- DRC.6.1.8 Schedule 8 - BM Unit Data.
- DRC.6.1.9 Schedule 9 - Data Supplied By NGET To ~~Existing~~ Users.
- DRC.6.1.10 Schedule 10 - Demand Profiles And Active Energy Data  
Comprising information relating to the **Network Operators'** and **Non-Embedded Customers'** total **Demand** and **Active Energy** taken from the **National Electricity Transmission System**
- DRC.6.1.11 Schedule 11 - Connection Point Data  
Comprising information relating to **Demand**, demand transfer capability and the **Small Power Station, Medium Power Station** and **Customer** generation connected to the **Connection Point**
- DRC.6.1.12 Schedule 12 - Demand Control Data  
Comprising information related to **Demand Control**
- DRC.6.1.13 Schedule 13 - Fault Infeed Data  
Comprising information relating to the short circuit contribution to the **National Electricity Transmission System** from ~~Existing-Users~~ other than ~~Existing-Generators, HVDC System Owners~~ and **DC Converter Station** owners.
- DRC.6.1.14 Schedule 14 - Fault Infeed Data (~~Existing-Generators~~ Including Unit And Station Transformers)  
Comprising information relating to the Short Circuit contribution to the **National Electricity Transmission System** from ~~Existing-Generators, HVDC System Owners~~ and **DC Converter Station** owners.
- DRC.6.1.15 Schedule 15 – ~~Mothballed Power Generating Module, Mothballed Generating Unit, Mothballed Power Park Module (including Mothballed DC Connected Power Park Modules), Mothballed HVDCe Systems, Mothballed HVDC Converters, Mothballed DC Converters aA DC Converter Station aAnd Alternative Fuel Data~~  
Comprising information relating to estimated return to service times for **Mothballed Power Generating Modules, Mothballed Generating Units, Mothballed Power Park Modules (including Mothballed DC Connected Power Park Modules), Mothballed HVDC Systems, Mothballed HVDC Converters** and **Mothballed DC Converters at a DC Converter Station** and the capability of gas-fired **Generating Units** to operate using alternative fuels.
- DRC.6.1.16 Schedule 16 – Black Start Information  
Comprising information relating to **Black Start**.
- DRC.6.1.17 Schedule 17 – Access Period Schedule

Formatted: Font: Not Bold

Formatted: Font: Not Bold

Formatted: Font: Bold

Formatted: Font: Not Bold

Formatted: Font: Not Bold

Formatted: Font: Bold

Formatted: Font: Bold

Comprising **Access Period** information for **Transmission Interface Circuits** within an **Access Group**.

- DRC.6.1.18 [Schedule 18 – Generators Undertaking OTSDUW Arrangements](#)  
Comprising electrical parameters relating to **OTSDUW Plant and Apparatus** between the **Offshore Grid Entry Point** and **Transmission Interface Point**.
- DRC.6.1.19 [Schedule 19 – User Data File Structure](#)  
Comprising information relating to the **User Data File Structure**.
- DRC.6.2 The **Schedules** applicable to each class of **User** are as follows:

| <u>User</u>   | <u>Schedule</u>               |
|---|-------------------------------|
| <b>Existing-Generators</b> with <b>Large Power Stations</b>   | 1, 2, 3, 4, 9, 14, 15, 16, 19 |
| <b>Existing-Generators</b> with <b>Medium Power Stations</b><br>(see notes 2, 3, 4)   | 1, 2 (part), 9, 14, 15, 19    |
| <b>Existing-Generators</b> with <b>Small Power Stations</b> directly connected to the <b>National Electricity Transmission System</b> | 1, 6, 14, 15, 19              |
| <b>Existing-Generators</b> undertaking <b>OTSDUW</b><br>(see note 5)  | 18, 19                        |
| All <b>Existing-Users</b> connected directly to the <b>National Electricity Transmission System</b>                                   | 5, 6, 9                       |
| All <b>Existing-Users</b> connected directly to the <b>National Electricity Transmission System</b> other than <b>Generators</b>      | 10,11,13,17                   |
| All <b>Existing-Users</b> connected directly to the <b>National Electricity Transmission System</b> with <b>Demand</b>                | 7, 9                          |
| A <b>Pumped Storage Generator, Externally Interconnected System Operator</b> and <b>Interconnector Users</b>                          | 12<br>(as marked)             |
| All <b>Suppliers</b>  | 12                            |
| All <b>Network Operators</b>  | 12                            |
| All <b>BM Participants</b>  | 8                             |
| All <b>DC Converter Station</b> owners  | 1, 4, 9, 14, 15, 19           |

Notes:

- (1) **Network Operators** must provide data relating to **Small Power Stations** and/or **Customer Generating Plant Embedded** in their **Systems** when such data is requested by **NGET** pursuant to PC.A.3.1.4 or PC.A.5.1.4.
- (2) The data in schedules 1, 14 and 15 need not be supplied in relation to **Medium Power Stations** connected at a voltage level below the voltage level of the **Subtransmission System** except in connection with a **CUSC Contract** or unless specifically requested by **NGET**.
- (3) Each **Network Operator** within whose **System** an **Embedded Medium Power Station** not subject to a **Bilateral Agreement** or **Embedded DC Converter Station** not subject to a **Bilateral Agreement** is situated shall provide the data to **NGET** in respect of each such **Embedded Medium Power Station** or **Embedded DC Converter Station** or **HVDC System**.

Formatted: Font: Not Bold

- (4) In the case of Schedule 2, ~~Existing Generators~~, HVDC System Owners, DC Converter Station owners or Network Operators in the case of Embedded Medium Power Stations not subject to a Bilateral Agreement or Embedded DC Converter Stations not subject to a Bilateral Agreement, would only be expected to submit data in relation to Standard Planning Data as required by the Planning Code.
- (5) In the case of ~~Existing Generators~~ undertaking OTSDUW, the ~~Existing Generator~~ will need to supply ~~Existing-User~~ data in accordance with the requirements of Large or Small Power Stations (as defined in DRC.6.2) up to the Offshore Grid Entry Point. In addition, the ~~Existing-User~~ will also need to submit Offshore Transmission System data in between the Interface Point and its Connection Points in accordance with the requirements of Schedule 18.

Formatted: Font: Bold

**SCHEDULE 1 — POWER GENERATING MODULE, GENERATING UNIT (OR CCGT MODULE), POWER PARK MODULE, DC CONNECTED POWER PARK MODULE, HVDC SYSTEM AND DC CONVERTER TECHNICAL DATA**

PAGE 1 OF 19

ABBREVIATIONS:

**SPD = Standard Planning Data**

% on MVA = % on Rated MVA

% on 100 = % on 100 MVA

**DPD = Detailed Planning Data**

**RC = Registered Capacity**

**MC = Maximum Capacity**

**OC1, BC1, etc = Grid Code**  
for which data is required

**CUSC Contract = ~~Existing~~—User** data which may be submitted to the **Relevant Transmission Licensees** by **NGET**, following the acceptance by a ~~Existing~~ **User** of a **CUSC Contract**.

**CUSC App. Form = ~~Existing~~—User** data which may be submitted to the **Relevant Transmission Licensees** by **NGET**, following an application by a ~~Existing~~ **User** for a **CUSC Contract**.

Note:

All parameters, where applicable, are to be measured at nominal **System Frequency**

+ these **SPD** items should only be given in the data supplied with the application for a **CUSC Contract**.

\* Asterisk items are not required for **Small Power Stations** and **Medium Power Stations**

Information is to be given on a **Unit** basis, unless otherwise stated. Where references to **CCGT Modules** are made, the columns "G1" etc should be amended to read "M1" etc, as appropriate

□ These data items may be submitted to the **Relevant Transmission Licensees** from **NGET** in respect of the **National Electricity Transmission System**. The data may be submitted to the **Relevant Transmission Licensees** in a summarised form e.g. network model; the data transferred will have been originally derived from data submitted by ~~Existing~~ **Users** to **NGET**.

■ these data items may be submitted to the **Relevant Transmission Licensee** from **NGET** in respect to **Relevant Units** only. The data may be submitted to the **Relevant Transmission Licensee** in a summarised form e.g. network model; the data transferred will have been originally derived from data submitted by ~~Existing~~ **Users** to **NGET**.

**SCHEDULE 1 -- POWER GENERATING MODULE, GENERATING UNIT (OR CCGT MODULE), POWER PARK MODULE, DC CONNECTED POWER PARK MODULE, HVDC SYSTEM AND DC CONVERTER TECHNICAL DATA**

POWER STATION NAME: \_\_\_\_\_

DATE: \_\_\_\_\_

| DATA DESCRIPTION   | UNITS  | DATA to   |   | DATA CAT. | GENERATING UNIT OR STATION DATA |            |            |            |            |            |            |
|--|--|---|---|-----------|---------------------------------|------------|------------|------------|------------|------------|------------|
|  |  | RTL<br>CUSC<br>Cont<br>ract   | CUSC<br>App.<br>Form  |           | F.Yr.<br>0                      | F.Yr.<br>1 | F.Yr.<br>2 | F.Yr.<br>3 | F.Yr.<br>4 | F.Yr.<br>5 | F.Yr.<br>6 |
| <p><b>GENERATING STATION DEMANDS:</b><br/>Demand associated with the Power Station supplied through the National Electricity Transmission System or the <del>Existing</del> Generator's User System (PC.A.5.2)</p> <ul style="list-style-type: none"> <li>- The maximum Demand that could occur.</li> <li>- Demand at specified time of annual peak half hour of National Electricity Transmission System Demand at Annual ACS Conditions.</li> <li>- Demand at specified time of annual minimum half-hour of National Electricity Transmission System Demand.</li> </ul> <p>(Additional Demand supplied through the unit transformers to be provided below)</p>   | <p>MW<br/>MVA<br/>MW<br/>MVA</p> <p>MW<br/>MVA</p> | <p><input type="checkbox"/><br/><input type="checkbox"/><br/><input type="checkbox"/><br/><input type="checkbox"/></p> <p><input type="checkbox"/><br/><input type="checkbox"/></p> | <p>DPD I<br/>DPD I<br/>DPD II<br/>DPD II</p> <p>DPD II<br/>DPD II</p> |           |                                 |            |            |            |            |            |            |
| <p><b>INDIVIDUAL GENERATING UNIT (OR AS THE CASE MAY BE, SYNCHRONOUS POWER GENERATING MODULE OR CCGT MODULE) DATA</b></p> <p>Point of connection to the National Electricity Transmission System (or the Total System if embedded) of the Generating Unit or Synchronous Power Generating Module (other than a CCGT Unit) or the CCGT Module, as the case may be in terms of geographical and electrical location and system voltage (PC.A.3.4.1)</p> <p>If the busbars at the Connection Point are normally run in separate sections identify the section to which the Generating Unit (other than a CCGT Unit) or Synchronous Power Generating Module or CCGT Module, as the case may be is connected (PC.A.3.1.5)</p> | <p>Text</p> <p>Section Number</p>                  | <p><input type="checkbox"/><br/><input type="checkbox"/></p>  | <p>■<br/>■</p> <p>SPD<br/>SPD</p>                                     | G1        | G2                              | G3         | G4         | G5         | G6         | STN        |            |

**Comment [A1]:** House keeping Change - bold

**Formatted:** Font: Bold

**Formatted:** Font: Bold

**Formatted:** Font: Not Bold

**Formatted:** Font: Bold

**Formatted:** Font: Bold

Type of Unit (steam, **Gas Turbine  
Combined Cycle Gas Turbine Unit,**  
tidal, wind, etc.)  
(PC.A.3.2.2 (h))

□

**SCHEDULE 1 -- POWER GENERATING MODULE, GENERATING UNIT (OR CCGT MODULE), POWER PARK MODULE, DC CONNECTED POWER PARK MODULE, HVDC SYSTEM AND DC CONVERTER TECHNICAL DATA**

PAGE 3 OF 19

| <u>INDIVIDUAL SYNCHRONOUS POWER GENERATING MODULE GENERATING UNIT (OR AS THE CASE MAY BE, CCGT MODULE) DATA</u>  |   |   |     |  | G1 | G2 | G3 | G4 | G5 | G6 | STN |
|--|---|---|-----|--|----|----|----|----|----|----|-----|
| <p>A list of the <b>Generating Units and CCGT Units</b> within a <b>Synchronous Power Generating Module or CCGT Module</b>, identifying each <b>CCGT Unit</b>, and the <b>Power Generating Module or CCGT Module</b> of which it forms part, unambiguously. In the case of a <b>Range CCGT Module</b>, details of the possible configurations should also be submitted. (PC.A.3.2.2 (g))</p> | □ | ■ | SPD |  |    |    |    |    |    |    |     |

**Formatted:** Font: Bold

**Formatted:** Font: Bold

**Formatted:** Font: Bold



**SCHEDULE 1 – POWER GENERATING MODULE, GENERATING UNIT (OR CCGT MODULE), POWER PARK MODULE, DC CONNECTED POWER PARK MODULE, HVDC SYSTEM AND DC CONVERTER TECHNICAL DATA**

| DATA DESCRIPTION  | UNITS        | DATA to                  |                                     | DATA CAT. | GENERATING UNIT (OR CCGT MODULE, AS THE CASE MAY BE)   |    |    |    |    |    |     |  |
|---|--------------|--------------------------|-------------------------------------|-----------|--|----|----|----|----|----|-----|--|
|   |              | RTL                      |                                     |           | G1   | G2 | G3 | G4 | G5 | G6 | STN |  |
| Rated MVA (PC.A.3.3.1)  | MVA          | <input type="checkbox"/> | <input checked="" type="checkbox"/> | SPD+      |  |    |    |    |    |    |     |  |
| Rated MW (PC.A.3.3.1)   | MW           | <input type="checkbox"/> | <input checked="" type="checkbox"/> | SPD+      |  |    |    |    |    |    |     |  |
| Rated terminal voltage (PC.A.5.3.2.(a) & PC.A.5.4.2 (b))  | kV           | <input type="checkbox"/> | <input type="checkbox"/>            | DPD I     |  |    |    |    |    |    |     |  |
| *Performance Chart at <b>Onshore Synchronous Generating Unit</b> stator terminals (PC.A.3.2.2(f)(i))                                |              |                          |                                     | SPD       | (see OC2 for specification)  |    |    |    |    |    |     |  |
| * Performance Chart of the <b>Offshore Synchronous Generating Unit</b> at the <b>Offshore Grid Entry Point</b> (PC.A.3.2.2(f)(iii)) |              |                          |                                     |           |  |    |    |    |    |    |     |  |
| * <u>Synchronous Generating Unit Performance Chart (PC.A.3.2.2(f))</u>  |              |                          |                                     |           |  |    |    |    |    |    |     |  |
| * <u>Power Generating Module Performance Chart of the Synchronous Power Generating Module (PC.A.3.2.2(f))</u>                       |              |                          |                                     |           |  |    |    |    |    |    |     |  |
| * Maximum terminal voltage set point(PC.A.5.3.2.(a) & PC.A.5.4.2 (b))   | kV           | <input type="checkbox"/> | <input type="checkbox"/>            | DPD I     |  |    |    |    |    |    |     |  |
| * Terminal voltage set point step resolution – if not continuous (PC.A.5.3.2.(a) & PC.A.5.4.2 (b))                                  | kV           | <input type="checkbox"/> | <input type="checkbox"/>            | DPD I     |  |    |    |    |    |    |     |  |
| * <b>Output Usable</b> (on a monthly basis) (PC.A.3.2.2(b))   | MW           |                          |                                     | SPD       | (except in relation to <b>CCGT Modules</b> when required on a unit basis under the <b>Grid Code</b> , this data item may be supplied under Schedule 3) |    |    |    |    |    |     |  |
| Turbo-Generator inertia constant (for synchronous machines) (PC.A.5.3.2(a))   | MW secs /MVA | <input type="checkbox"/> | <input checked="" type="checkbox"/> | SPD+      |  |    |    |    |    |    |     |  |
| Short circuit ratio (synchronous machines) (PC.A.5.3.2(a))  |              | <input type="checkbox"/> | <input checked="" type="checkbox"/> | SPD+      |  |    |    |    |    |    |     |  |
| Normal auxiliary load supplied by the <b>Generating Unit</b> at rated MW output (PC.A.5.2.1)  | MW           | <input type="checkbox"/> | <input type="checkbox"/>            | DPD II    |  |    |    |    |    |    |     |  |
| Rated field current at rated MW and MVA output and at rated terminal voltage (PC.A.5.3.2 (a))                                       | A            | <input type="checkbox"/> | <input type="checkbox"/>            | DPD II    |  |    |    |    |    |    |     |  |
| Field current open circuit saturation curve (as derived from appropriate manufacturers' test certificates): (PC.A.5.3.2 (a))        |              |                          |                                     |           |  |    |    |    |    |    |     |  |
| 120% rated terminal volts   | A            | <input type="checkbox"/> | <input type="checkbox"/>            | DPD II    |  |    |    |    |    |    |     |  |
| 110% rated terminal volts   | A            | <input type="checkbox"/> | <input type="checkbox"/>            | DPD II    |  |    |    |    |    |    |     |  |
| 100% rated terminal volts   | A            | <input type="checkbox"/> | <input type="checkbox"/>            | DPD II    |  |    |    |    |    |    |     |  |
| 90% rated terminal volts  | A            | <input type="checkbox"/> | <input type="checkbox"/>            | DPD II    |  |    |    |    |    |    |     |  |
| 80% rated terminal volts  | A            | <input type="checkbox"/> | <input type="checkbox"/>            | DPD II    |  |    |    |    |    |    |     |  |
| 70% rated terminal volts  | A            | <input type="checkbox"/> | <input type="checkbox"/>            | DPD II    |  |    |    |    |    |    |     |  |
| 60% rated terminal volts  | A            | <input type="checkbox"/> | <input type="checkbox"/>            | DPD II    |  |    |    |    |    |    |     |  |
| 50% rated terminal volts  | A            | <input type="checkbox"/> | <input type="checkbox"/>            | DPD II    |  |    |    |    |    |    |     |  |
| <b>IMPEDANCES:</b> (Unsaturated)  |              |                          |                                     |           |  |    |    |    |    |    |     |  |
| Direct axis synchronous reactance (PC.A.5.3.2(a))   | % on MVA     | <input type="checkbox"/> | <input type="checkbox"/>            | DPD I     |  |    |    |    |    |    |     |  |
| Direct axis transient reactance (PC.A.3.3.1(a)& PC.A.5.3.2(a))  | % on MVA     | <input type="checkbox"/> | <input checked="" type="checkbox"/> | SPD+      |  |    |    |    |    |    |     |  |
| Direct axis sub-transient reactance (PC.A.5.3.2(a))   | % on MVA     | <input type="checkbox"/> | <input type="checkbox"/>            | DPD I     |  |    |    |    |    |    |     |  |
| Quad axis synch reactance (PC.A.5.3.2(a))   | % on MVA     | <input type="checkbox"/> | <input type="checkbox"/>            | DPD I     |  |    |    |    |    |    |     |  |
| Quad axis sub-transient reactance (PC.A.5.3.2(a))   | % on MVA     | <input type="checkbox"/> | <input type="checkbox"/>            | DPD I     |  |    |    |    |    |    |     |  |
| Stator leakage reactance (PC.A.5.3.2(a))  | % on MVA     | <input type="checkbox"/> | <input type="checkbox"/>            | DPD I     |  |    |    |    |    |    |     |  |

Formatted Table

|   |          |                          |       |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
|---|----------|--------------------------|-------|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|
| Armature winding direct current resistance. (PC.A.5.3.2(a))     | % on MVA | <input type="checkbox"/> | DPD I |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |
| In Scotland, negative sequence resistance (PC.A.2.5.6 (a) (iv)) | % on MVA | <input type="checkbox"/> | DPD I |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |

Note:- the above data item relating to armature winding direct-current resistance need only be provided by **Generators** in relation to **Generating Units or Synchronous Generating Units within Power Generating Modules** commissioned after 1st March 1996 and in cases where, for whatever reason, the **Generator** is aware of the value of the data item.

**Formatted:** Font: Bold

**Formatted:** Font: Bold

**SCHEDULE 1 -- POWER GENERATING MODULE, GENERATING UNIT (OR CCGT MODULE), POWER PARK MODULE DC CONNECTED POWER PARK MODULE, HVDC SYSTEM AND DC CONVERTER TECHNICAL DATA**

| DATA DESCRIPTION  | UNITS            | DATA to                  |                                     | DATA CAT.     | GENERATING UNIT OR STATION DATA |    |    |    |    |    |     |
|---|------------------|--------------------------|-------------------------------------|---------------|---------------------------------|----|----|----|----|----|-----|
|   |                  | CUSC Contract            | CUSC App. Form                      |               | G1                              | G2 | G3 | G4 | G5 | G6 | STN |
| <b>TIME CONSTANTS</b><br>(Short-circuit and Unsaturated)  |                  |                          |                                     |               |                                 |    |    |    |    |    |     |
| Direct axis transient time constant<br>(PC.A.5.3.2(a))  | S                | <input type="checkbox"/> |                                     | DPD I         |                                 |    |    |    |    |    |     |
| Direct axis sub-transient time constant<br>(PC.A.5.3.2(a))  | S                | <input type="checkbox"/> |                                     | DPD I         |                                 |    |    |    |    |    |     |
| Quadrature axis sub-transient time constant<br>(PC.A.5.3.2(a))  | S                | <input type="checkbox"/> |                                     | DPD I         |                                 |    |    |    |    |    |     |
| Stator time constant (PC.A.5.3.2(a))  | S                | <input type="checkbox"/> |                                     | DPD I         |                                 |    |    |    |    |    |     |
| <b>MECHANICAL PARAMETERS</b><br>(PC.A.5.3.2(a))   |                  |                          |                                     |               |                                 |    |    |    |    |    |     |
| The number of turbine generator masses  |                  | <input type="checkbox"/> |                                     | DPD II        |                                 |    |    |    |    |    |     |
| Diagram showing the Inertia and parameters for each turbine generator mass for the complete drive train             | Kgm <sup>2</sup> | <input type="checkbox"/> |                                     | DPD II        |                                 |    |    |    |    |    |     |
| Diagram showing Stiffness constants and parameters between each turbine generator mass for the complete drive train | Nm/rad           | <input type="checkbox"/> |                                     | DPD II        |                                 |    |    |    |    |    |     |
| Number of poles   |                  | <input type="checkbox"/> |                                     | DPD II        |                                 |    |    |    |    |    |     |
| Relative power applied to different parts of the turbine  | %                | <input type="checkbox"/> |                                     | DPD II        |                                 |    |    |    |    |    |     |
| Torsional mode frequencies  | Hz               | <input type="checkbox"/> |                                     | DPD II        |                                 |    |    |    |    |    |     |
| Modal damping decrement factors for the different mechanical modes  |                  | <input type="checkbox"/> |                                     | DPD II        |                                 |    |    |    |    |    |     |
| <b>GENERATING UNIT STEP-UP TRANSFORMER</b>  |                  |                          |                                     |               |                                 |    |    |    |    |    |     |
| Rated MVA (PC.A.3.3.1 & PC.A.5.3.2)   | MVA              | <input type="checkbox"/> | <input checked="" type="checkbox"/> | SPD+<br>DPD I |                                 |    |    |    |    |    |     |
| Voltage Ratio (PC.A.5.3.2)  | -                | <input type="checkbox"/> |                                     | DPD I         |                                 |    |    |    |    |    |     |
| Positive sequence reactance: (PC.A.5.3.2)   |                  |                          |                                     |               |                                 |    |    |    |    |    |     |
| Max tap   | % on MVA         | <input type="checkbox"/> | <input checked="" type="checkbox"/> | SPD+          |                                 |    |    |    |    |    |     |
| Min tap   | % on MVA         | <input type="checkbox"/> | <input checked="" type="checkbox"/> | SPD+          |                                 |    |    |    |    |    |     |
| Nominal tap   | % on MVA         | <input type="checkbox"/> | <input checked="" type="checkbox"/> | SPD+          |                                 |    |    |    |    |    |     |
| Positive sequence resistance: (PC.A.5.3.2)  |                  |                          |                                     |               |                                 |    |    |    |    |    |     |
| Max tap   | % on MVA         | <input type="checkbox"/> |                                     | DPD II        |                                 |    |    |    |    |    |     |
| Min tap   | % on MVA         | <input type="checkbox"/> |                                     | DPD II        |                                 |    |    |    |    |    |     |
| Nominal tap   | % on MVA         | <input type="checkbox"/> |                                     | DPD II        |                                 |    |    |    |    |    |     |
| Zero phase sequence reactance (PC.A.5.3.2)  | % on MVA         | <input type="checkbox"/> |                                     | DPD II        |                                 |    |    |    |    |    |     |
| Tap change range (PC.A.5.3.2)   | +%/ -%           | <input type="checkbox"/> |                                     | DPD II        |                                 |    |    |    |    |    |     |
| Tap change step size (PC.A.5.3.2)   | %                | <input type="checkbox"/> |                                     | DPD II        |                                 |    |    |    |    |    |     |
| Tap changer type: on-load or off-circuit (PC.A.5.3.2)   | On/Off           | <input type="checkbox"/> |                                     | DPD II        |                                 |    |    |    |    |    |     |

**SCHEDULE 1 -- POWER GENERATING MODULE, GENERATING UNIT (OR CCGT MODULE), POWER PARK MODULE, DC CONNECTED POWER PARK MODULE, HVDC SYSTEM AND DC CONVERTER TECHNICAL DATA**

| DATA DESCRIPTION  | UNITS             | DATA to |                          | DATA CAT.     | GENERATING UNIT OR STATION DATA |    |    |    |    |    |     |
|---|-------------------|---------|--------------------------|---------------|---------------------------------|----|----|----|----|----|-----|
|   |                   | RTL     |                          |               | G1                              | G2 | G3 | G4 | G5 | G6 | STN |
| <b>EXCITATION:</b>  |                   |         |                          |               |                                 |    |    |    |    |    |     |
| <b>Note:</b> The data items requested under Option 1 below may continue to be provided by <b>Generators</b> in relation to <b>Generating Units</b> on the <b>System</b> at 9 January 1995 (in this paragraph, the "relevant date") or they may provide the new data items set out under Option 2. <b>Generators</b> must supply the data as set out under Option 2 (and not those under Option 1) for <b>Generating Unit and Synchronous Power Generating Unit</b> excitation control systems commissioned after the relevant date, those <b>Generating Unit or Synchronous Power Generating Unit</b> excitation control systems recommissioned for any reason such as refurbishment after the relevant date and <b>Generating Unit or Synchronous Power Generating Unit</b> excitation control systems where, as a result of testing or other process, the <b>Generator</b> is aware of the data items listed under Option 2 in relation to that <b>Generating Unit or Synchronous Power Generating Unit</b> . |                   |         |                          |               |                                 |    |    |    |    |    |     |
| <b>Option 1</b>   |                   |         |                          |               |                                 |    |    |    |    |    |     |
| DC gain of <b>Excitation Loop</b> (PC.A.5.3.2(c))   |                   |         | <input type="checkbox"/> | <b>DPD II</b> |                                 |    |    |    |    |    |     |
| Max field voltage (PC.A.5.3.2(c))   | V                 |         | <input type="checkbox"/> | <b>DPD II</b> |                                 |    |    |    |    |    |     |
| Min field voltage (PC.A.5.3.2(c))   | V                 |         | <input type="checkbox"/> | <b>DPD II</b> |                                 |    |    |    |    |    |     |
| Rated field voltage (PC.A.5.3.2(c))   | V                 |         | <input type="checkbox"/> | <b>DPD II</b> |                                 |    |    |    |    |    |     |
| Max rate of change of field volts: (PC.A.5.3.2(c))  |                   |         |                          |               |                                 |    |    |    |    |    |     |
| Rising  | V/Sec             |         | <input type="checkbox"/> | <b>DPD II</b> |                                 |    |    |    |    |    |     |
| Falling   | V/Sec             |         | <input type="checkbox"/> | <b>DPD II</b> |                                 |    |    |    |    |    |     |
| Details of <b>Excitation Loop</b> (PC.A.5.3.2(c))<br>Described in block diagram form showing transfer functions of individual elements  | Diagram           |         | <input type="checkbox"/> | <b>DPD II</b> | (please attach)                 |    |    |    |    |    |     |
| Dynamic characteristics of over- excitation limiter (PC.A.5.3.2(c))   |                   |         | <input type="checkbox"/> | <b>DPD II</b> |                                 |    |    |    |    |    |     |
| Dynamic characteristics of under-excitation limiter (PC.A.5.3.2(c))   |                   |         | <input type="checkbox"/> | <b>DPD II</b> |                                 |    |    |    |    |    |     |
| <b>Option 2</b>   |                   |         |                          |               |                                 |    |    |    |    |    |     |
| Exciter category, e.g. <b>Rotating Exciter</b> , or <b>Static Exciter</b> etc (PC.A.5.3.2(c))   | Text              |         | <input type="checkbox"/> | <b>SPD</b>    |                                 |    |    |    |    |    |     |
| Excitation System Nominal Response (PC.A.5.3.2(c))  | Sec <sup>-1</sup> |         | <input type="checkbox"/> | <b>DPD II</b> |                                 |    |    |    |    |    |     |
| $V_E$   |                   |         |                          |               |                                 |    |    |    |    |    |     |
| Rated Field Voltage (PC.A.5.3.2(c)) $U_{IN}$  | V                 |         | <input type="checkbox"/> | <b>DPD II</b> |                                 |    |    |    |    |    |     |
| No-load Field Voltage (PC.A.5.3.2(c)) $U_{IO}$  | V                 |         | <input type="checkbox"/> | <b>DPD II</b> |                                 |    |    |    |    |    |     |
| Excitation System On-Load (PC.A.5.3.2(c))   |                   |         | <input type="checkbox"/> |               |                                 |    |    |    |    |    |     |
| Positive Ceiling Voltage $U_{pL+}$  | V                 |         | <input type="checkbox"/> | <b>DPD II</b> |                                 |    |    |    |    |    |     |
| Excitation System No-Load (PC.A.5.3.2(c))   |                   |         | <input type="checkbox"/> |               |                                 |    |    |    |    |    |     |
| Positive Ceiling Voltage $U_{pO+}$  | V                 |         | <input type="checkbox"/> | <b>DPD II</b> |                                 |    |    |    |    |    |     |
| Excitation System No-Load (PC.A.5.3.2(c))   |                   |         | <input type="checkbox"/> |               |                                 |    |    |    |    |    |     |
| Negative Ceiling Voltage $U_{pO-}$  | V                 |         | <input type="checkbox"/> | <b>DPD II</b> |                                 |    |    |    |    |    |     |
| Power System Stabiliser (PSS) fitted (PC.A.3.4.2)   | Yes/No            |         | <input type="checkbox"/> | <b>SPD</b>    |                                 |    |    |    |    |    |     |
| <b>Stator Current Limit</b> (PC.A.5.3.2(c))   | A                 |         | <input type="checkbox"/> | <b>DPD II</b> |                                 |    |    |    |    |    |     |
| Details of <b>Excitation System</b> (PC.A.5.3.2(c)) (including PSS if fitted) described in block diagram form showing transfer functions of individual elements.  | Diagram           |         | <input type="checkbox"/> | <b>DPD II</b> |                                 |    |    |    |    |    |     |
| Details of <b>Over-excitation Limiter</b> (PC.A.5.3.2(c)) described in block diagram form showing transfer functions of individual elements.  | Diagram           |         | <input type="checkbox"/> | <b>DPD II</b> |                                 |    |    |    |    |    |     |

Formatted: Font: Bold

Formatted: Font: Bold

Formatted: Font: Bold

Formatted: Left

Formatted: Normal

Formatted: Font: 8 pt

Formatted: Font color: Auto

Details of **Under-excitation Limiter**  
(PC.A.5.3.2(c))

described in block diagram form showing  
transfer functions of individual elements.

Diagram

□

**DPD II**

**SCHEDULE 1 -- POWER GENERATING MODULE, GENERATING UNIT (OR CCGT MODULE), POWER PARK MODULE, DC CONNECTED POWER PARK MODULE, HVDC SYSTEM AND DC CONVERTER TECHNICAL DATA**

| DATA DESCRIPTION   | UNITS | DATA to RTL              |                | DATA CAT. | GENERATING UNIT OR STATION DATA |    |    |    |    |    |     |
|--|-------|--------------------------|----------------|-----------|---------------------------------|----|----|----|----|----|-----|
|  |       | CUSC Contract            | CUSC App. Form |           | G1                              | G2 | G3 | G4 | G5 | G6 | STN |
| <u>GOVERNOR AND ASSOCIATED PRIME MOVER PARAMETERS</u>  |       |                          |                |           |                                 |    |    |    |    |    |     |
| <p><u>Note:</u> The data items requested under Option 1 below may continue to be provided by <b>Generators</b> in relation to <b>Generating Units</b> on the <b>System</b> at 9 January 1995 (in this paragraph, the "relevant date") or they may provide the new data items set out under Option 2. <b>Generators</b> must supply the data as set out under Option 2 (and not those under Option 1) for <b>Generating Unit and Synchronous Power Generating Unit</b> governor control systems commissioned after the relevant date, those <b>Generating Unit and Synchronous Power Generating Unit</b> governor control systems recommissioned for any reason such as refurbishment after the relevant date and <b>Generating Unit and Synchronous Power Generating Unit</b> governor control systems where, as a result of testing or other process, the <b>Generator</b> is aware of the data items listed under Option 2 in relation to that <b>Generating Unit and Synchronous Power Generating Unit</b>.</p> |       |                          |                |           |                                 |    |    |    |    |    |     |
| <b>Option 1</b>  |       |                          |                |           |                                 |    |    |    |    |    |     |
| <u>GOVERNOR PARAMETERS (REHEAT UNITS) (PC.A.5.3.2(d) – Option 1(i))</u>  |       |                          |                |           |                                 |    |    |    |    |    |     |
| HP Governor average gain   | MW/Hz | <input type="checkbox"/> |                | DPD II    |                                 |    |    |    |    |    |     |
| Speeder motor setting range  | Hz    | <input type="checkbox"/> |                | DPD II    |                                 |    |    |    |    |    |     |
| HP governor valve time constant  | S     | <input type="checkbox"/> |                | DPD II    |                                 |    |    |    |    |    |     |
| HP governor valve opening limits   |       | <input type="checkbox"/> |                | DPD II    |                                 |    |    |    |    |    |     |
| HP governor valve rate limits  |       | <input type="checkbox"/> |                | DPD II    |                                 |    |    |    |    |    |     |
| Re-heat time constant (stored <b>Active Energy</b> in reheater)  | S     | <input type="checkbox"/> |                | DPD II    |                                 |    |    |    |    |    |     |
| IP governor average gain   | MW/Hz | <input type="checkbox"/> |                | DPD II    |                                 |    |    |    |    |    |     |
| IP governor setting range  | Hz    | <input type="checkbox"/> |                | DPD II    |                                 |    |    |    |    |    |     |
| IP governor time constant  | S     | <input type="checkbox"/> |                | DPD II    |                                 |    |    |    |    |    |     |
| IP governor valve opening limits   |       | <input type="checkbox"/> |                | DPD II    |                                 |    |    |    |    |    |     |
| IP governor valve rate limits  |       | <input type="checkbox"/> |                | DPD II    |                                 |    |    |    |    |    |     |
| Details of acceleration sensitive elements HP & IP in governor loop  |       | <input type="checkbox"/> |                | DPD II    | (please attach)                 |    |    |    |    |    |     |
| Governor block diagram showing transfer functions of individual elements   |       | <input type="checkbox"/> |                | DPD II    | (please attach)                 |    |    |    |    |    |     |
| <u>GOVERNOR (Non-reheat steam and Gas Turbines) (PC.A.5.3.2(d) – Option 1(ii))</u>   |       |                          |                |           |                                 |    |    |    |    |    |     |
| Governor average gain  | MW/Hz | <input type="checkbox"/> |                | DPD II    |                                 |    |    |    |    |    |     |
| Speeder motor setting range  |       | <input type="checkbox"/> |                | DPD II    |                                 |    |    |    |    |    |     |
| Time constant of steam or fuel governor valve  | S     | <input type="checkbox"/> |                | DPD II    |                                 |    |    |    |    |    |     |
| Governor valve opening limits  |       | <input type="checkbox"/> |                | DPD II    |                                 |    |    |    |    |    |     |
| Governor valve rate limits   |       | <input type="checkbox"/> |                | DPD II    |                                 |    |    |    |    |    |     |
| Time constant of turbine   | S     | <input type="checkbox"/> |                | DPD II    |                                 |    |    |    |    |    |     |
| Governor block diagram   |       | <input type="checkbox"/> |                | DPD II    | (please attach)                 |    |    |    |    |    |     |

**SCHEDULE 1 -- POWER GENERATING MODULE, GENERATING UNIT (OR CCGT MODULE), POWER PARK MODULE DC CONNECTED POWER PARK MODULE, HVDC SYSTEM AND DC CONVERTER TECHNICAL DATA**

| DATA DESCRIPTION  | UNITS | DATA to RTL   |                          | DATA CAT. | GENERATING UNIT OR STATION DATA |    |    |    |    |    |     |
|---|-------|---------------|--------------------------|-----------|---------------------------------|----|----|----|----|----|-----|
|   |       | CUSC Contract | CUSC App. Form           |           | G1                              | G2 | G3 | G4 | G5 | G6 | STN |
| <i>(PC.A.5.3.2(d) – Option 1(iii))</i><br><b>BOILER &amp; STEAM TURBINE DATA*</b>                                 |       |               |                          |           |                                 |    |    |    |    |    |     |
| Boiler time constant (Stored <b>Active Energy</b> )   | S     |               |                          | DPD II    |                                 |    |    |    |    |    |     |
| HP turbine response ratio:<br>(Proportion of <b>Primary Response</b> arising from HP turbine)                     | %     |               |                          | DPD II    |                                 |    |    |    |    |    |     |
| HP turbine response ratio:<br>(Proportion of <b>High Frequency Response</b> arising from HP turbine)              | %     |               |                          | DPD II    |                                 |    |    |    |    |    |     |
| End of Option 1   |       |               |                          |           |                                 |    |    |    |    |    |     |
| <b>Option 2</b>   |       |               |                          |           |                                 |    |    |    |    |    |     |
| <u>All Generating Units and Synchronous Power Generating Units</u>  |       |               |                          |           |                                 |    |    |    |    |    |     |
| Governor Block Diagram showing transfer function of individual elements including acceleration sensitive elements |       |               | <input type="checkbox"/> | DPD II    |                                 |    |    |    |    |    |     |
| Governor Time Constant<br><i>(PC.A.5.3.2(d) – Option 2(i))</i>  | Sec   |               | <input type="checkbox"/> | DPD II    |                                 |    |    |    |    |    |     |
| #Governor Deadband<br><i>(PC.A.5.3.2(d) – Option 2(i))</i>  |       |               |                          |           |                                 |    |    |    |    |    |     |
| - Maximum Setting   | ±Hz   |               |                          | DPD II    |                                 |    |    |    |    |    |     |
| - Normal Setting  | ±Hz   |               |                          | DPD II    |                                 |    |    |    |    |    |     |
| - Minimum Setting   | ±Hz   |               |                          | DPD II    |                                 |    |    |    |    |    |     |
| Speeder Motor Setting Range<br><i>(PC.A.5.3.2(d) – Option 2(i))</i>   | %     |               | <input type="checkbox"/> | DPD II    |                                 |    |    |    |    |    |     |
| Average Gain <i>(PC.A.5.3.2(d) – Option 2(i))</i>   | MW/Hz |               | <input type="checkbox"/> | DPD II    |                                 |    |    |    |    |    |     |
| <b>Steam Units</b>  |       |               |                          |           |                                 |    |    |    |    |    |     |
| <i>(PC.A.5.3.2(d) – Option 2(ii))</i>   |       |               |                          |           |                                 |    |    |    |    |    |     |
| HP Valve Time Constant  | sec   |               | <input type="checkbox"/> | DPD II    |                                 |    |    |    |    |    |     |
| HP Valve Opening Limits   | %     |               | <input type="checkbox"/> | DPD II    |                                 |    |    |    |    |    |     |
| HP Valve Opening Rate Limits  | %/sec |               | <input type="checkbox"/> | DPD II    |                                 |    |    |    |    |    |     |
| HP Valve Closing Rate Limits  | %/sec |               | <input type="checkbox"/> | DPD II    |                                 |    |    |    |    |    |     |
| HP Turbine Time Constant<br><i>(PC.A.5.3.2(d) – Option 2(ii))</i>   | sec   |               | <input type="checkbox"/> | DPD II    |                                 |    |    |    |    |    |     |
| IP Valve Time Constant  | sec   |               | <input type="checkbox"/> | DPD II    |                                 |    |    |    |    |    |     |
| IP Valve Opening Limits   | %     |               | <input type="checkbox"/> | DPD II    |                                 |    |    |    |    |    |     |
| IP Valve Opening Rate Limits  | %/sec |               | <input type="checkbox"/> | DPD II    |                                 |    |    |    |    |    |     |
| IP Valve Closing Rate Limits  | %/sec |               | <input type="checkbox"/> | DPD II    |                                 |    |    |    |    |    |     |
| IP Turbine Time Constant<br><i>(PC.A.5.3.2(d) – Option 2(ii))</i>   | sec   |               | <input type="checkbox"/> | DPD II    |                                 |    |    |    |    |    |     |
| LP Valve Time Constant  | sec   |               | <input type="checkbox"/> | DPD II    |                                 |    |    |    |    |    |     |
| LP Valve Opening Limits   | %     |               | <input type="checkbox"/> | DPD II    |                                 |    |    |    |    |    |     |
| LP Valve Opening Rate Limits  | %/sec |               | <input type="checkbox"/> | DPD II    |                                 |    |    |    |    |    |     |
| LP Valve Closing Rate Limits  | %/sec |               | <input type="checkbox"/> | DPD II    |                                 |    |    |    |    |    |     |
| LP Turbine Time Constant<br><i>(PC.A.5.3.2(d) – Option 2(ii))</i>   | sec   |               | <input type="checkbox"/> | DPD II    |                                 |    |    |    |    |    |     |
| Reheater Time Constant  | sec   |               |                          | DPD II    |                                 |    |    |    |    |    |     |
| Boiler Time Constant  | sec   |               |                          | DPD II    |                                 |    |    |    |    |    |     |
| HP Power Fraction   | %     |               |                          | DPD II    |                                 |    |    |    |    |    |     |
| IP Power Fraction   | %     |               |                          | DPD II    |                                 |    |    |    |    |    |     |

# Where the generating unit or synchronous power generating unit governor does not have a selectable deadband facility, then the actual value of the deadband need only be provided.

Formatted: Font: 10 pt

Formatted: Font: 10 pt, Not Bold

Formatted: Font: 10 pt

Formatted: Font: 10 pt, Not Bold

Formatted: Font: 10 pt, Not Bold

Formatted: Font: 10 pt, Not Bold

**SCHEDULE 1 – POWER GENERATING MODULE, GENERATING UNIT (OR CCGT MODULE), POWER PARK MODULE, DC CONNECTED POWER PARK MODULE, HVDC SYSTEM AND DC CONVERTER TECHNICAL DATA**

| DATA DESCRIPTION   | UNITS      | DATA to       |                          | DATA CAT.    | GENERATING UNIT OR STATION DATA |    |    |    |    |    |     |
|--|------------|---------------|--------------------------|--------------|---------------------------------|----|----|----|----|----|-----|
|  |            | CUSC Contract | CUSC App. Form           |              | G1                              | G2 | G3 | G4 | G5 | G6 | STN |
| <b>Gas Turbine Units</b>   |            |               |                          |              |                                 |    |    |    |    |    |     |
| <i>(PC.A.5.3.2(d) – Option 2(iii))</i>                               |            |               |                          |              |                                 |    |    |    |    |    |     |
| Inlet Guide Vane Time Constant                                       | sec        |               | <input type="checkbox"/> | DPD II       |                                 |    |    |    |    |    |     |
| Inlet Guide Vane Opening Limits                                      | %          |               | <input type="checkbox"/> | DPD II       |                                 |    |    |    |    |    |     |
| Inlet Guide Vane Opening Rate Limits                                 | %/sec      |               | <input type="checkbox"/> | DPD II       |                                 |    |    |    |    |    |     |
| Inlet Guide Vane Closing Rate Limits                                 | %/sec      |               | <input type="checkbox"/> | DPD II       |                                 |    |    |    |    |    |     |
| <i>(PC.A.5.3.2(d) – Option 2(iii))</i>                               |            |               |                          |              |                                 |    |    |    |    |    |     |
| Fuel Valve Time Constant   | sec        |               | <input type="checkbox"/> | DPD II       |                                 |    |    |    |    |    |     |
| Fuel Valve Opening Limits  | %          |               | <input type="checkbox"/> | DPD II       |                                 |    |    |    |    |    |     |
| Fuel Valve Opening Rate Limits                                       | %/sec      |               | <input type="checkbox"/> | DPD II       |                                 |    |    |    |    |    |     |
| Fuel Valve Closing Rate Limits                                       | %/sec      |               | <input type="checkbox"/> | DPD II       |                                 |    |    |    |    |    |     |
| <i>(PC.A.5.3.2(d) – Option 2(iii))</i>                               |            |               |                          |              |                                 |    |    |    |    |    |     |
| Waste Heat Recovery Boiler Time Constant                             |            |               |                          |              |                                 |    |    |    |    |    |     |
| <b>Hydro Generating Units</b>  |            |               |                          |              |                                 |    |    |    |    |    |     |
| <i>(PC.A.5.3.2(d) – Option 2(iv))</i>                                |            |               |                          |              |                                 |    |    |    |    |    |     |
| Guide Vane Actuator Time Constant                                    | sec        |               | <input type="checkbox"/> | DPD II       |                                 |    |    |    |    |    |     |
| Guide Vane Opening Limits  | %          |               | <input type="checkbox"/> | DPD II       |                                 |    |    |    |    |    |     |
| Guide Vane Opening Rate Limits                                       | %/sec      |               | <input type="checkbox"/> | DPD II       |                                 |    |    |    |    |    |     |
| Guide Vane Closing Rate Limits                                       | %/sec      |               | <input type="checkbox"/> | DPD II       |                                 |    |    |    |    |    |     |
| Water Time Constant  | sec        |               | <input type="checkbox"/> | DPD II       |                                 |    |    |    |    |    |     |
| End of Option 2  |            |               |                          |              |                                 |    |    |    |    |    |     |
| <b>UNIT CONTROL OPTIONS*</b>   |            |               |                          |              |                                 |    |    |    |    |    |     |
| <i>(PC.A.5.3.2(e))</i>   |            |               |                          |              |                                 |    |    |    |    |    |     |
| Maximum droop  | %          |               | <input type="checkbox"/> | DPD II       |                                 |    |    |    |    |    |     |
| Normal droop   | %          |               | <input type="checkbox"/> | DPD II       |                                 |    |    |    |    |    |     |
| Minimum droop  | %          |               | <input type="checkbox"/> | DPD II       |                                 |    |    |    |    |    |     |
| Maximum frequency deadband   | ±Hz        |               |                          | DPD II       |                                 |    |    |    |    |    |     |
| Normal frequency deadband  | ±Hz        |               |                          | DPD II       |                                 |    |    |    |    |    |     |
| Minimum frequency deadband   | ±Hz        |               |                          | DPD II       |                                 |    |    |    |    |    |     |
| <u>Maximum frequency Insensitivity1</u>                              | <u>±Hz</u> |               |                          | <u>DPDII</u> |                                 |    |    |    |    |    |     |
| <u>Normal frequency Insensitivity1</u>                               | <u>±Hz</u> |               |                          | <u>DPDII</u> |                                 |    |    |    |    |    |     |
| <u>Minimum frequency Insensitivity1</u>                              | <u>±Hz</u> |               |                          | <u>DPDII</u> |                                 |    |    |    |    |    |     |
| Maximum Output deadband  | ±MW        |               |                          | DPD II       |                                 |    |    |    |    |    |     |
| Normal Output deadband   | ±MW        |               |                          | DPD II       |                                 |    |    |    |    |    |     |
| Minimum Output deadband  | ±MW        |               |                          | DPD II       |                                 |    |    |    |    |    |     |
| <u>Maximum Output Insensitivity1</u>                                 | <u>±Hz</u> |               |                          | <u>DPDII</u> |                                 |    |    |    |    |    |     |
| <u>Normal Output Insensitivity1</u>                                  | <u>±Hz</u> |               |                          | <u>DPDII</u> |                                 |    |    |    |    |    |     |
| <u>Minimum Output Insensitivity1</u>                                 | <u>±Hz</u> |               |                          | <u>DPDII</u> |                                 |    |    |    |    |    |     |
| Frequency settings between which Unit Load Controller droop applies: |            |               |                          |              |                                 |    |    |    |    |    |     |
| Maximum  | Hz         |               |                          | DPD II       |                                 |    |    |    |    |    |     |
| Normal   | Hz         |               |                          | DPD II       |                                 |    |    |    |    |    |     |
| Minimum  | Hz         |               |                          | DPD II       |                                 |    |    |    |    |    |     |
| Sustained response normally selected                                 | Yes/No     |               |                          | DPD II       |                                 |    |    |    |    |    |     |

Formatted: Underline, Font color: Red





**SCHEDULE 1 -- POWER GENERATING MODULE, GENERATING UNIT (OR CCGT MODULE), POWER PARK MODULE, DC CONNECTED POWER PARK MODULE, HVDC SYSTEM AND DC CONVERTER TECHNICAL DATA**

| DATA DESCRIPTION  | UNITS   | DATA to RTL              |                                     | DATA CAT.     | POWER PARK UNIT (OR POWER PARK MODULE, AS THE CASE MAY BE)   |    |    |    |    |    |     |  |
|---|---|--------------------------|-------------------------------------|---------------|--|----|----|----|----|----|-----|--|
|   |   | CUSC Contract            | CUSC App. Form                      |               | G1   | G2 | G3 | G4 | G5 | G6 | STN |  |
| <b>Power Park Module Rated MVA</b><br><i>(PC.A.3.3.1(a))</i>  | MVA   | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <b>SPD+</b>   |  |    |    |    |    |    |     |  |
| <b>Power Park Module Rated MW</b><br><i>(PC.A.3.3.1(a))</i>   | MW  | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <b>SPD+</b>   |  |    |    |    |    |    |     |  |
| *Performance Chart of a <b>Power Park Module</b> at the connection point <i>(PC.A.3.2.2(f)(ii))</i>   |   |                          |                                     | <b>SPD</b>    | (see <b>OC2</b> for specification)   |    |    |    |    |    |     |  |
| *Output Usable (on a monthly basis)<br><i>(PC.A.3.2.2(b))</i>   | MW  |                          |                                     | <b>SPD</b>    | (except in relation to <b>CCGT Modules</b> when required on a unit basis under the <b>Grid Code</b> , this data item may be supplied under Schedule 3) |    |    |    |    |    |     |  |
| Number & Type of <b>Power Park Units</b> within each <b>Power Park Module</b> <i>(PC.A.3.2.2(k))</i>  |   | <input type="checkbox"/> |                                     | <b>SPD</b>    |  |    |    |    |    |    |     |  |
| Number & Type of <b>Offshore Power Park Units</b> within each <b>Offshore Power Park String</b> and the number of <b>Offshore Power Park Strings</b> and connection point within each <b>Offshore Power Park Module</b> <i>(PC.A.3.2.2.(k))</i>   |   |                          |                                     | <b>SPD</b>    |  |    |    |    |    |    |     |  |
| In the case where an appropriate <b>Manufacturer's Data &amp; Performance Report</b> is registered with <b>NGET</b> then subject to <b>NGET's</b> agreement, the report reference may be given as an alternative to completion of the following sections of this Schedule 1 to the end of page 11 with the exception of the sections marked thus # below. | Reference the <b>Manufacturer's Data &amp; Performance Report</b>                             |                          |                                     | <b>SPD</b>    |  |    |    |    |    |    |     |  |
| <b>Power Park Unit Model</b> - A validated mathematical model in accordance with <b>PC.5.4.2 (a)</b>  | Transfer function block diagram and algebraic equations, simulation and measured test results | <input type="checkbox"/> |                                     | <b>DPD II</b> |  |    |    |    |    |    |     |  |

**SCHEDULE 1 -- POWER GENERATING MODULE, GENERATING UNIT (OR CCGT MODULE), POWER PARK MODULE DC CONNECTED POWER PARK MODULE, HVDC SYSTEM AND DC CONVERTER TECHNICAL DATA**

| DATA DESCRIPTION  | UNITS                  | DATA to                  |                                     | DATA CAT. | POWER PARK UNIT (OR POWER PARK MODULE, AS THE CASE MAY BE) |    |    |    |    |    |     |  |
|---|------------------------|--------------------------|-------------------------------------|-----------|--|----|----|----|----|----|-----|--|
|   |                        | CUSC Contract            | CUSC App. Form                      |           | G1   | G2 | G3 | G4 | G5 | G6 | STN |  |
| <b>Power Park Unit Data</b> (where applicable)  |                        |                          |                                     |           |  |    |    |    |    |    |     |  |
| Rated MVA (PC.A.3.3.1(e))   | MVA                    | <input type="checkbox"/> | <input checked="" type="checkbox"/> | SPD+      |  |    |    |    |    |    |     |  |
| Rated MW (PC.A.3.3.1(e))  | MW                     | <input type="checkbox"/> | <input checked="" type="checkbox"/> | SPD+      |  |    |    |    |    |    |     |  |
| Rated terminal voltage (PC.A.3.3.1(e))  | V                      | <input type="checkbox"/> | <input checked="" type="checkbox"/> | SPD+      |  |    |    |    |    |    |     |  |
| Site minimum air density (PC.A.5.4.2(b))  | kg/m <sup>3</sup>      | <input type="checkbox"/> | <input checked="" type="checkbox"/> | DPD       |  |    |    |    |    |    |     |  |
| Site maximum air density  | kg/m <sup>3</sup>      | <input type="checkbox"/> | <input checked="" type="checkbox"/> | DPD       |  |    |    |    |    |    |     |  |
| Site average air density  | kg/m <sup>3</sup>      | <input type="checkbox"/> | <input checked="" type="checkbox"/> | DPD       |  |    |    |    |    |    |     |  |
| Year for which air density data is submitted  |                        | <input type="checkbox"/> | <input checked="" type="checkbox"/> | DPD       |  |    |    |    |    |    |     |  |
| Number of pole pairs  |                        | <input type="checkbox"/> | <input checked="" type="checkbox"/> | DPD       |  |    |    |    |    |    |     |  |
| Blade swept area  | m <sup>2</sup>         | <input type="checkbox"/> | <input checked="" type="checkbox"/> | DPD       |  |    |    |    |    |    |     |  |
| Gear Box Ratio  |                        | <input type="checkbox"/> | <input checked="" type="checkbox"/> | DPD       |  |    |    |    |    |    |     |  |
| Stator Resistance (PC.A.5.4.2(b))   | % on MVA               | <input type="checkbox"/> | <input checked="" type="checkbox"/> | SPD+      |  |    |    |    |    |    |     |  |
| Stator Reactance (PC.A.3.3.1(e))  | % on MVA               | <input type="checkbox"/> | <input checked="" type="checkbox"/> | SPD+      |  |    |    |    |    |    |     |  |
| Magnetising Reactance (PC.A.3.3.1(e))   | % on MVA               | <input type="checkbox"/> | <input checked="" type="checkbox"/> | SPD+      |  |    |    |    |    |    |     |  |
| Rotor Resistance (at starting). (PC.A.5.4.2(b))   | % on MVA               | <input type="checkbox"/> | <input checked="" type="checkbox"/> | DPD       |  |    |    |    |    |    |     |  |
| Rotor Resistance (at rated running) (PC.A.3.3.1(e))   | % on MVA               | <input type="checkbox"/> | <input checked="" type="checkbox"/> | SPD+      |  |    |    |    |    |    |     |  |
| Rotor Reactance (at starting). (PC.A.5.4.2(b))  | % on MVA               | <input type="checkbox"/> | <input checked="" type="checkbox"/> | DPD       |  |    |    |    |    |    |     |  |
| Rotor Reactance (at rated running) (PC.A.3.3.1(e))  | % on MVA               | <input type="checkbox"/> | <input checked="" type="checkbox"/> | SPD       |  |    |    |    |    |    |     |  |
| Equivalent inertia constant of the first mass (e.g. wind turbine rotor and blades) at minimum speed (PC.A.5.4.2(b))     | MW secs /MVA           | <input type="checkbox"/> | <input checked="" type="checkbox"/> | SPD+      |  |    |    |    |    |    |     |  |
| Equivalent inertia constant of the first mass (e.g. wind turbine rotor and blades) at synchronous speed (PC.A.5.4.2(b)) | MW secs /MVA           | <input type="checkbox"/> | <input checked="" type="checkbox"/> | SPD+      |  |    |    |    |    |    |     |  |
| Equivalent inertia constant of the first mass (e.g. wind turbine rotor and blades) at rated speed (PC.A.5.4.2(b))       | MW secs /MVA           | <input type="checkbox"/> | <input checked="" type="checkbox"/> | SPD+      |  |    |    |    |    |    |     |  |
| Equivalent inertia constant of the second mass (e.g. generator rotor) at minimum speed (PC.A.5.4.2(b))                  | MW secs /MVA           | <input type="checkbox"/> | <input checked="" type="checkbox"/> | SPD+      |  |    |    |    |    |    |     |  |
| Equivalent inertia constant of the second mass (e.g. generator rotor) at synchronous speed (PC.A.5.4.2(b))              | MW secs /MVA           | <input type="checkbox"/> | <input checked="" type="checkbox"/> | SPD+      |  |    |    |    |    |    |     |  |
| Equivalent inertia constant of the second mass (e.g. generator rotor) at rated speed (PC.A.5.4.2(b))                    | MW secs /MVA           | <input type="checkbox"/> | <input checked="" type="checkbox"/> | SPD+      |  |    |    |    |    |    |     |  |
| Equivalent shaft stiffness between the two masses (PC.A.5.4.2(b))   | Nm / electrical radian | <input type="checkbox"/> | <input checked="" type="checkbox"/> | SPD+      |  |    |    |    |    |    |     |  |

**SCHEDULE 1 -- POWER GENERATING MODULE, GENERATING UNIT (OR CCGT MODULE), POWER PARK MODULE, DC CONNECTED POWER PARK MODULE, HVDC SYSTEM AND DC CONVERTER TECHNICAL DATA**

| DATA DESCRIPTION   | UNITS                    | DATA to RTL              |                                     | DATA CAT. | POWER PARK UNIT (OR POWER PARK MODULE, AS THE CASE MAY BE) |    |    |    |    |    |     |  |
|--|--------------------------|--------------------------|-------------------------------------|-----------|--|----|----|----|----|----|-----|--|
|  |                          | CUSC Contract            | CUSC App. Form                      |           | G1   | G2 | G3 | G4 | G5 | G6 | STN |  |
| Minimum generator rotor speed (Doubly Fed Induction Generators) (PC.A.3.3.1(e))  | RPM                      | <input type="checkbox"/> | <input checked="" type="checkbox"/> | SPD+      |  |    |    |    |    |    |     |  |
| Maximum generator rotor speed (Doubly Fed Induction Generators) (PC.A.3.3.1(e))  | RPM                      | <input type="checkbox"/> | <input checked="" type="checkbox"/> | SPD+      |  |    |    |    |    |    |     |  |
| The optimum generator rotor speed versus wind speed (PC.A.5.4.2(b))  | tabular format           | <input type="checkbox"/> |                                     | DPD II    |  |    |    |    |    |    |     |  |
| Power Converter Rating (Doubly Fed Induction Generators) (PC.A.5.4.2(b))   | MVA                      | <input type="checkbox"/> | <input checked="" type="checkbox"/> | DPD II    |  |    |    |    |    |    |     |  |
| The rotor power coefficient (C <sub>p</sub> ) versus tip speed ratio (λ) curves for a range of blade angles (where applicable) (PC.A.5.4.2(b))   | Diagram + tabular format | <input type="checkbox"/> |                                     | DPD II    |  |    |    |    |    |    |     |  |
| # The electrical power output versus generator rotor speed for a range of wind speeds over the entire operating range of the <b>Power Park Unit</b> . (PC.A.5.4.2(b))  | Diagram + tabular format | <input type="checkbox"/> |                                     | DPD II    |  |    |    |    |    |    |     |  |
| The blade angle versus wind speed curve (PC.A.5.4.2(b))  | Diagram + tabular format | <input type="checkbox"/> |                                     | DPD II    |  |    |    |    |    |    |     |  |
| The electrical power output versus wind speed over the entire operating range of the <b>Power Park Unit</b> . (PC.A.5.4.2(b))  | Diagram + tabular format | <input type="checkbox"/> |                                     | DPD II    |  |    |    |    |    |    |     |  |
| Transfer function block diagram, parameters and description of the operation of the power electronic converter including fault ride through capability (where applicable). (PC.A.5.4.2(b))   | Diagram                  | <input type="checkbox"/> |                                     | DPD II    |  |    |    |    |    |    |     |  |
| For a <b>Power Park Unit</b> consisting of a synchronous machine in combination with a back to back <b>DC Converter</b> or <b>HVDC Converter</b> , or for a <b>Power Park Unit</b> not driven by a wind turbine, the data to be supplied shall be agreed with <b>NGET</b> in accordance with PC.A.7. (PC.A.5.4.2(b)) |                          | <input type="checkbox"/> |                                     |           |  |    |    |    |    |    |     |  |

Formatted: Font: Not Bold

**SCHEDULE 1 -- POWER GENERATING MODULE, GENERATING UNIT (OR CCGT MODULE), POWER PARK MODULE, DC CONNECTED POWER PARK MODULE, HVDC SYSTEM AND DC CONVERTER TECHNICAL DATA**

| DATA DESCRIPTION   | UNITS          | DATA to RTL              |                | DATA CAT.     | POWER PARK UNIT (OR POWER PARK MODULE, AS THE CASE MAY BE) |    |    |    |    |    |     |  |
|--|----------------|--------------------------|----------------|---------------|--|----|----|----|----|----|-----|--|
|  |                | CUSC Contract            | CUSC App. Form |               | G1   | G2 | G3 | G4 | G5 | G6 | STN |  |
| Torque / Speed and blade angle control systems and parameters (PC.A.5.4.2(c))<br><br>For the <b>Power Park Unit</b> , details of the torque / speed controller and blade angle controller in the case of a wind turbine and power limitation functions (where applicable) described in block diagram form showing transfer functions and parameters of individual elements | Diagram        | <input type="checkbox"/> |                | <b>DPD II</b> |  |    |    |    |    |    |     |  |
| # Voltage/Reactive Power/Power Factor control system parameters (PC.A.5.4.2(d))<br><br># For the <b>Power Park Unit</b> and <b>Power Park Module</b> details of <b>Voltage/Reactive Power/Power Factor</b> controller (and <b>PSS</b> if fitted) described in block diagram form including parameters showing transfer functions of individual elements.                   | Diagram        | <input type="checkbox"/> |                | <b>DPD II</b> |  |    |    |    |    |    |     |  |
| # <b>Frequency</b> control system parameters (PC.A.5.4.2(e))<br># For the <b>Power Park Unit</b> and <b>Power Park Module</b> details of the <b>Frequency</b> controller described in block diagram form showing transfer functions and parameters of individual elements.   | Diagram        | <input type="checkbox"/> |                | <b>DPD II</b> |  |    |    |    |    |    |     |  |
| As an alternative to PC.A.5.4.2 (a), (b), (c), (d), (e) and (f), is the submission of a single complete model that consists of the full information required under PC.A.5.4.2 (a), (b), (c), (d) (e) and (f) provided that all the information required under PC.A.5.4.2 (a), (b), (c), (d), (e) and (f) individually is clearly identifiable. (PC.A.5.4.2(g))             | Diagram        | <input type="checkbox"/> |                | <b>DPD II</b> |  |    |    |    |    |    |     |  |
| # Harmonic Assessment Information (PC.A.5.4.2(h)) (as defined in IEC 61400-21 (2001)) for each <b>Power Park Unit</b> :-   |                |                          |                |               |  |    |    |    |    |    |     |  |
| # Flicker coefficient for continuous operation   |                | <input type="checkbox"/> |                | <b>DPD I</b>  |  |    |    |    |    |    |     |  |
| # Flicker step factor  |                | <input type="checkbox"/> |                | <b>DPD I</b>  |  |    |    |    |    |    |     |  |
| # Number of switching operations in a 10 minute window   |                | <input type="checkbox"/> |                | <b>DPD I</b>  |  |    |    |    |    |    |     |  |
| # Number of switching operations in a 2 hour window  |                | <input type="checkbox"/> |                | <b>DPD I</b>  |  |    |    |    |    |    |     |  |
| # Voltage change factor  |                | <input type="checkbox"/> |                | <b>DPD I</b>  |  |    |    |    |    |    |     |  |
| # Current Injection at each harmonic for each <b>Power Park Unit</b> and for each <b>Power Park Module</b>   | Tabular format | <input type="checkbox"/> |                | <b>DPD I</b>  |  |    |    |    |    |    |     |  |
| <b>Note:- Generators who own or operate DC Connected Power Park Modules shall supply all data for their DC Connected Power Park Modules as applicable to Power Park Modules.</b>   |                |                          |                |               |  |    |    |    |    |    |     |  |

Formatted: Font: Bold

**SCHEDULE 1 -- POWER GENERATING MODULE, GENERATING UNIT (OR CCGT MODULE), POWER PARK MODULE, DC CONNECTED POWER PARK MODULE, HVDC SYSTEM AND DC CONVERTER TECHNICAL DATA**  
PAGE 14 OF 19

HVDC SYSTEM AND DC CONVERTER STATION TECHNICAL DATA

HVDC SYSTEM OR DC CONVERTER STATION NAME

DATE: \_\_\_\_\_

| Data Description   | Units      | DATA to RTL              |                                     | Data Category    | DC Converter Station Data |
|--|------------|--------------------------|-------------------------------------|------------------|---------------------------|
|  |            | CUSC Contract            | CUSC App. Form                      |                  |                           |
| (PC.A.4)   |            |                          |                                     |                  |                           |
| <b>HVDC SYSTEM AND DC CONVERTER STATION DEMANDS:</b>   |            |                          |                                     |                  |                           |
| <b>Demand</b> supplied through <b>Station Transformers</b> associated with the <b>DC Converter Station</b> <u>and HVDC System</u> [PC.A.4.1]                                     | MW<br>MVar | <input type="checkbox"/> | <input type="checkbox"/>            | DPD II<br>DPD II |                           |
| - Demand with all <b>DC Converters</b> <u>and HVDC Converters</u> within and HVDC System operating at <b>Rated MW</b> import.  | MW<br>MVar | <input type="checkbox"/> | <input type="checkbox"/>            | DPD II<br>DPD II |                           |
| - Demand with all <b>DC Converters</b> <u>and HVDC Converters</u> within an HVDC System operating at <b>Rated MW</b> export.   |            |                          |                                     |                  |                           |
| Additional <b>Demand</b> associated with the <b>DC Converter Station</b> <u>or HVDC System</u> supplied through the <b>National Electricity Transmission System</b> . [PC.A.4.1] | MW<br>MVar | <input type="checkbox"/> | <input type="checkbox"/>            | DPD II<br>DPD II |                           |
| - The maximum <b>Demand</b> that could occur.  | MW<br>MVar | <input type="checkbox"/> | <input type="checkbox"/>            | DPD II<br>DPD II |                           |
| - Demand at specified time of annual peak half hour of <b>NGET Demand</b> at <b>Annual ACS Conditions</b> .  | MW<br>MVar | <input type="checkbox"/> | <input type="checkbox"/>            | DPD II<br>DPD II |                           |
| - Demand at specified time of annual minimum half-hour of <b>NGET Demand</b> .   | Text       | <input type="checkbox"/> | <input checked="" type="checkbox"/> | SPD+             |                           |
| <b>DC CONVERTER STATION AND HVDC SYSTEM DATA</b>   | Text       | <input type="checkbox"/> | <input checked="" type="checkbox"/> | SPD+             |                           |
| Number of poles, i.e. number of <b>DC Converters</b> <u>or HVDC Converters</u> within the <b>HVDC System</b>   |            | <input type="checkbox"/> | <input checked="" type="checkbox"/> | SPD+             |                           |
| Pole arrangement (e.g. monopole or bipole)   |            | <input type="checkbox"/> | <input checked="" type="checkbox"/> |                  |                           |
| Details of each viable operating configuration   |            | <input type="checkbox"/> | <input checked="" type="checkbox"/> |                  |                           |
| Configuration 1  | Diagram    | <input type="checkbox"/> | <input checked="" type="checkbox"/> | SPD              |                           |
| Configuration 2  | Diagram    |                          |                                     |                  |                           |
| Configuration 3  | Diagram    |                          |                                     |                  |                           |
| Configuration 4  | Diagram    |                          |                                     |                  |                           |

Formatted: Font: Not Bold

Formatted: Font: Not Bold

Formatted: Font: Not Bold

Formatted: Font: Not Bold

Formatted: Font: Bold

Formatted: Font: Not Bold

Formatted: Font: Not Bold

Formatted: Left

|                                    |         |  |  |  |  |
|------------------------------------|---------|--|--|--|--|
| Configuration 5<br>Configuration 6 | Diagram |  |  |  |  |
| Remote ac connection arrangement   | Diagram |  |  |  |  |

**SCHEDULE 1 -- POWER PARK MODULE, GENERATING UNIT (OR CCGT MODULE),  
POWER PARK MODULE, DC CONNECTED POWER PARK MODULE, HVDC SYSTEM  
AND DC CONVERTER TECHNICAL DATA**

| Data Description   | Units          | DATA to RTL              |                                     | Data Category | Operating Configuration |   |   |   |   |   |
|--|----------------|--------------------------|-------------------------------------|---------------|-------------------------|---|---|---|---|---|
|  |                | CUSC Contract            | CUSC App. Form                      |               | 1                       | 2 | 3 | 4 | 5 | 6 |
| <b>DC CONVERTER STATION AND HVDC SYSTEM DATA (PC.A.3.3.1d)</b>   |                |                          |                                     |               |                         |   |   |   |   |   |
| <b>DC Converter or HVDC Converter Type</b> (e.g. current or Voltage source)  | Text           | <input type="checkbox"/> | <input checked="" type="checkbox"/> | SPD           |                         |   |   |   |   |   |
| Point of connection to the <b>NGET Transmission System</b> (or the <b>Total System if Embedded</b> ) of the <b>DC Converter Station or HVDC System</b> configuration in terms of geographical and electrical location and system voltage | Text           | <input type="checkbox"/> | <input checked="" type="checkbox"/> | SPD           |                         |   |   |   |   |   |
| If the busbars at the <b>Connection Point</b> are normally run in separate sections identify the section to which the <b>DC Converter Station or HVDC System</b> configuration is connected  | Section Number | <input type="checkbox"/> | <input checked="" type="checkbox"/> | SPD           |                         |   |   |   |   |   |
| <b>Rated MW import per pole [PC.A.3.3.1]</b>   | MW             | <input type="checkbox"/> | <input checked="" type="checkbox"/> | SPD +         |                         |   |   |   |   |   |
| <b>Rated MW export per pole [PC.A.3.3.1]</b>   | MW             | <input type="checkbox"/> | <input checked="" type="checkbox"/> | SPD +         |                         |   |   |   |   |   |
| <b>ACTIVE POWER TRANSFER CAPABILITY (PC.A.3.2.2)</b>   |                |                          |                                     |               |                         |   |   |   |   |   |
| <b>Registered Capacity</b>   | MW             | <input type="checkbox"/> | <input checked="" type="checkbox"/> | SPD           |                         |   |   |   |   |   |
| <b>Registered Import Capacity</b>  | MW             | <input type="checkbox"/> | <input checked="" type="checkbox"/> | SPD           |                         |   |   |   |   |   |
| <b>Minimum Generation</b>  | MW             | <input type="checkbox"/> | <input checked="" type="checkbox"/> | SPD           |                         |   |   |   |   |   |
| <b>Minimum Import Capacity</b>   | MW             | <input type="checkbox"/> | <input checked="" type="checkbox"/> | SPD           |                         |   |   |   |   |   |
| <b>Maximum HVDC Active Power Transmission Capacity</b>   | MW             | <input type="checkbox"/> | <input checked="" type="checkbox"/> | SPD           |                         |   |   |   |   |   |
| <b>Minimum Active Power Transmission Capacity</b>  | MW             | <input type="checkbox"/> | <input checked="" type="checkbox"/> | SPD           |                         |   |   |   |   |   |
| Import MW available in excess of <b>Registered Import Capacity and Maximum Active Power Transmission Capacity</b>  | MW             | <input type="checkbox"/> | <input checked="" type="checkbox"/> | SPD           |                         |   |   |   |   |   |
| Time duration for which MW in excess of <b>Registered Import Capacity</b> is available   | Min            | <input type="checkbox"/> | <input checked="" type="checkbox"/> | SPD           |                         |   |   |   |   |   |
| Export MW available in excess of <b>Registered Capacity and Maximum Active Power Transmission Capacity</b>   | MW             | <input type="checkbox"/> | <input checked="" type="checkbox"/> | SPD           |                         |   |   |   |   |   |
| Time duration for which MW in excess of <b>Registered Capacity</b> is available  | Min            | <input type="checkbox"/> | <input checked="" type="checkbox"/> | SPD           |                         |   |   |   |   |   |

Formatted: Font: Bold

Formatted: Font: Bold

Formatted: Font: Not Bold

Formatted: Font: Bold

Formatted: Left

Formatted: Left

Formatted: Left

Formatted: Indent: Left: 0 cm, First line: 0 cm

Formatted: Left

Formatted: Font: Not Bold

Formatted: Font: Not Bold





**SCHEDULE 1 --POWER GENERATING MODULE, GENERATING UNIT (OR CCGT MODULE), POWER PARK MODULE, DC CONNECTED POWER PARK MODULE, HVDC SYSTEM AND DC CONVERTER TECHNICAL DATA**

| Data Description   | Units    | DATA to RTL              |                | Data Category | Operating Configuration |   |   |   |   |   |  |
|--|----------|--------------------------|----------------|---------------|-------------------------|---|---|---|---|---|--|
|  |          | CUSC Contract            | CUSC App. Form |               | 1                       | 2 | 3 | 4 | 5 | 6 |  |
| <b>DC CONVERTER AND HVDC CONVERTER TRANSFORMER [PC.A.5.4.3.1</b> |          |                          |                | <b>DPD II</b> |                         |   |   |   |   |   |  |
| Rated MVA  | MVA      | <input type="checkbox"/> |                | <b>DPD II</b> |                         |   |   |   |   |   |  |
| Winding arrangement  | kV       | <input type="checkbox"/> |                | <b>DPD II</b> |                         |   |   |   |   |   |  |
| Nominal primary voltage  | kV       | <input type="checkbox"/> |                | <b>DPD II</b> |                         |   |   |   |   |   |  |
| Nominal secondary (converter-side) voltage(s)                    |          | <input type="checkbox"/> |                | <b>DPD II</b> |                         |   |   |   |   |   |  |
| Positive sequence reactance                                      | % on MVA | <input type="checkbox"/> |                | <b>DPD II</b> |                         |   |   |   |   |   |  |
| Maximum tap  | % on MVA | <input type="checkbox"/> |                | <b>DPD II</b> |                         |   |   |   |   |   |  |
| Nominal tap  | MVA      |                          |                | <b>DPD II</b> |                         |   |   |   |   |   |  |
| Minimum tap  | % on MVA | <input type="checkbox"/> |                | <b>DPD II</b> |                         |   |   |   |   |   |  |
| Positive sequence resistance                                     | % on MVA | <input type="checkbox"/> |                | <b>DPD II</b> |                         |   |   |   |   |   |  |
| Maximum tap  | % on MVA | <input type="checkbox"/> |                | <b>DPD II</b> |                         |   |   |   |   |   |  |
| Nominal tap  | MVA      | <input type="checkbox"/> |                | <b>DPD II</b> |                         |   |   |   |   |   |  |
| Minimum tap  | % on MVA | <input type="checkbox"/> |                | <b>DPD II</b> |                         |   |   |   |   |   |  |
| Zero phase sequence reactance                                    | MVA      | <input type="checkbox"/> |                | <b>DPD II</b> |                         |   |   |   |   |   |  |
| Tap change range   | % on MVA | <input type="checkbox"/> |                | <b>DPD II</b> |                         |   |   |   |   |   |  |
| Number of steps  | MVA      |                          |                | <b>DPD II</b> |                         |   |   |   |   |   |  |
|  | % on MVA |                          |                |               |                         |   |   |   |   |   |  |
|  | MVA      |                          |                |               |                         |   |   |   |   |   |  |
|  | % on MVA |                          |                |               |                         |   |   |   |   |   |  |
|  | MVA      |                          |                |               |                         |   |   |   |   |   |  |
|  | +% / -%  |                          |                |               |                         |   |   |   |   |   |  |

Formatted: Font: Bold

**SCHEDULE 1 -- POWER GENERATING MODULE, GENERATING UNIT (OR CCGT MODULE), DC CONNECTED POWER PARK MODULE, HVDC SYSTEM, POWER PARK MODULE AND DC CONVERTER TECHNICAL DATA**

| Data Description  | Units   | DATA to RTL   |  | Data Category  | Operating configuration |   |   |   |   |   |
|---|---|---|--|--|-------------------------|---|---|---|---|---|
|   |   | CUSC Contract   | CUSC App. Form   |  | 1                       | 2 | 3 | 4 | 5 | 6 |
| <p><b>DC NETWORK [PC.A.5.4.3.1 (c)]</b></p> <p>Rated DC voltage per pole<br/>Rated DC current per pole</p> <p>Details of the <b>DC Network</b> described in diagram form including resistance, inductance and capacitance of all DC cables and/or DC lines. Details of any line reactors (including line reactor resistance), line capacitors, DC filters, earthing electrodes and other conductors that form part of the <b>DC Network</b> should be shown.</p>        | <p>kV<br/>A</p> <p>Diagram</p>  | <p><input type="checkbox"/><br/><input type="checkbox"/><br/><input type="checkbox"/></p>   |  | <p><b>DPD II</b><br/><b>DPD II</b><br/><b>DPD II</b></p>   |                         |   |   |   |   |   |
| <p><b>DC CONVERTER STATION AND HVDC SYSTEM AC HARMONIC FILTER AND REACTIVE COMPENSATION EQUIPMENT [PC.A.5.4.3.1 (d)]</b></p> <p>For all switched reactive compensation equipment</p> <p>Total number of AC filter banks<br/>Diagram of filter connections<br/>Type of equipment (e.g. fixed or variable)<br/>Capacitive rating; or<br/>Inductive rating; or<br/>Operating range</p> <p><b>Reactive Power</b> capability as a function of various MW transfer levels</p> | <p>Diagram</p> <p>Text<br/>Diagram<br/>Text<br/>MVAR<br/>MVAR<br/>MVAR</p> <p>Table</p> | <p><input type="checkbox"/><br/><input type="checkbox"/><br/><input type="checkbox"/><br/><input type="checkbox"/><br/><input type="checkbox"/><br/><input type="checkbox"/><br/><input type="checkbox"/></p> | <p><input checked="" type="checkbox"/><br/><input checked="" type="checkbox"/><br/><input checked="" type="checkbox"/><br/><input checked="" type="checkbox"/></p> | <p><b>DPD II</b><br/><b>DPD II</b><br/><b>DPD II</b><br/><b>DPD II</b><br/><b>DPD II</b><br/><b>DPD II</b><br/><b>DPD II</b></p> |                         |   |   |   |   |   |

**Formatted:** Font: Bold

**SCHEDULE 1 -- POWER GENERATING MODULE, GENERATING UNIT (OR CCGT MODULE), POWER PARK MODULE, DC CONNECTED POWER PARK MODULE, HVDC SYSTEM AND DC CONVERTER TECHNICAL DATA**

PAGE 18 OF 19

| Data Description | Units | DATA to<br>RTL   |                      | Data<br>Category | Operating<br>configuration |   |   |   |   |   |  |
|------------------|-------|------------------|----------------------|------------------|----------------------------|---|---|---|---|---|--|
|                  |       | CUSC<br>Contract | CUSC<br>App.<br>Form |                  | 1                          | 2 | 3 | 4 | 5 | 6 |  |
|                  |       |                  |                      |                  |                            |   |   |   |   |   |  |

Formatted Table

| Data Description  | Units              | DATA to RTL  |                | Data Category    | Operating configuration |   |   |   |   |   |
|---|--------------------|--|----------------|------------------|-------------------------|---|---|---|---|---|
|   |                    | CUSC Contract  | CUSC App. Form |                  | 1                       | 2 | 3 | 4 | 5 | 6 |
| <b>CONTROL SYSTEMS [PC.A.5.4.3.2]</b>   |                    |  |                |                  |                         |   |   |   |   |   |
| Static $V_{DC} - P_{DC}$ (DC voltage – DC power) or<br>Static $V_{DC} - I_{DC}$ (DC voltage – DC current) characteristic (as appropriate) when operating as<br>–Rectifier<br>–Inverter  | Diagram<br>Diagram | <input type="checkbox"/><br><input type="checkbox"/> |                | DPD II<br>DPD II |                         |   |   |   |   |   |
| Details of rectifier mode control system, in block diagram form together with parameters showing transfer functions of individual elements.   | Diagram            | <input type="checkbox"/>                             |                | DPD II           |                         |   |   |   |   |   |
| Details of inverter mode control system, in block diagram form showing transfer functions of individual elements including parameters.  | Diagram            | <input type="checkbox"/>                             |                | DPD II           |                         |   |   |   |   |   |
| Details of converter transformer tap changer control system in block diagram form showing transfer functions of individual elements including parameters. (Only required for <b>DC Converters and HVDC Systems</b> connected to the <b>National Electricity Transmission System</b> .)              | Diagram            | <input type="checkbox"/>                             |                | DPD II           |                         |   |   |   |   |   |
| Details of AC filter and reactive compensation equipment control systems in block diagram form showing transfer functions of individual elements including parameters. (Only required for <b>DC Converters and HVDC Systems</b> connected to the <b>National Electricity Transmission System</b> .) | Diagram            | <input type="checkbox"/>                             |                | DPD II           |                         |   |   |   |   |   |
| Details of any frequency and/or load control systems in block diagram form showing transfer functions of individual elements including parameters.  | Diagram            | <input type="checkbox"/>                             |                | DPD II           |                         |   |   |   |   |   |
| Details of any large or small signal modulating controls, such as power oscillation damping controls or sub-synchronous oscillation damping controls, that have not been submitted as part of the above control system data.  | Diagram            | <input type="checkbox"/>                             |                | DPD II           |                         |   |   |   |   |   |
| <u>Details of HVDC Converter unit models and/or control systems in block diagram form showing transfer functions of individual elements including parameters.</u>   | Diagram            | <input type="checkbox"/>                             |                | DPD II           |                         |   |   |   |   |   |
| <u>Details of AC component models and/or control systems in block diagram form showing transfer functions of individual elements including parameters.</u>  | Diagram            | <input type="checkbox"/>                             |                | DPD II           |                         |   |   |   |   |   |
| <u>Details of DC Grid models and/or control systems in block diagram form showing transfer functions of individual elements including parameters.</u>   | Diagram            | <input type="checkbox"/>                             |                | DPD II           |                         |   |   |   |   |   |
| <u>Details of Voltage and power controller and/or control systems in block diagram form showing transfer functions of individual elements including parameters.</u>   | Diagram            | <input type="checkbox"/>                             |                | DPD II           |                         |   |   |   |   |   |
| <u>Details of Special control features if applicable (eg power oscillation damping (POD) function, subsynchronous torsional interaction (SSTI) control and/or control systems in block diagram form showing transfer functions of individual elements including parameters.</u>                     | Diagram            | <input type="checkbox"/>                             |                | DPD II           |                         |   |   |   |   |   |
| <u>Details of Multi terminal control, if applicable and/or control systems in block diagram form showing transfer functions of individual elements including parameters.</u>  | Diagram            | <input type="checkbox"/>                             |                | DPD II           |                         |   |   |   |   |   |
| <u>Details of HVDC System protection models as agreed between NGET the HVDC System Owner and/or control systems in block diagram form showing transfer functions of individual elements including parameters.</u>   | Diagram            | <input type="checkbox"/>                             |                | DPD II           |                         |   |   |   |   |   |
| <u>Transfer block diagram representation of the reactive power control at converter ends for a voltage source converter</u>   | Diagram            | <input type="checkbox"/>                             |                | DPD II           |                         |   |   |   |   |   |

Formatted Table

Formatted: Font: Bold

Formatted: Left

Formatted: Font: Bold

Formatted: Left

Formatted: Left

Formatted: Left



**SCHEDULE 1 -- POWER GENERATING MODULE, GENERATING UNIT (OR CCGT MODULE), POWER PARK MODULE, DC CONNECTED POWER PARK MODULE, HVDC SYSTEM AND DC CONVERTER TECHNICAL DATA**

| Data Description   | Units | DATA to RTL   |                | Data Category | Operating configuration |   |   |   |   |   |
|--|-------|---------------|----------------|---------------|-------------------------|---|---|---|---|---|
|  |       | CUSC Contract | CUSC App. Form |               | 1                       | 2 | 3 | 4 | 5 | 6 |
| <b>LOADING PARAMETERS [PC.A.5.4.3.3]</b>   |       |               |                |               |                         |   |   |   |   |   |
| MW Export  |       |               |                |               |                         |   |   |   |   |   |
| Nominal loading rate   | MW/s  |               |                | DPD I         |                         |   |   |   |   |   |
| Maximum (emergency) loading rate   | MW/s  |               |                | DPD I         |                         |   |   |   |   |   |
| MW Import  |       |               |                |               |                         |   |   |   |   |   |
| Nominal loading rate   | MW/s  |               |                | DPD I         |                         |   |   |   |   |   |
| Maximum (emergency) loading rate   | MW/s  |               |                | DPD I         |                         |   |   |   |   |   |
| Maximum recovery time, to 90% of pre-fault loading, following an AC system fault or severe voltage depression. | s     |               | □              | DPD II        |                         |   |   |   |   |   |
| Maximum recovery time, to 90% of pre-fault loading, following a transient DC Network fault.                    | s     |               | □              | DPD II        |                         |   |   |   |   |   |

**NOTE:** **Existing Users** are referred to Schedules 5 & 14 which set down data required for all **Existing Users** directly connected to the **National Electricity Transmission System**, including **Power Stations**. **Generators** undertaking **OTSDUW Arrangements** and are utilising an **OTSDUW DC Converter** are referred to Schedule 18.

**Comment [A2]:** House Keeping change - bold

## SCHEDULE 2 - GENERATION PLANNING PARAMETERS

PAGE 1 OF 3

This schedule contains the **Genset Generation Planning Parameters** required by **NGET** to facilitate studies in **Operational Planning** timescales.

For a **Generating Unit** including those within a **Power Generating Module** (other than a **Power Park Unit**) at a **Large Power Station** the information is to be submitted on a unit basis and for a **CCGT Module** or **Power Park Module** at a **Large Power Station** the information is to be submitted on a module basis, unless otherwise stated.

Where references to **CCGT Modules** or **Power Park Modules** at a **Large Power Station** are made, the columns "G1" etc should be amended to read "M1" etc, as appropriate.

**Power Station:** \_\_\_\_\_

### Generation Planning Parameters

| DATA DESCRIPTION   | UNITS  | DATA to RTL                    |                                | DATA CAT.                                  | GENSET OR STATION DATA |    |    |    |    |    |     |  |
|--|--|--------------------------------|--------------------------------|--|------------------------|----|----|----|----|----|-----|--|
|  |  | CUSC Contract                  | CUSC App. Form                 |  | G1                     | G2 | G3 | G4 | G5 | G6 | STN |  |
| <b>OUTPUT CAPABILITY</b><br><i>(PC.A.3.2.2)</i><br><b>Registered Capacity</b> on a station and unit basis (on a station and module basis in the case of a <b>CCGT Module</b> or <b>Power Park Module</b> at a <b>Large Power Station</b> )   | MW   |                                |                                | SPD  |                        |    |    |    |    |    |     |  |
| <b>Maximum Capacity on a Power Generating Module basis and Synchronous Generating Unit basis and Registered Capacity on a Power Station basis</b>  |  | □                              | ■                              |  |                        |    |    |    |    |    |     |  |
| <b>Minimum Generation</b> (on a module basis in the case of a <b>CCGT Module</b> or <b>Power Park Module</b> at a <b>Large Power Station</b> )   | MW   |                                |                                | SPD  |                        |    |    |    |    |    |     |  |
| <b>Minimum Stable Operating Level</b> (on a module basis in the case of a <b>Power Generating Module</b> at a <b>Large Power Station</b> )   |  | □                              | ■                              |  |                        |    |    |    |    |    |     |  |
| MW available from <b>Power Generating Modules and Generating Units or Power Park Modules</b> in excess of <b>Registered Capacity or Maximum Capacity</b>   | MW   | □                              | ■                              | SPD  |                        |    |    |    |    |    |     |  |
| <b>REGIME UNAVAILABILITY</b><br><br>These data blocks are provided to allow fixed periods of unavailability to be registered.<br><b>Expected Running Regime.</b> Is <b>Power Station</b> normally available for full output 24 hours per day, 7 days per week? If No please provide details of unavailability below.<br><i>(PC.A.3.2.2.)</i><br>Earliest <b>Synchronising</b> time: <i>OC2.4.2.1(a)</i><br>Monday<br>Tuesday – Friday<br>Saturday – Sunday<br><br>Latest <b>De-Synchronising</b> time: <i>OC2.4.2.1(a)</i><br>Monday – Thursday<br>Friday<br>Saturday – Sunday | hr/min<br>hr/min<br>hr/min<br><br>hr/min<br>hr/min<br>hr/min | ■<br>■<br>■<br><br>■<br>■<br>■ | ■<br>■<br>■<br><br>■<br>■<br>■ | OC2<br>OC2<br>OC2<br><br>OC2<br>OC2<br>OC2 |                        |    |    |    |    |    |     |  |
| <b>SYNCHRONISING PARAMETERS</b><br><i>OC2.4.2.1(a)</i>   |  |                                |                                |  |                        |    |    |    |    |    |     |  |

Formatted: Font: Bold

Formatted: Font: Not Bold

Formatted: Font: Not Bold

Formatted: Font: Not Bold

Formatted: Font: Not Bold

Formatted: Font: Not Bold

Formatted: Indent: Left: 0 cm, First line: 0 cm

Formatted: Font: Bold

Formatted: Indent: Left: 0 cm

Formatted: Font: Bold

Formatted: Font: Bold

Formatted: Font: Bold

Formatted: Font: Not Bold



|  |        |   |  |  |            |            |   |   |   |   |   |   |   |   |   |   |   |   |
|--|--------|---|--|--|------------|------------|---|---|---|---|---|---|---|---|---|---|---|---|
| Notice to Deviate from Zero (NDZ) after 48 hour<br><b>Shutdown</b>           | Mins   | ■ |  |  | <b>OC2</b> |            |   |   |   |   |   |   |   |   |   |   |   |   |
| Station <b>Synchronising</b> Intervals (SI) after<br>48 hour <b>Shutdown</b> | Mins   | ■ |  |  |            | -          | - | - | - | - | - | - | - | - | - | - | - | - |
| <b>Synchronising</b> Group (if applicable)                                   | 1 to 4 | ■ |  |  |            | <b>OC2</b> |   |   |   |   |   |   |   |   |   |   |   | - |

## SCHEDULE 2 - GENERATION PLANNING PARAMETERS

PAGE 2 OF 3

| DATA DESCRIPTION  | UNITS        | DATA to RTL   |                | DATA CAT.                     | GENSET OR STATION DATA |    |    |    |    |    |     |        |
|---|--------------|---------------|----------------|-------------------------------|------------------------|----|----|----|----|----|-----|--------|
|   |              | CUSC Contract | CUSC App. Form |                               | G1                     | G2 | G3 | G4 | G5 | G6 | STN |        |
| <b>Synchronising Generation (SYG) after 48 hour Shutdown</b><br><i>PC.A.5.3.2(f) &amp; OC2.4.2.1(a)</i>                                   | MW           | ■             |                | <b>DPD II &amp; OC2</b>       |                        |    |    |    |    |    |     | -      |
| <b>De-Synchronising Intervals (Single value)</b><br><i>OC2.4.2.1(a)</i>   | Mins         | ■             |                | <b>OC2</b>                    | -                      | -  | -  | -  | -  | -  | -   | -      |
| <u>RUNNING AND SHUTDOWN PERIOD LIMITATIONS:</u>   |              |               |                |                               |                        |    |    |    |    |    |     |        |
| Minimum Non Zero time (MNZT) after 48 hour Shutdown <i>OC2.4.2.1(a)</i>   | Mins         | ■             |                | <b>OC2</b>                    |                        |    |    |    |    |    |     |        |
| Minimum Zero time (MZT) <i>OC2.4.2.1(a)</i>   | Mins         |               |                | <b>OC2</b>                    |                        |    |    |    |    |    |     |        |
| <b>Existing AGR Plant Flexibility Limit (Existing AGR Plant only)</b>   | No.          |               |                | <b>OC2</b>                    |                        |    |    |    |    |    |     |        |
| 80% Reactor Thermal Power (expressed as Gross-Net MW) ( <b>Existing AGR Plant only</b> )  | MW           |               |                | <b>OC2</b>                    |                        |    |    |    |    |    |     |        |
| <b>Frequency Sensitive AGR Unit Limit (Frequency Sensitive AGR Units only)</b>  | No.          |               |                | <b>OC2</b>                    |                        |    |    |    |    |    |     |        |
| <u>RUN-UP PARAMETERS</u><br><i>PC.A.5.3.2(f) &amp; OC2.4.2.1(a)</i>   |              |               |                |                               |                        |    |    |    |    |    |     |        |
| <u>Run-up rates (RUR) after 48 hour Shutdown:</u><br>(See note 2 page 3)<br>MW Level 1 (MWL1)<br>MW Level 2 (MWL2)                        | MW<br>MW     | ■<br>■        |                | <b>OC2<br/>OC2</b>            |                        |    |    |    |    |    |     | -<br>- |
| RUR from Synch. Gen to MWL1   | MW/Mins      | ■             |                | <b>DPD II &amp; OC2</b>       |                        |    |    |    |    |    |     |        |
| RUR from MWL1 to MWL2   | MW/Mins      | ■             |                | <b>OC2</b>                    |                        |    |    |    |    |    |     |        |
| RUR from MWL2 to RC   | MW/Mins      | ■             |                | <b>OC2</b>                    |                        |    |    |    |    |    |     |        |
| <u>Run-Down Rates (RDR):</u><br>(Note that for DPD only a single value of run-down rate from Registered Capacity to de-synch is required) |              |               |                |                               |                        |    |    |    |    |    |     |        |
| MWL2<br>RDR from RC to MWL2   | MW<br>MW/Min | ■<br>■        |                | <b>OC2<br/>DPD II<br/>OC2</b> |                        |    |    |    |    |    |     |        |
| MWL1<br>RDR from MWL2 to MWL1   | MW<br>MW/Min | ■<br>■        |                | <b>OC2<br/>OC2</b>            |                        |    |    |    |    |    |     |        |
| RDR from MWL1 to de-synch   | MW/Min       | ■             |                | <b>OC2</b>                    |                        |    |    |    |    |    |     |        |

**SCHEDULE 2 - GENERATION PLANNING PARAMETERS**  
PAGE 3 OF 3

| DATA DESCRIPTION  | UNITS            | DATA to                 |              | DATA CAT.        | GENSET OR STATION DATA |    |    |    |    |    |     |  |
|---|------------------|-------------------------|--------------|------------------|------------------------|----|----|----|----|----|-----|--|
|   |                  | RTL<br>CUSC<br>Contract | App.<br>Form |                  | G1                     | G2 | G3 | G4 | G5 | G6 | STN |  |
| <b>REGULATION PARAMETERS</b><br>OC2.4.2.1(a)<br>Regulating Range<br>Load rejection capability while still<br><b>Synchronised</b> and able to supply Load. | MW<br>MW         | ■                       |              | DPD II<br>DPD II |                        |    |    |    |    |    |     |  |
| <b>GAS TURBINE LOADING PARAMETERS:</b><br>OC2.4.2.1(a)<br>Fast loading<br>Slow loading  | MW/Min<br>MW/Min | ■                       |              | OC2<br>OC2       |                        |    |    |    |    |    |     |  |
| <b>CCGT MODULE PLANNING MATRIX</b>  |                  |                         |              | OC2              | (please attach)        |    |    |    |    |    |     |  |
| <b>POWER PARK MODULE PLANNING MATRIX</b>  |                  |                         |              | OC2              | (please attach)        |    |    |    |    |    |     |  |
| <b>Power Park Module Active Power Output/<br/>Intermittent Power Source Curve<br/>(eg MW output / Wind speed)</b>   |                  |                         |              | OC2              | (please attach)        |    |    |    |    |    |     |  |

NOTES:

- (1) To allow for different groups of **Gensets** within a **Power Station** (eg. **Gensets** with the same operator) each **Genset** may be allocated to one of up to four **Synchronising Groups**. Within each such **Synchronising Group** the single synchronising interval will apply but between **Synchronising Groups** a zero synchronising interval will be assumed.
- (2) The run-up of a **Genset** from synchronising block load to **Registered Capacity** or **Maximum Capacity** is represented as a three stage characteristic in which the run-up rate changes at two intermediate loads, MWL1 and MWL2. The values MWL1 & MWL2 can be different for each **Genset**.

Formatted: Font: Bold

**SCHEDULE 3 - LARGE POWER STATION OUTAGE PROGRAMMES, OUTPUT USABLE AND INFLEXIBILITY INFORMATION**

PAGE 1 OF 3

(Also outline information on contracts involving **External Interconnections**)

For a **Generating Unit** at a **Large Power Station** the information is to be submitted on a unit basis and for a **CCGT Module** or **Power Park Module** at a **Large Power Station** the information is to be submitted on a module basis, unless otherwise stated.

| DATA DESCRIPTION   |  | UNITS | TIME COVERED | UPDATE TIME | DATA CAT. | DATA to RTL        |
|--|--|-------|--------------|-------------|-----------|--------------------|
| <b>Power Station name:</b> .....<br><b>Generating Unit (or CCGT Module or Power Park Module at a Large Power Station) number:</b> ...<br><b>Registered Capacity:</b> ..... |  |       |              |             |           |                    |
| <b>Large Power Station OUTAGE PROGRAMME</b>  | <b>Large Power Station OUTPUT USABLE</b> |       |              |             |           |                    |
| <u>PLANNING FOR YEARS 3 - 7 AHEAD (OC2.4.1.2.1(a)(i), (e) &amp; (j))</u>   |  |       |              |             |           |                    |
|  | Monthly average OU                       | MW    | F. yrs 5 - 7 | Week 24     | SPD       | CUSC Contract Form |
| Provisional outage programme comprising:   |  |       | C. yrs 3 - 5 | Week 2      | OC2       |                    |
| duration   |  | weeks | "            | "           | "         | ■                  |
| preferred start date   |  | date  | "            | "           | "         | ■                  |
| earliest start date  |  | date  | "            | "           | "         | ■                  |
| latest finish date   |  | date  | "            | "           | "         | ■                  |
|  | Weekly OU                                | MW    | "            | "           | "         | ■                  |
| <b>(NGET response as detailed in OC2 (Existing Users' response to NGET suggested changes or potential outages)</b>   |  |       | C. yrs 3 - 5 | Week12)     |           | ■                  |
|  |  |       | C. yrs 3 - 5 | Week14)     |           | ■                  |
| Updated provisional outage programme comprising:   |  |       | C. yrs 3 - 5 | Week 25     | OC2       |                    |
| duration   |  | weeks | "            | "           | "         | ■                  |
| preferred start date   |  | date  | "            | "           | "         | ■                  |
| earliest start date  |  | date  | "            | "           | "         | ■                  |
| latest finish date   |  | date  | "            | "           | "         | ■                  |
|  | Updated weekly OU                        | MW    | "            | "           | "         | ■                  |
| <b>(NGET response as detailed in OC2 for (Existing Users' response to NGET suggested changes or update of potential outages)</b>   |  |       | C. yrs 3 - 5 | Week28)     |           | ■                  |
|  |  |       | C. yrs 3 - 5 | Week31)     |           | ■                  |
| <b>(NGET further suggested revisions etc. (as detailed in OC2 for</b>  |  |       | C. yrs 3 - 5 | Week42)     |           | ■                  |
| <b>Agreement of final Generation Outage Programme</b>  |  |       | C. yrs 3 - 5 | Week 45     | OC2       | ■                  |
| <u>PLANNING FOR YEARS 1 - 2 AHEAD (OC2.4.1.2.2(a) &amp; OC2.4.1.2.2(i))</u>  |  |       |              |             |           |                    |
| Update of previously agreed Final Generation Outage Programme  |  |       | C. yrs 1 - 2 | Week 10     | OC2       |                    |
|  | Weekly OU                                | MW    | "            | "           |           | ■                  |

**SCHEDULE 3 - LARGE POWER STATION OUTAGE PROGRAMMES, OUTPUT  
USABLE AND INFLEXIBILITY INFORMATION  
PAGE 2 OF 3**

| DATA DESCRIPTION  | UNITS           | TIME COVERED | UPDATE TIME              | DATA CAT        | DATA to RTL              |
|---|-----------------|--------------|--------------------------|-----------------|--------------------------|
| (NGET response as detailed in OC2 for (Existing-Users' response to NGET suggested changes or update of potential outages) |                 | C. yrs 1 – 2 | Week 12)                 |                 | <input type="checkbox"/> |
|   |                 | C. yrs 1 – 2 | Week 14)                 |                 | <input type="checkbox"/> |
| Revised weekly OU   |                 | C. yrs 1 – 2 | Week 34                  | OC2             | <input type="checkbox"/> |
| (NGET response as detailed in OC2 for (Existing-Users' response to NGET suggested changes or update of potential outages) |                 | C. yrs 1 – 2 | Week 39)                 |                 | <input type="checkbox"/> |
|   |                 | C. yrs 1 – 2 | Week 46)                 |                 | <input type="checkbox"/> |
| Agreement of final Generation Outage Programme  |                 | C. yrs 1 – 2 | Week 48                  | OC2             | <input type="checkbox"/> |
| <u>PLANNING FOR YEAR 0</u>  |                 |              |                          |                 |                          |
| Updated Final Generation Outage Programme   |                 | C. yr 0      | Week 2 ahead to year end | 1600 Weds.      | OC2                      |
| OU at weekly peak   | MW              | "            | "                        | "               |                          |
| (NGET response as detailed in OC2 for (   |                 | C. yrs 0     | Weeks 2 to 52 ahead      | 1600 ) Friday ) |                          |
| (   |                 | Weeks 2 - 7  | ahead                    | 1600 ) Thurs )  |                          |
| (NGET response as detailed in OC2 for (   |                 | date         | days 2 to 14 ahead       | 0900 daily      | OC2                      |
| Forecast return to services (Planned Outage or breakdown)   |                 |              |                          |                 |                          |
| OU (all hours)  | MW              | "            | "                        | "               | OC2                      |
| (NGET response as detailed in OC2 for (   |                 | days 2 to 14 | ahead                    | 1600 ) daily )  |                          |
|   |                 |              |                          |                 |                          |
| <u>INFLEXIBILITY</u>  |                 |              |                          |                 |                          |
| Genset inflexibility  | Min MW (Weekly) | Weeks 2 - 8  | ahead                    | 1600 Tues       | OC2                      |
| (NGET response on Negative Reserve Active (Power Margin   |                 | "            | "                        | 1200 ) Friday ) |                          |
| Genset inflexibility  | Min MW (daily)  | days 2 -14   | ahead                    | 0900 daily      | OC2                      |
| (NGET response on Negative Reserve Active (Power Margin   |                 | "            | "                        | 1600 ) daily )  |                          |

**SCHEDULE 3 - LARGE POWER STATION OUTAGE PROGRAMMES, OUTPUT  
USABLE AND INFLEXIBILITY INFORMATION  
PAGE 3 OF 3**

| DATA DESCRIPTION   | UNITS | TIME COVERED | UPDATE TIME | DATA CAT | DATA to RTL   |                |
|--|-------|--------------|-------------|----------|---------------|----------------|
| <u>OUTPUT PROFILES</u>   |       |              |             |          |               |                |
|  |       |              |             |          | CUSC Contract | CUSC App. Form |
| In the case of <b>Large Power Stations</b> whose output may be expected to vary in a random manner (eg. wind power) or to some other pattern (eg. Tidal) sufficient information is required to enable an understanding of the possible profile | MW    | F. yrs 1 - 7 | Week 24     | SPD      |               |                |
|  |       |              |             |          |               |                |
|  |       |              |             |          |               |                |
|  |       |              |             |          |               |                |
|  |       |              |             |          |               |                |
|  |       |              |             |          |               |                |
|  |       |              |             |          |               |                |

Notes: 1. The week numbers quoted in the Update Time column refer to standard weeks in the current year.

**SCHEDULE 4 - LARGE POWER STATION DROOP AND RESPONSE DATA**  
PAGE 1 OF 1

**GOVERNOR DROOP AND RESPONSE (PC.A.5.5 ■ CUSC Contract)**  
The Data in this Schedule 4 is to be supplied by **Generators** with respect to all **Large Power Stations, HVDC System Owners** and by **DC Converter Station owners** (where agreed), whether directly connected or **Embedded**

| DATA DESCRIPTION | NORMAL VALUE   | MW | DATA CAT | DROOP% |        |        | RESPONSE CAPABILITY |           |                |   |
|------------------|--|----|----------|--------|--------|--------|---------------------|-----------|----------------|---|
|                  |  |    |          | Unit 1 | Unit 2 | Unit 3 | Primary             | Secondary | High Frequency |   |
| MLP1             | Designed Minimum Operating Level, or Minimum Regulating Level, for a CCGT Module or Power Park Module, on a modular basis assuming all units are Synchronised                      | ▲  | ▲        | ▲      | ▲      | ▲      | ▲                   | ▲         | ▲              | ▲ |
| MLP2             | Minimum Generation, or Minimum Stable Operating Level, for a CCGT Module, or Power Park Module, or Power Generating Module, on a modular basis assuming all units are Synchronised |    |          |        |        |        |                     |           |                |   |
| MLP3             | 70% of Registered Capacity, or Maximum Capacity  |    |          |        |        |        |                     |           |                |   |
| MLP4             | 80% of Registered Capacity, or Maximum Capacity  | ▲  |          |        |        |        |                     |           |                |   |
| MLP5             | 95% of Registered Capacity, or Maximum Capacity  | ▲  |          |        |        |        |                     |           |                |   |
| MLP6             | Registered Capacity, or Maximum Capacity   | ▲  |          |        |        |        |                     |           |                |   |

- NOTES:**
- The data provided in this Schedule 4 is not intended to constrain any **Ancillary Services Agreement**.
  - Registered Capacity** or **Maximum Capacity** should be identical to that provided in Schedule 2.
  - The Governor Droop should be provided for each **Generating Unit** (excluding **Power Park Units**), **Power Park Module**, **HVDC Converter**, or **DC Converter**. The Response Capability should be provided for each **Genset** or **DC Converter**.
  - Primary**, **Secondary** and **High Frequency Response** are defined in CC.A.3.2 and are based on a frequency ramp of 0.5Hz over 10 seconds. **Primary Response** is the minimum value of response between 10s and 30s after the frequency ramp starts, **Secondary Response** between 30s and 30 minutes, and **High Frequency Response** is the minimum value after 10s on an indefinite basis.
  - For plants which have not yet **Synchronised**, the data values of MLP1 to MLP6 should be as described above. For plants which have already **Synchronised**, the values of MLP1 to MLP6 can take any value between **Designed Operating Level** and **Registered Capacity** or **Maximum Capacity**. If MLP1 is not provided at the **Designed Minimum Operating Level**, the value of the **Designed Minimum Operating Level** should be separately stated.
  - For the avoidance of doubt **Transmission DC Converters** and **OTSDUW DC Converters** must be capable of providing a continuous signal indicating the real time frequency measured at the **Transmission Interface Point** to the **Offshore Grid Entry Point** (as detailed in CC.6.3.7(vii) and CC.6.3.7(viii)) to enable **Offshore Power Generating Modules**, **Offshore Generating Units**, **Offshore Power Park Modules** and/or **Offshore DC Converters** to satisfy the frequency response requirements of CC.6.3.7.

Formatted: Font: 7.5 pt

Formatted Table

Formatted: Font: Bold

Formatted: Font: 7.5 pt

Formatted: Font: 7.5 pt

Formatted: Font: 7.5 pt

Formatted: Font: 7.5 pt

Formatted: Font: 7.5 pt

Formatted: Font: 7.5 pt

Formatted: Font: 7.5 pt

Formatted: Font: 7.5 pt

Formatted: Font: 7.5 pt

Formatted: Font: 7.5 pt

Formatted: Font: 7.5 pt, Bold

Formatted: Font: 7.5 pt, Bold

Formatted: Font: 7.5 pt, Not Bold

Formatted: Font: 7.5 pt

Formatted: Font: 7.5 pt

Formatted: Font: 7.5 pt

Formatted: Font: Bold

Formatted: Font: Not Bold

## SCHEDULE 5 - USERS SYSTEM DATA

PAGE 1 OF 10

The data in this Schedule 5 is required from **Users** who are connected to the **National Electricity Transmission System** via a **Connection Point** (or who are seeking such a connection). **Generators** undertaking **OTSDUW** should use **DRC** Schedule 18 although they should still supply data under Schedule 5 in relation to their **Existing-User's System** up to the **Offshore Grid Entry Point**.

| DATA DESCRIPTION   | UNITS | DATA to RTL   |                | DATA CATEGORY |
|--|-------|---------------|----------------|---------------|
|  |       | CUSC Contract | CUSC App. Form |               |
| <p><b>EXISTING-USERS SYSTEM LAYOUT</b> (PC.A.2.2)</p> <p>A <b>Single Line Diagram</b> showing all or part of the <b>Existing-User's System</b> is required. This diagram shall include:-</p> <p>(a) all parts of the <b>Existing-User's System</b>, whether existing or proposed, operating at <b>Supergrid Voltage</b>, and in Scotland and <b>Offshore</b>, also all parts of the <b>Existing-User System</b> operating at 132kV,</p> <p>(b) all parts of the <b>Existing-User's System</b> operating at a voltage of 50kV, and in Scotland and <b>Offshore</b> greater than 30kV, or higher which can interconnect <b>Connection Points</b>, or split bus-bars at a single <b>Connection Point</b>,</p> <p>(c) all parts of the <b>Existing-User's System</b> between <b>Embedded Medium Power Stations</b> or <b>Large Power Stations</b> or <b>Offshore Transmission Systems</b> connected to the <b>Existing-User's Subtransmission System</b> and the relevant <b>Connection Point</b> or <b>Interface Point</b>,</p> <p>(d) all parts of the <b>Existing-User's System</b> at a <b>Transmission Site</b>.</p> <p>The <b>Single Line Diagram</b> may also include additional details of the <b>Existing-User's Subtransmission System</b>, and the transformers connecting the <b>Existing-User's Subtransmission System</b> to a lower voltage. With <b>NGET's</b> agreement, it may also include details of the <b>Existing-User's System</b> at a voltage below the voltage of the <b>Subtransmission System</b>.</p> <p>This <b>Single Line Diagram</b> shall depict the arrangement(s) of all of the existing and proposed load current carrying <b>Apparatus</b> relating to both existing and proposed <b>Connection Points</b>, showing electrical circuitry (ie. overhead lines, underground cables, power transformers and similar equipment), operating voltages. In addition, for equipment operating at a <b>Supergrid Voltage</b>, and in Scotland and <b>Offshore</b> also at 132kV, circuit breakers and phasing arrangements shall be shown.</p> |       | ■             | ■              | SPD           |



**SCHEDULE 5 - USERS SYSTEM DATA**  
PAGE 2 OF 10

| DATA DESCRIPTION   | UNITS   | DATA EXCH  |  | DATA CATEGORY   |
|--|---|--|--|---|
|  |   | CUSC Contract  | CUSC App. Form   |   |
| <p><u>REACTIVE COMPENSATION (PC.A.2.4)</u></p> <p>For independently switched reactive compensation equipment not owned by a <b>Transmission Licensee</b> connected to the <b>Existing-User's System</b> at 132kV and above, and also in Scotland and <b>Offshore</b>, connected at 33kV and above, other than power factor correction equipment associated with a customers <b>Plant</b> or <b>Apparatus</b>:</p> <p>Type of equipment (eg. fixed or variable)<br/>           Capacitive rating; or<br/>           Inductive rating; or<br/>           Operating range</p> <p>Details of automatic control logic to enable operating characteristics to be determined</p> <p>Point of connection to <b>Existing-User's System</b> (electrical location and system voltage)</p> | <p>Text</p> <p>MVAr</p> <p>MVAr</p> <p>MVAr</p> <p>text and/or diagrams</p> <p>Text</p> | <p>■</p> <p>■</p> <p>■</p> <p>■</p> <p>■</p> <p>■</p> <p>■</p> | <p>■</p> <p>■</p> <p>■</p> <p>■</p> <p>■</p> <p>■</p> <p>■</p> | <p>SPD</p> <p>SPD</p> <p>SPD</p> <p>SPD</p> <p>SPD</p> <p>SPD</p> |
| <p><u>SUBSTATION INFRASTRUCTURE (PC.A.2.2.6(b))</u></p> <p>For the infrastructure associated with any <b>Existing-User's</b> equipment at a Substation owned by a <b>Transmission Licensee</b> or operated or managed by <b>NGET</b>:-</p> <p>Rated 3-phase rms short-circuit withstand current<br/>           Rated 1-phase rms short-circuit withstand current<br/>           Rated Duration of short-circuit withstand<br/>           Rated rms continuous current</p>  | <p>kA</p> <p>kA</p> <p>s</p> <p>A</p>   | <p>■</p> <p>■</p> <p>■</p> <p>■</p>                            | <p>■</p> <p>■</p> <p>■</p> <p>■</p>                            | <p>SPD</p> <p>SPD</p> <p>SPD</p> <p>SPD</p>                       |

**SCHEDULE 5 – ~~EXISTING~~ USERS SYSTEM DATA**

PAGE 3 OF 10

| DATA DESCRIPTION   |   | UNITS        | DATA EXCH     |                | DATA CATEGORY |
|--|---|--------------|---------------|----------------|---------------|
| LUMPED SUSCEPTANCES (PC.A.2.3)   |   |              | CUSC Contract | CUSC App. Form |               |
| Equivalent Lumped Susceptance required for all parts of the <del>Existing</del> User's Subtransmission System which are not included in the Single Line Diagram. |   |              | ■             | ■              |               |
| This should not include:   |   |              | ■             | ■              |               |
| (a)  | independently switched reactive compensation equipment identified above.  |              | ■             | ■              |               |
| (b)  | any susceptance of the <del>Existing</del> User's System inherent in the Demand (Reactive Power) data provided in Schedule 1 (Generator Data) or Schedule 11 (Connection Point data). |              | ■             | ■              |               |
| Equivalent lumped shunt susceptance at nominal Frequency.  |   | % on 100 MVA | ■             | ■              | SPD           |
|  |   |              |               |                |               |



**EXISTING-USERS SYSTEM DATA**

Transformer Data (PC.A.2.2.5) (■ CUSC Contract & ■ CUSC Application Form)

The data below is all **Standard Planning Data**, and details should be shown below of all transformers shown on the **Single Line Diagram**. Details of Winding Arrangement, Tap Changer and earthing details are only required for transformers connecting the **Existing-User's** higher voltage system with its **Primary Voltage System**.

**SCHEDULE 5 – EXISTING-USERS SYSTEM DATA**  
PAGE 5 OF 10

| Years valid | Name of Node or Connection Point | Transformer | Rating MVA | Voltage Ratio |    | Positive Phase Sequence Reactance % on Rating |          |           | Positive Phase Sequence Resistance % on Rating |          |           | Zero Sequence Reactance % on Rating | Winding Arr. | Tap Changer   |             |               | Earthing Details (delete as app.) * |
|-------------|----------------------------------|-------------|------------|---------------|----|---|----------|-----------|--|----------|-----------|-------------------------------------|--------------|---------------|-------------|---------------|-------------------------------------|
|             |                                  |             |            | HV            | LV | Max. Tap                                      | Min. Tap | Norm. Tap | Max. Tap                                       | Min. Tap | Norm. Tap |                                     |              | range +%-to-% | step size % | type (delete) |                                     |
|             |                                  |             |            |               |    |   |          |           |  |          |           |                                     |              |               |             |               | Direct/Res/Rea                      |
|             |                                  |             |            |               |    |   |          |           |  |          |           |                                     |              |               |             |               | Direct/Res/Rea                      |
|             |                                  |             |            |               |    |   |          |           |  |          |           |                                     |              |               |             |               | Direct/Res/Rea                      |
|             |                                  |             |            |               |    |   |          |           |  |          |           |                                     |              |               |             |               | Direct/Res/Rea                      |
|             |                                  |             |            |               |    |   |          |           |  |          |           |                                     |              |               |             |               | Direct/Res/Rea                      |
|             |                                  |             |            |               |    |   |          |           |  |          |           |                                     |              |               |             |               | Direct/Res/Rea                      |
|             |                                  |             |            |               |    |   |          |           |  |          |           |                                     |              |               |             |               | Direct/Res/Rea                      |

\*If Resistance or Reactance please give impedance value

Notes

1. Data should be supplied for the current, and each of the seven succeeding Financial Years. This should be done by showing for which years the data is valid in the first column of the Table
2. For a transformer with two secondary windings, the positive and zero phase sequence leakage impedances between the HV and LV1, HV and LV2, and LV1 and LV2 windings are required.

**SCHEDULE 5 – EXISTING USERS SYSTEM DATA**

PAGE 6 OF 10

**USER'S SYSTEM DATA**

Switchgear Data (PC-A.2.2.6(a)) (CUSC Contract & CUSC Application Form)

The data below is all **Standard Planning Data**, and should be provided for all switchgear (ie. circuit breakers, load disconnectors and disconnectors) operating at a **Supergrid Voltage**, and also in Scotland and **Offshore**, operating at 132kV. In addition, data should be provided for all circuit breakers irrespective of voltage located at a **Connection Site** which is owned by a **Transmission Licensee** or operated or managed by **NGET**.

| Years Valid | Connect-ion Point | Switch No. | Rated Voltage kV rms | Operating Voltage kV rms | Rated short-circuit breaking current |                | Rated short-circuit peak making current |                 | Rated rms continuous current (A) | DC time constant at testing of asymmetrical breaking ability(s) |
|-------------|-------------------|------------|----------------------|--------------------------|--------------------------------------|----------------|---|-----------------|----------------------------------|---|
|             |                   |            |                      |                          | 3 Phase kA rms                       | 1 Phase kA rms | 3 Phase kA peak                         | 1 Phase kA peak |                                  |   |
|             |                   |            |                      |                          |                                      |                |   |                 |                                  |   |

Notes

1. Rated Voltage should be as defined by IEC 694.
2. Data should be supplied for the current, and each of the seven succeeding Financial Years. This should be done by showing for which years the data is valid in the first column of the Table

**SCHEDULE 5 – EXISTING USERS SYSTEM DATA**  
PAGE 7 OF 10

| DATA DESCRIPTION   | UNITS | DATA to RTL   |                | DATA CATEGORY |
|--|-------|---------------|----------------|---------------|
|  |       | CUSC Contract | CUSC App. Form |               |
| <p><b>PROTECTION SYSTEMS</b> (PC.A.6.3)</p> <p>The following information relates only to <b>Protection</b> equipment which can trip or inter-trip or close any <b>Connection Point</b> circuit breaker or any <b>Transmission</b> circuit breaker. The information need only be supplied once, in accordance with the timing requirements set out in PC.A.1.4 (b) and need not be supplied on a routine annual basis thereafter, although <b>NGET</b> should be notified if any of the information changes.</p> <p>(a) A full description, including estimated settings, for all relays and Protection systems installed or to be installed on the <b>Existing-User's System</b>;</p> <p>(b) A full description of any auto-reclose facilities installed or to be installed on the <b>Existing-User's System</b>, including type and time delays;</p> <p>(c) A full description, including estimated settings, for all relays and <b>Protection</b> systems installed or to be installed on the <b>Power Generating Module, Power Park Module</b> or <b>Generating Unit's</b> generator transformer, unit transformer, station transformer and their associated connections;</p> <p>(d) For <b>Generating Units</b> (other than <b>Power Park Units</b>) having a circuit breaker at the generator terminal voltage clearance times for electrical faults within the <b>Generating Unit</b> zone must be declared.</p> <p>(e) Fault Clearance Times:<br/>Most probable fault clearance time for electrical faults on any part of the <b>Existing-Users System</b> directly connected to the <b>National Electricity Transmission System</b>.</p> |       |               |                |               |
|  |       | ■             |                | <b>DPD II</b> |
|  |       | ■             |                | <b>DPD II</b> |
|  |       | ■             |                | <b>DPD II</b> |
|  |       | ■             |                | <b>DPD II</b> |
|  | mSec  | ■             |                | <b>DPD II</b> |

Formatted: Font: Bold

| DATA DESCRIPTION   | UNITS | DATA to RTL   |                | DATA CATEGORY |
|--|-------|---------------|----------------|---------------|
|  |       | CUSC Contract | CUSC App. Form |               |
| <p><b>POWER PARK MODULE/UNIT PROTECTION SYSTEMS</b></p> <p>Details of settings for the <b>Power Park Module/Unit</b> protection relays (to include): (PC.A.5.4.2(f))</p> <p>(a) Under frequency,</p> <p>(b) Over Frequency,</p> <p>(c) Under Voltage, Over Voltage,</p> <p>(d) Rotor Over current</p> <p>(e) Stator Over current,.</p> <p>(f) High Wind Speed Shut Down Level</p> <p>(g) Rotor Underspeed</p> <p>(h) Rotor Overspeed</p> |       |               |                |               |
|  |       | ■             |                | <b>DPD II</b> |
|  |       | ■             |                | <b>DPD II</b> |
|  |       | ■             |                | <b>DPD II</b> |
|  |       | ■             |                | <b>DPD II</b> |
|  |       | ■             |                | <b>DPD II</b> |
|  |       | ■             |                | <b>DPD II</b> |
|  |       | ■             |                | <b>DPD II</b> |

**SCHEDULE 5 - USERS SYSTEM DATA**  
**PAGE 8 OF 10**

Information for Transient Overvoltage Assessment (DPD I) (PC.A.6.2 ■ CUSC Contract)

The information listed below may be requested by **NGET** from each **Existing-User** with respect to any **Connection Site** between that **Existing-User** and the **National Electricity Transmission System**. The impact of any third party **Embedded** within the **Existing-Users System** should be reflected.

- (a) Busbar layout plan(s), including dimensions and geometry showing positioning of any current and voltage transformers, through bushings, support insulators, disconnectors, circuit breakers, surge arresters, etc. Electrical parameters of any associated current and voltage transformers, stray capacitances of wall bushings and support insulators, and grading capacitances of circuit breakers;
- (b) Electrical parameters and physical construction details of lines and cables connected at that busbar. Electrical parameters of all plant e.g., transformers (including neutral earthing impedance or zig-zag transformers if any), series reactors and shunt compensation equipment connected at that busbar (or to the tertiary of a transformer) or by lines or cables to that busbar;
- (c) Basic insulation levels (BIL) of all **Apparatus** connected directly, by lines or by cables to the busbar;
- (d) Characteristics of overvoltage **Protection** devices at the busbar and at the termination points of all lines, and all cables connected to the busbar;
- (e) Fault levels at the lower voltage terminals of each transformer connected directly or indirectly to the **National Electricity Transmission System** without intermediate transformation;
- (f) The following data is required on all transformers operating at **Supergrid Voltage** throughout **Great Britain** and, in Scotland and **Offshore**, also at 132kV: three or five limb cores or single phase units to be specified, and operating peak flux density at nominal voltage.
- (g) An indication of which items of equipment may be out of service simultaneously during **Planned Outage** conditions.

Harmonic Studies (DPD I) (PC.A.6.4 ■ CUSC Contract)

The information given below, both current and forecast, where not already supplied in this Schedule 5 may be requested by **NGET** from each **Existing-User** if it is necessary for **NGET** to evaluate the production/magnification of harmonic distortion on the **National Electricity Transmission System** and **Existing-User's** systems. The impact of any third party **Embedded** within the **Existing-User's System** should be reflected:

- (a) Overhead lines and underground cable circuits of the **Existing-User's Subtransmission System** must be differentiated and the following data provided separately for each type:
  - Positive phase sequence resistance
  - Positive phase sequence reactance
  - Positive phase sequence susceptance
- (b) for all transformers connecting the **Existing-User's Subtransmission System** to a lower voltage:
  - Rated MVA
  - Voltage Ratio
  - Positive phase sequence resistance
  - Positive phase sequence reactance

## SCHEDULE 5 – ~~EXISTING~~ USERS SYSTEM DATA

PAGE 9 OF 10

(c) at the lower voltage points of those connecting transformers:

Equivalent positive phase sequence susceptance

Connection voltage and MVar rating of any capacitor bank and component design parameters if configured as a filter

Equivalent positive phase sequence interconnection impedance with other lower voltage points

The minimum and maximum **Demand** (both MW and MVar) that could occur

Harmonic current injection sources in Amps at the Connection voltage points

Details of traction loads, eg connection phase pairs, continuous variation with time, etc.

(d) an indication of which items of equipment may be out of service simultaneously during **Planned Outage** conditions

### Voltage Assessment Studies (DPD I) (PC.A.6.5 ■ CUSC Contract)

The information listed below, where not already supplied in this Schedule 5, may be requested by **NGET** from each ~~Existing-User~~ with respect to any **Connection Site** if it is necessary for **NGET** to undertake detailed voltage assessment studies (eg to examine potential voltage instability, voltage control co-ordination or to calculate voltage step changes). The impact of any third party **Embedded** within the ~~Existing-Users System~~ should be reflected:

(a) For all circuits of the ~~Existing-User's Subtransmission System~~:

Positive Phase Sequence Reactance

Positive Phase Sequence Resistance

Positive Phase Sequence Susceptance

MVar rating of any reactive compensation equipment

(b) for all transformers connecting the ~~Existing-User's Subtransmission System~~ to a lower voltage:

Rated MVA

Voltage Ratio

Positive phase sequence resistance

Positive Phase sequence reactance

Tap-changer range

Number of tap steps

Tap-changer type: on-load or off-circuit

AVC/tap-changer time delay to first tap movement

AVC/tap-changer inter-tap time delay



**SCHEDULE 5 – EXISTING-USERS SYSTEM DATA**  
**PAGE 10 OF 10**

(c) at the lower voltage points of those connecting transformers:-

Equivalent positive phase sequence susceptance

MVA rating of any reactive compensation equipment

Equivalent positive phase sequence interconnection impedance with other lower voltage points

The maximum **Demand** (both MW and MVA) that could occur

Estimate of voltage insensitive (constant power) load content in % of total load at both winter peak and 75% off-peak load conditions

Short Circuit Analyses:(DPD I) (PC.A.6.6 ■ CUSC Contract)

The information listed below, both current and forecast, and where not already supplied under this Schedule 5, may be requested by **NGET** from each **Existing-User** with respect to any **Connection Site** where prospective short-circuit currents on equipment owned by a **Transmission Licensee** or operated or managed by **NGET** are close to the equipment rating. The impact of any third party **Embedded** within the **Existing-User's System** should be reflected:-

(a) For all circuits of the **User's Subtransmission System**:

Positive phase sequence resistance

Positive phase sequence reactance

Positive phase sequence susceptance

Zero phase sequence resistance (both self and mutuals)

Zero phase sequence reactance (both self and mutuals)

Zero phase sequence susceptance (both self and mutuals)

(b) for all transformers connecting the **Existing-User's Subtransmission System** to a lower voltage:

Rated MVA

Voltage Ratio

Positive phase sequence resistance (at max, min and nominal tap)

Positive Phase sequence reactance (at max, min and nominal tap)

Zero phase sequence reactance (at nominal tap)

Tap changer range

Earthing method: direct, resistance or reactance

Impedance if not directly earthed

(c) at the lower voltage points of those connecting transformers:-

The maximum **Demand** (in MW and MVA) that could occur

Short-circuit infeed data in accordance with PC.A.2.5.6(a) unless the **Existing-User's** lower voltage network runs in parallel with the **Subtransmission System**, when to prevent double counting in each node infeed data, a  $\pi$  equivalent comprising the data items of PC.A.2.5.6(a) for each node together with the positive phase sequence interconnection impedance between the nodes shall be submitted.

## SCHEDULE 6 – EXISTING-USERS OUTAGE INFORMATION

PAGE 1 OF 2

| DATA DESCRIPTION   | UNITS  | DATA to RTL   |                | TIMESCALE COVERED        | UPDATE TIME   | DATA CAT.  |
|--|--|---------------|----------------|--------------------------|---|------------|
|  |  | CUSC Contract | CUSC App. Form |                          |   |            |
| Details are required from <b>Network Operators</b> of proposed outages in their <b>Existing-User Systems</b> and from <b>Generators</b> with respect to their outages, which may affect the performance of the <b>Total System</b> (eg. at a <b>Connection Point</b> or constraining <b>Embedded Large Power Stations</b> or constraints to the <b>Maximum Import Capacity</b> or <b>Maximum Export Capacity</b> at an <b>Interface Point</b> ) (OC2.4.1.3.2(a) & (b)) |  | ■             |                | Years 2-5                | Week 8<br><b>(Network Operator</b> etc)<br>Week 13<br><b>(Generators)</b> | <b>OC2</b> |
|  |  |               |                |                          |   | <b>OC2</b> |
| (NGET advises <b>Network Operators</b> of <b>National Electricity Transmission System</b> outages affecting their <b>Systems</b> )   |  |               |                | Years 2-5                | Week 28)  |            |
| <b>Network Operator</b> informs <b>NGET</b> if unhappy with proposed outages)  |  | ■             |                | "                        | Week 30   | <b>OC2</b> |
| (NGET draws up revised <b>National Electricity Transmission System</b> ( outage plan advises <b>Existing-Users</b> of operational effects)   |  |               |                | "                        | Week 34)  |            |
| <b>Generators</b> and <b>Non-Embedded Customers</b> provide Details of <b>Apparatus</b> owned by them (other than <b>Gensets</b> ) at each <b>Grid Supply Point</b> (OC2.4.1.3.3)  |  | ■             |                | Year 1                   | Week 13   | <b>OC2</b> |
| (NGET advises <b>Network Operators</b> of outages affecting their <b>Systems</b> ) (OC2.4.1.3.3)   |  |               |                | Year 1                   | Week 28)  |            |
| <b>Network Operator</b> details of relevant outages affecting the <b>Total System</b> (OC2.4.1.3.3)  |  | ■             |                | Year 1                   | Week 32   | <b>OC2</b> |
| Details of:-<br><b>Maximum Import Capacity</b> for each <b>Interface Point</b><br><b>Maximum Export Capacity</b> for each <b>Interface Point</b><br>Changes to previously declared values of the <b>Interface Point Target Voltage/Power Factor</b> (OC2.4.1.3.3(c)).  | MVA / MW<br>MVA / MW<br>V (unless power factor control |               |                | Year 1                   | Week 32   | <b>OC2</b> |
| (NGET informs <b>Existing-Users</b> of aspects that may affect their <b>Systems</b> ) (OC2.4.1.3.3)  |  |               |                | Year 1                   | Week 34)  |            |
| <b>Existing-Users</b> inform <b>NGET</b> if unhappy with aspects as notified (OC2.4.1.3.3)   |  | ■             |                | Year 1                   | Week 36   | <b>OC2</b> |
| (NGET issues final <b>National Electricity Transmission System</b> ( outage plan with advice of operational) (OC2.4.1.3.3) ( effects on <b>Existing-Users System</b> )   |  | ■             |                | Year 1                   | Week 49   | <b>OC2</b> |
| <b>Generator, Network Operator</b> and <b>Non-Embedded Customers</b> to inform <b>NGET</b> of changes to outages previously requested  |  |               |                | Week 8 ahead to year end | As occurring  | <b>OC2</b> |
| Details of load transfer capability of 12MW or more between <b>Grid Supply Points</b> in England and Wales and 10MW or more between <b>Grid Supply Points</b> in Scotland.<br>Details of:-<br><b>Maximum Import Capacity</b> for each <b>Interface Point</b><br><b>Maximum Export Capacity</b> for each <b>Interface Point</b><br>Changes to previously declared values of the <b>Interface Point Target Voltage/Power Factor</b>                                      | MVA / MW<br>MVA / MW<br>V (unless power factor control |               |                | Within Yr 0              | As <b>NGET</b> request  | <b>OC2</b> |
|  |  |               |                | Within Yr 0              | As occurring  | <b>OC2</b> |

Note: **Existing Users** should refer to **OC2** for full details of the procedure summarised above and for the information which **NGET** will provide on the **Programming Phase**.

**SCHEDULE 6 – EXISTING USERS OUTAGE INFORMATION**  
PAGE 2 OF 2

The data below is to be provided to **NGET** as required for compliance with the European Commission Regulation No 543/2013 (OC2.4.2.3). Data provided under Article Numbers 7.1(a), 7.1(b), 15.1(a), 15.1(b), and 15.1(c) and 15.1(d) is to be provided using **MODIS**.

| ECR ARTICLE No. | DATA DESCRIPTION  | EXISTING USERS PROVIDING DATA | FREQUENCY OF SUBMISSION   |
|-----------------|---|-------------------------------|---|
| 7.1(a)          | Planned unavailability of the <b>Apparatus</b> belonging to a <b>Non-Embedded Customer</b> where OC2.4.7 (a) applies<br><ul style="list-style-type: none"> <li>- Energy Identification Code (EIC)*</li> <li>- Unavailable demand capacity during the event (MW)</li> <li>- Estimated start date and time (dd.mm.yy hh:mm)</li> <li>- Estimated end date and time (dd.mm.yy hh:mm)</li> <li>- Reason for unavailability from the list below: <ul style="list-style-type: none"> <li>. Maintenance</li> <li>. Failure</li> <li>. Shutdown</li> <li>. Other</li> </ul> </li> </ul> | <b>Non-Embedded Customer</b>  | To be received by <b>NGET</b> as soon as reasonably possible but in any case to facilitate publication of data no later than 1 hour after a <b>decision has been made by the Non-Embedded Customer</b> regarding the planned unavailability |
| 7.1(b)          | Changes in actual availability of the <b>Apparatus</b> belonging to a <b>Non-Embedded Customer</b> where OC2.4.7 (b) applies<br><ul style="list-style-type: none"> <li>- Energy Identification Code (EIC)*</li> <li>- Unavailable demand capacity during the event (MW)</li> <li>- Start date and time (dd.mm.yy hh:mm)</li> <li>- Estimated end date and time (dd.mm.yy hh:mm)</li> <li>- Reason for unavailability from the list below : <ul style="list-style-type: none"> <li>. Maintenance</li> <li>. Failure</li> <li>. Shutdown</li> <li>. Other</li> </ul> </li> </ul>  | <b>Non-Embedded Customer</b>  | To be received by <b>NGET</b> as soon as reasonably possible but in any case to facilitate publication of data no later than 1 hour after the change in actual availability   |
| 8.1             | Year Ahead Forecast Margin information as provided in accordance with OC2.4.1.2.2<br><ul style="list-style-type: none"> <li>- <b>Output Usable</b></li> </ul>   | <b>Generator</b>              | In accordance with OC2.4.1.2.2  |
| 14.1(a)         | <b>Registered Capacity or Maximum Capacity for Generating Units or Power Generating Modules</b> with greater than 1 MW <b>Registered Capacity or Maximum Capacity</b> provided in accordance with PC.4.3.1 and PC.A.3.4.3 or PC.A.3.1.4<br><ul style="list-style-type: none"> <li>- <b>Registered Capacity or Maximum Capacity</b> (MW)</li> <li>- Production type (from that listed under PC.A.3.4.3)</li> </ul>   | <b>Generator</b>              | Week 24   |
| 14.1(b)         | <b>Power Station Registered Capacity</b> for units with equal or greater than 100 MW <b>Registered Capacity</b> provided in accordance with PC.4.3.1 and PC.A.3.4.3<br><ul style="list-style-type: none"> <li>- <b>Power Station name</b></li> <li>- Location of <b>Generating Unit</b></li> <li>- Production type (from that listed under PC.A.3.4.3)</li> <li>- Voltage connection levels</li> <li>- <b>Registered Capacity or Maximum Capacity</b> (MW)</li> </ul>   | <b>Generator</b>              | Week 24   |

Formatted: Font: Bold

Formatted: Font: Bold

Formatted: Font: Bold

Formatted: Font: Bold

|         |  |                  |   |
|---------|--|------------------|---|
| 14.1(c) | <p>Estimated output of <b>Active Power</b> of a <b>BM Unit</b> or <b>Generating Unit</b> for each per <b>Settlement Period</b> of the next <b>Operational Day</b> provided in accordance with BC1.4.2</p> <p>- <b>Physical Notification</b></p>  | <b>Generator</b> | In accordance with BC1.4.2  |
| 15.1(a) | <p>Planned unavailability of a <b>Generating Unit</b> where OC2.4.7(c) applies</p> <p>- <b>Power Station</b> name<br/> - <b>Generating Unit and/or Power Generating Module</b> name<br/> - Location of <b>Generating Unit and/or Power Generating Module</b><br/> - <b>Generating Unit Registered Capacity</b> (MW)<br/> - Production type (from that listed under PC.A.3.4.3)<br/> - <b>Output Usable</b> (MW) during the event<br/> - Start date and time (dd.mm.yy hh:mm)<br/> - Estimated end date and time (dd.mm.yy hh:mm)<br/> - Reason for unavailability from the list below:<br/> . Maintenance<br/> . Shutdown<br/> . Other</p>   | <b>Generator</b> | To be received by <b>NGET</b> as soon as reasonably possible but in any case to facilitate publication of data no later than 1 hour after a decision has been made by the <b>Generator</b> regarding the planned unavailability |
| 15.1(b) | <p>Changes in availability of a <b>Generating Unit and/or Power Generating Module</b> where OC2.4.7 (d) applies</p> <p>- <b>Power Station</b> name<br/> - <b>Generating Unit and/or Power Generating Module</b> name<br/> - Location of <b>Generating Unit and/or Power Generating Module</b><br/> - <b>Generating Unit Registered Capacity and Power Generating Module Maximum Capacity</b> (MW)<br/> - Production type (from that listed under PC.A.3.4.3)<br/> - Maximum Export Limit (MW) during the event<br/> - Start date and time (dd.mm.yy hh:mm)<br/> - Estimated end date and time (dd.mm.yy hh:mm)<br/> - Reason for unavailability from the list below:<br/> . Maintenance<br/> . Shutdown<br/> . Other</p> | <b>Generator</b> | To be received by <b>NGET</b> as soon as reasonably possible but in any case to facilitate publication of data no later than 1 hour after the change in actual availability   |
| 15.1(c) | <p>Planned unavailability of a <b>Power Station</b> where OC2.4.7(e) applies</p> <p>- <b>Power Station</b> name<br/> - Location of <b>Power Station</b><br/> - <b>Power Station Registered Capacity</b> (MW)<br/> - Production type (from that listed under PC.A.3.4.3)<br/> - <b>Power Station</b> aggregated <b>Output Usable</b> (MW) during the event<br/> - Start date and time (dd.mm.yy hh:mm)<br/> - Estimated end date and time (dd.mm.yy hh:mm)<br/> - Reason for unavailability from the list below:<br/> . Maintenance<br/> . Shutdown<br/> . Other</p>  | <b>Generator</b> | To be received by <b>NGET</b> as soon as reasonably possible but in any case to facilitate publication of data no later than 1 hour after a decision has been made by the <b>Generator</b> regarding the planned unavailability |
| 15.1(d) | <p>Changes in actual availability of a <b>Power Station</b> where OC2.4.7 (f) applies</p> <p>- <b>Power Station</b> name<br/> - Location of <b>Power Station</b><br/> - <b>Power Station Registered Capacity</b> (MW)<br/> - Production type (from that listed under PC.A.3.4.3)<br/> - <b>Power Station</b> aggregated Maximum Export Limit (MW) during the event<br/> - Start date and time (dd.mm.yy hh:mm)<br/> - Estimated end date and time (dd.mm.yy hh:mm)<br/> - Reason for unavailability from the list below:<br/> . Maintenance<br/> . Shutdown<br/> . Other</p>   | <b>Generator</b> | To be received by <b>NGET</b> as soon as reasonably possible but in any case to facilitate publication of data no later than 1 hour after the change in actual availability   |

**Formatted: Font: Bold**

**Formatted: Font: Bold**

**Formatted: Font: Bold**

**Formatted: Font: Bold**

\* Energy Identification Coding (EIC) is a coding scheme that is approved by ENTSO-E for standardised electronic data interchanges and is utilised for reporting to the Central European Transparency Platform. NGET will act as the Local Issuing Office for IEC in respect of GB.

## SCHEDULE 7 - LOAD CHARACTERISTICS AT GRID SUPPLY POINTS

PAGE 1 OF 1

All data in this schedule 7 is categorised as **Standard Planning Data (SPD)** and is required for existing and agreed future connections. This data is only required to be updated when requested by **NGET**.

| DATA DESCRIPTION   | UNITS            | DATA to RTL   |  | DATA FOR FUTURE YEARS |      |      |      |      |      |      |  |  |
|--|------------------|---|--|-----------------------|------|------|------|------|------|------|--|--|
|  |                  |   |  | Yr 1                  | Yr 2 | Yr 3 | Yr 4 | Yr 5 | Yr 6 | Yr 7 |  |  |
| <p><b>FOR ALL TYPES OF DEMAND FOR EACH GRID SUPPLY POINT</b></p> <p>The following information is required infrequently and should only be supplied, wherever possible, when requested by <b>NGET</b> (PC.A.4.7)</p> <p>Details of individual loads which have Characteristics significantly different from the typical range of domestic or commercial and industrial load supplied: (PC.A.4.7(a))</p> <p>Sensitivity of demand to fluctuations in voltage And frequency on <b>National Electricity Transmission System</b> at time of peak <b>Connection Point Demand (Active Power)</b> (PC.A.4.7(b))</p> <p>Voltage Sensitivity (PC.A.4.7(b))</p> <p><b>Frequency Sensitivity</b> (PC.A.4.7(b))</p> <p><b>Reactive Power</b> sensitivity should relate to the <b>Power Factor</b> information given in Schedule 11 (or for <b>Generators</b>, Schedule 1) and note 6 on Schedule 11 relating to <b>Reactive Power</b> therefore applies: (PC.A.4.7(b))</p> <p>Phase unbalance imposed on the <b>National Electricity Transmission System</b> (PC.A.4.7(d))</p> <p style="padding-left: 20px;">- maximum %</p> <p style="padding-left: 20px;">- average %</p> <p>Maximum Harmonic Content imposed on <b>National Electricity Transmission System</b> (PC.A.4.7(e)) %</p> <p>Details of any loads which may cause <b>Demand</b> Fluctuations greater than those permitted under Engineering Recommendation P28, Stage 1 at the <b>Point of Common Coupling</b> including <b>Flicker Severity (Short Term)</b> and <b>Flicker Severity (Long Term)</b> (PC.A.4.7(f))</p> |                  | <small>CUSC Contract</small><br><small>CUSC App. Form</small> |  |                       |      |      |      |      |      |      |  |  |
|  |                  | <input type="checkbox"/>                                      |  |                       |      |      |      |      |      |      |  |  |
|  |                  | <input type="checkbox"/>                                      |  | (Please Attach)       |      |      |      |      |      |      |  |  |
|  |                  | <input type="checkbox"/>                                      |  |                       |      |      |      |      |      |      |  |  |
|  | MW/kV<br>MVAR/kV | <input type="checkbox"/>                                      |  |                       |      |      |      |      |      |      |  |  |
|  | MW/Hz<br>MVAR/Hz | <input type="checkbox"/>                                      |  |                       |      |      |      |      |      |      |  |  |
|  |                  | <input type="checkbox"/>                                      |  |                       |      |      |      |      |      |      |  |  |
|  |                  | <input type="checkbox"/>                                      |  |                       |      |      |      |      |      |      |  |  |
|  |                  | <input type="checkbox"/>                                      |  |                       |      |      |      |      |      |      |  |  |
|  |                  | <input type="checkbox"/>                                      |  |                       |      |      |      |      |      |      |  |  |
|  |                  | <input type="checkbox"/>                                      |  |                       |      |      |      |      |      |      |  |  |

**SCHEDULE 8 - DATA SUPPLIED BY BM PARTICIPANTS**  
**PAGE 1 OF 1**

| CODE                 | DESCRIPTION   |
|----------------------|---|
| <b>BC1</b>           | <b>Physical Notifications</b>                                     |
| <b>BC1</b>           | <b>Quiescent Physical Notifications</b>                           |
| <b>BC1 &amp; BC2</b> | <b>Export and Import Limits</b>                                   |
| <b>BC1</b>           | <b>Bid-Offer Data</b>   |
| <b>BC1</b>           | <b>Dynamic Parameters (Day Ahead)</b>                             |
| <b>BC2</b>           | <b>Dynamic Parameters (For use in <b>Balancing Mechanism</b>)</b> |
| <b>BC1 &amp; BC2</b> | <b>Other Relevant Data</b>  |
| <b>BC1</b>           | <b>Joint BM Unit Data</b>   |

- No information collated under this Schedule will be transferred to the **Relevant Transmission Licensees**

**SCHEDULE 9 - DATA SUPPLIED BY NGET TO ~~EXISTING~~ USERS**

PAGE 1 OF 1

(Example of data to be supplied)

| CODE | DESCRIPTION  |
|------|--|
| CC   | Operation Diagram  |
| CC   | Site Responsibility Schedules  |
| PC   | Day of the peak <b>National Electricity Transmission System Demand</b><br>Day of the minimum <b>National Electricity Transmission System Demand</b>  |
| OC2  | <b>Surpluses</b> and OU requirements for each <b>Generator</b> over varying timescales<br><br>Equivalent networks to <del>Existing</del> Users for <b>Outage Planning</b><br><br><b>Negative Reserve Active Power Margins</b> (when necessary)<br><br><b>Operating Reserve</b> information |
| BC1  | <b>Demand</b> Estimates, <b>Indicated Margin</b> and <b>Indicated Imbalance</b> , indicative <b>Synchronising</b> and <b>Desynchronising</b> times of <b>Embedded Power Stations</b> to <b>Network Operators</b> , special actions.  |
| BC2  | <b>Bid-Offer Acceptances</b> , <b>Ancillary Services</b> instructions to relevant <del>Existing</del> Users, <b>Emergency Instructions</b>   |
| BC3  | Location, amount, and <b>Low Frequency Relay</b> settings of any <b>Low Frequency Relay</b> initiated <b>Demand</b> reduction for <b>Demand</b> which is <b>Embedded</b> .   |

- No information collated under this Schedule will be transferred to the **Relevant Transmission Licensees**

DATA TO BE SUPPLIED BY NGET TO ~~EXISTING~~ USERS

PURSUANT TO THE TRANSMISSION LICENCE

1. The **Transmission Licence** requires **NGET** to publish annually the **Seven Year Statement** which is designed to provide ~~Existing~~ Users and potential ~~Users~~ with information to enable them to identify opportunities for continued and further use of the **National Electricity Transmission System**.

When an ~~Existing~~ User is considering a development at a specific site, certain additional information may be required in relation to that site which is of such a level of detail that it is inappropriate to include it in the **Seven Year Statement**. In these circumstances the ~~Existing~~ User may contact **NGET** who will be pleased to arrange a discussion and the provision of such additional information relevant to the site under consideration as the ~~Existing~~ User may reasonably require.

2. The **Transmission Licence** also requires **NGET** to offer terms for an agreement for connection to and use of the **National Electricity Transmission System** and further information will be given by **NGET** to the potential ~~Existing~~ User in the course of the discussions of the terms of

**Comment [A3]:** House Keeping Change - Bold



such an agreement.

**SCHEDULE 10 - DEMAND PROFILES AND ACTIVE ENERGY DATA**  
**PAGE 1 OF 2**

The following information is required from each **Network Operator** and from each **Non-Embedded Customer**. The data should be provided in calendar week 24 each year (although **Network Operators** may delay the submission until calendar week 28).

| DATA DESCRIPTION  | F. Yr.<br>0  | F. Yr.<br>1 | F. Yr.<br>2 | F. Yr.<br>3 | F. Yr.<br>4 | F. Yr.<br>5 | F. Yr.<br>6 | F. Yr.<br>7 | UPDATE<br>TIME | DATA CAT   |
|---|--|-------------|-------------|-------------|-------------|-------------|-------------|-------------|----------------|------------|
| <u>Demand Profiles</u>  | <i>(PC.A.4.2) (■ – CUSC Contract &amp; ■ CUSC Application Form)</i>  |             |             |             |             |             |             |             |                |            |
| <b>Total Existing-User's system profile</b> (please delete as applicable) | Day of <b>Existing-User's</b> annual Maximum demand at <b>Annual ACS Conditions</b> (MW)                   |             |             |             |             |             |             |             |                |            |
|   | Day of annual peak of <b>National Electricity Transmission System Demand at Annual ACS Conditions</b> (MW) |             |             |             |             |             |             |             |                |            |
|   | Day of annual minimum <b>National Electricity Transmission System Demand</b> at average conditions (MW)    |             |             |             |             |             |             |             |                |            |
| 0000 : 0030   |  |             |             |             |             |             |             |             | Wk.24          | <b>SPD</b> |
| 0030 : 0100   |  |             |             |             |             |             |             |             | :              | :          |
| 0100 : 0130   |  |             |             |             |             |             |             |             | :              | :          |
| 0130 : 0200   |  |             |             |             |             |             |             |             | :              | :          |
| 0200 : 0230   |  |             |             |             |             |             |             |             | :              | :          |
| 0230 : 0300   |  |             |             |             |             |             |             |             | :              | :          |
| 0300 : 0330   |  |             |             |             |             |             |             |             | :              | :          |
| 0330 : 0400   |  |             |             |             |             |             |             |             | :              | :          |
| 0400 : 0430   |  |             |             |             |             |             |             |             | :              | :          |
| 0430 : 0500   |  |             |             |             |             |             |             |             | :              | :          |
| 0500 : 0530   |  |             |             |             |             |             |             |             | :              | :          |
| 0530 : 0600   |  |             |             |             |             |             |             |             | :              | :          |
| 0600 : 0630   |  |             |             |             |             |             |             |             | :              | :          |
| 0630 : 0700   |  |             |             |             |             |             |             |             | :              | :          |
| 0700 : 0730   |  |             |             |             |             |             |             |             | :              | :          |
| 0730 : 0800   |  |             |             |             |             |             |             |             | :              | :          |
| 0800 : 0830   |  |             |             |             |             |             |             |             | :              | :          |
| 0830 : 0900   |  |             |             |             |             |             |             |             | :              | :          |
| 0900 : 0930   |  |             |             |             |             |             |             |             | :              | :          |
| 0930 : 1000   |  |             |             |             |             |             |             |             | :              | :          |
| 1000 : 1030   |  |             |             |             |             |             |             |             | :              | :          |
| 1030 : 1100   |  |             |             |             |             |             |             |             | :              | :          |
| 1100 : 1130   |  |             |             |             |             |             |             |             | :              | :          |
| 1130 : 1200   |  |             |             |             |             |             |             |             | :              | :          |
| 1200 : 1230   |  |             |             |             |             |             |             |             | :              | :          |
| 1230 : 1300   |  |             |             |             |             |             |             |             | :              | :          |
| 1300 : 1330   |  |             |             |             |             |             |             |             | :              | :          |
| 1330 : 1400   |  |             |             |             |             |             |             |             | :              | :          |
| 1400 : 1430   |  |             |             |             |             |             |             |             | :              | :          |
| 1430 : 1500   |  |             |             |             |             |             |             |             | :              | :          |
| 1500 : 1530   |  |             |             |             |             |             |             |             | :              | :          |
| 1530 : 1600   |  |             |             |             |             |             |             |             | :              | :          |
| 1600 : 1630   |  |             |             |             |             |             |             |             | :              | :          |
| 1630 : 1700   |  |             |             |             |             |             |             |             | :              | :          |
| 1700 : 1730   |  |             |             |             |             |             |             |             | :              | :          |
| 1730 : 1800   |  |             |             |             |             |             |             |             | :              | :          |
| 1800 : 1830   |  |             |             |             |             |             |             |             | :              | :          |
| 1830 : 1900   |  |             |             |             |             |             |             |             | :              | :          |
| 1900 : 1930   |  |             |             |             |             |             |             |             | :              | :          |
| 1930 : 2000   |  |             |             |             |             |             |             |             | :              | :          |
| 2000 : 2030   |  |             |             |             |             |             |             |             | :              | :          |
| 2030 : 2100   |  |             |             |             |             |             |             |             | :              | :          |
| 2100 : 2130   |  |             |             |             |             |             |             |             | :              | :          |
| 2130 : 2200   |  |             |             |             |             |             |             |             | :              | :          |
| 2200 : 2230   |  |             |             |             |             |             |             |             | :              | :          |
| 2230 : 2300   |  |             |             |             |             |             |             |             | :              | :          |
| 2300 : 2330   |  |             |             |             |             |             |             |             | :              | :          |
| 2330 : 0000   |  |             |             |             |             |             |             |             | :              | :          |



**SCHEDULE 11 - CONNECTION POINT DATA**  
PAGE 1 OF 3

The following information is required from each **Network Operator** and from each **Non-Embedded Customer**. The data should be provided in calendar week 24 each year (although **Network Operators** may delay the submission until calendar week 28).

**Connection Point:**

|  |  |
|--|--|
| <b>Connection Point Demand</b> at the time of -<br>(select each one in turn)<br>(Provide data for each Access Period associated with the Connection Point) | a) maximum <b>Demand</b><br>b) peak <b>National Electricity Transmission System Demand</b> (specified by <b>NGET</b> )<br>c) minimum <b>National Electricity Transmission System Demand</b> (specified by <b>NGET</b> )<br>d) maximum <b>Demand</b> during <b>Access Period</b><br>e) specified by either <b>NGET</b> or an <b>Existing User</b> |
| Name of <b>Transmission Interface Circuit</b> out of service during <b>Access Period</b> (if reqd).  | <b>PC.A.4.1.4.2</b>  |

| DATA DESCRIPTION<br>(CUSC Contract □ & CUSC Application Form ■)   | Outturn | Outturn<br>Weather<br>Corrected | F.Yr. | F.Yr. | F.Yr. | F.Yr. | F.Yr. | F.Yr. | F.Yr. | F.Yr. | F.Yr. | DATA CAT             |
|---|---------|---------------------------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|----------------------|
|   |         |                                 | 1     | 2     | 3     | 4     | 5     | 6     | 7     | 8     |       |                      |
| Date of a), b), c), d) or e) as denoted above.  |         |                                 |       |       |       |       |       |       |       |       |       | <b>PC.A.4.3.3</b>    |
| Time of a), b), c), d) or e) as denoted above.  |         |                                 |       |       |       |       |       |       |       |       |       | <b>PC.A.4.3.3</b>    |
| <b>Connection Point Demand</b> (MW)   |         |                                 |       |       |       |       |       |       |       |       |       | <b>PC.A.4.3.1</b>    |
| <b>Connection Point Demand</b> (MVA <sub>r</sub> )  |         |                                 |       |       |       |       |       |       |       |       |       | <b>PC.A.4.3.1</b>    |
| Deduction made at <b>Connection Point</b> for <b>Small Power Stations, Medium Power Stations and Customer Generating Plant</b> (MW) |         |                                 |       |       |       |       |       |       |       |       |       | <b>PC.A.4.3.2(a)</b> |
| Reference to valid <b>Single Line Diagram</b>   |         |                                 |       |       |       |       |       |       |       |       |       | <b>PC.A.4.3.5</b>    |
| Reference to node and branch data.  |         |                                 |       |       |       |       |       |       |       |       |       | <b>PC.A.2.2</b>      |

Note: The following data block can be repeated for each post fault network revision that may impact on the Transmission System.

|   |  |  |  |  |  |  |  |  |  |  |  |                 |
|---|--|--|--|--|--|--|--|--|--|--|--|-----------------|
| Reference to post-fault revision of <b>Single Line Diagram</b>  |  |  |  |  |  |  |  |  |  |  |  | <b>PC.A.4.5</b> |
| Reference to post-fault revision of the node and branch data associated with the <b>Single Line Diagram</b>   |  |  |  |  |  |  |  |  |  |  |  | <b>PC.A.4.5</b> |
| Reference to the description of the actions and timescales involved in effecting the post-fault actions (e.g. auto-switching, manual, teleswitching, overload protection operation etc) |  |  |  |  |  |  |  |  |  |  |  | <b>PC.A.4.5</b> |

|                      |  |
|----------------------|--|
| <b>Access Group:</b> |  |
|----------------------|--|

Note: The following data block to be repeated for each **Connection Point** with the **Access Group**.

|  |  |  |  |  |  |  |  |  |  |  |  |                      |
|--|--|--|--|--|--|--|--|--|--|--|--|----------------------|
| Name of associated <b>Connection Point</b> within the same <b>Access Group:</b>  |  |  |  |  |  |  |  |  |  |  |  | <b>PC.A.4.3.1</b>    |
| <b>Demand</b> at associated <b>Connection Point</b> (MW)   |  |  |  |  |  |  |  |  |  |  |  | <b>PC.A.4.3.1</b>    |
| <b>Demand</b> at associated <b>Connection Point</b> (MVA <sub>r</sub> )  |  |  |  |  |  |  |  |  |  |  |  | <b>PC.A.4.3.1</b>    |
| Deduction made at associated <b>Connection Point</b> for <b>Small Power Stations, Medium Power Stations and Customer Generating Plant</b> (MW) |  |  |  |  |  |  |  |  |  |  |  | <b>PC.A.4.3.2(a)</b> |

**SCHEDULE 11 - CONNECTION POINT DATA**  
PAGE 2 OF 3

| Embedded Generation Data   |  |                              |           |           |           |           |           |           |           |           |                          |
|--|--|------------------------------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|--------------------------|
| Connection Point:  |  |                              |           |           |           |           |           |           |           |           |                          |
| DATA DESCRIPTION   | Outturn  | Outturn<br>Weather Corrected | F.Yr<br>1 | F.Yr<br>2 | F.Yr<br>3 | F.Yr<br>4 | F.Yr<br>5 | F.Yr<br>6 | F.Yr<br>7 | F.Yr<br>8 | DATA CAT                 |
| <b><u>Small Power Station, Medium Power Station and Customer Generation Summary</u></b>                                  | For each <b>Connection Point</b> where there are <b>Embedded Small Power Stations, Medium Power Stations</b> or <b>Customer Generating Stations</b> the following information is required: |                              |           |           |           |           |           |           |           |           |                          |
| No. of <b>Small Power Stations, Medium Power Stations</b> or <b>Customer Power Stations</b>                              |  |                              |           |           |           |           |           |           |           |           | <b>PC.A.3.1.4(a)</b>     |
| Number of <b>Generating Units or Power Generating Modules</b> within these stations                                      |  |                              |           |           |           |           |           |           |           |           | <b>PC.A.3.1.4(a)</b>     |
| Summated Capacity of all these <b>Generating Units and/or Power Generating Modules</b>                                   |  |                              |           |           |           |           |           |           |           |           | <b>PC.A.3.1.4(a)</b>     |
| Where the <b>Network Operator's System</b> places a constraint on the capacity of an <b>Embedded Large Power Station</b> |  |                              |           |           |           |           |           |           |           |           |                          |
| <b>Station Name</b>  |  |                              |           |           |           |           |           |           |           |           | <b>PC.A.3.2.2(c)</b>     |
| <b>Generating Unit</b>   |  |                              |           |           |           |           |           |           |           |           | <b>PC.A.3.2.2(c)</b>     |
| <b>System Constrained Capacity</b>   |  |                              |           |           |           |           |           |           |           |           | <b>PC.A.3.2.2(c)(i)</b>  |
| <b>Reactive Despatch Network Restriction</b>   |  |                              |           |           |           |           |           |           |           |           | <b>PC.A.3.2.2(c)(ii)</b> |

Formatted: Font: Not Bold

Formatted: Font: Not Bold

| Where the <b>Network Operator's System</b> places a constraint on the capacity of an <b>Offshore Transmission System</b> at an <b>Interface Point</b> |  |  |  |  |  |  |  |  |  |  |                      |
|---|--|--|--|--|--|--|--|--|--|--|----------------------|
| <b>Offshore Transmission System Name</b>  |  |  |  |  |  |  |  |  |  |  | <b>PC.A.3.2.2(c)</b> |
| <b>Interface Point Name</b>   |  |  |  |  |  |  |  |  |  |  | <b>PC.A.3.2.2(c)</b> |
| <b>Maximum Export Capacity</b>  |  |  |  |  |  |  |  |  |  |  | <b>PC.A.3.2.2(c)</b> |
| <b>Maximum Import Capacity</b>  |  |  |  |  |  |  |  |  |  |  | <b>PC.A.3.2.2(c)</b> |



**SCHEDULE 11 - CONNECTION POINT DATA**  
**PAGE 3 OF 3**

NOTES:

1. 'F.Yr.' means 'Financial Year'. F.Yr. 1 refers to the current financial year.
2. All **Demand** data should be net of the output (as reasonably considered appropriate by the **Existing-User**) of all **Embedded Small Power Stations, Medium Power Stations and Customer Generating Plant**. Generation and / or Auxiliary demand of **Embedded Large Power Stations** should not be included in the demand data submitted by the **Existing-User**. **Existing-Users** should refer to the **PC** for a full definition of the **Demand** to be included.
3. Peak **Demand** should relate to each **Connection Point** individually and should give the maximum demand that in the **Existing-User's** opinion could reasonably be imposed on the **National Electricity Transmission System**. **Existing-Users** may submit the **Demand** data at each node on the **Single Line Diagram** instead of at a **Connection Point** as long as the **Existing-User** reasonably believes such data relates to the peak (or minimum) at the **Connection Point**.  
  
In deriving **Demand** any deduction made by the **Existing-User** (as detailed in note 2 above) to allow for **Embedded Small Power Stations, Medium Power Stations and Customer Generating Plant** is to be specifically stated as indicated on the Schedule.
4. **NGET** may at its discretion require details of any **Embedded Small Power Stations** or **Embedded Medium Power Stations** whose output can be expected to vary in a random manner (eg. wind power) or according to some other pattern (eg. tidal power)
5. Where more than 95% of the total **Demand** at a **Connection Point** is taken by synchronous motors, values of the **Power Factor** at maximum and minimum continuous excitation may be given instead. **Power Factor** data should allow for series reactive losses on the **Existing-User's System** but exclude reactive compensation network susceptance specified separately in Schedule 5.
6. Where a **Reactive Despatch Network Restriction** is in place which requires the generator to maintain a target voltage set point this should be stated as an alternative to the size of the **Reactive Despatch Network Restriction**.



**SCHEDULE 12 - DEMAND CONTROL**  
**PAGE 1 OF 2**

The following information is required from each **Network Operator** and where indicated with an asterisk from **Externally Interconnected System Operators** and/or **Interconnector Users** and a **Pumped Storage Generator**. Where indicated with a double asterisk, the information is only required from **Suppliers**.

| DATA DESCRIPTION  | UNITS |                           | UPDATE TIME                         |            |
|---|-------|---------------------------|-------------------------------------|------------|
| <b><u>Demand Control</u></b>  |       |                           |                                     |            |
| <b>Demand</b> met or to be relieved by <b>Demand Control</b> (averaging at the <b>Demand Control Notification Level</b> or more over a half hour) at each <b>Connection Point</b> . |       |                           |                                     |            |
| <b>Demand Control</b> at time of <b>National Electricity Transmission System</b> weekly peak demand   |       |                           |                                     |            |
| Amount  | MW    | )F.yrs 0 to 5             | Week 24                             | <b>OC1</b> |
| Duration  | Min   | )                         |                                     |            |
| For each half hour  | MW    | Wks 2-8 ahead             | 1000 Mon                            | <b>OC1</b> |
| For each half hour  | MW    | Days 2-12 ahead           | 1200 Wed                            | <b>OC1</b> |
| For each half hour  | MW    | Previous calendar day     | 0600 daily                          | <b>OC1</b> |
| <b>**Customer Demand Management</b><br>(at the <b>Customer Demand Management Notification Level</b> or more at the <b>Connection Point</b> )  |       |                           |                                     |            |
| For each half hour  | MW    | Any time in Control Phase |                                     | <b>OC1</b> |
| For each half hour  | MW    | Remainder of period       | When changes occur to previous plan | <b>OC1</b> |
| For each half hour  | MW    | Previous calendar day     | 0600 daily                          | <b>OC1</b> |
| <b>**In Scotland, Load Management Blocks</b><br>For each block of 5MW or more, for each half hour   |       |                           |                                     |            |
|   | MW    | For the next day          | 11:00                               | <b>OC1</b> |

**SCHEDULE 12 - DEMAND CONTROL**  
PAGE 1 OF 2

| DATA DESCRIPTION   | UNITS | TIME COVERED            | UPDATE TIME       | DATA CAT.    |
|--|-------|-------------------------|-------------------|--------------|
| <b>*Demand Control or Pump Tripping Offered as Reserve</b>   |       |                         |                   |              |
| Magnitude of <b>Demand</b> or pumping load which is tripped  | MW    | Year ahead from week 24 | Week 24           | <b>DPD I</b> |
| <b>System Frequency</b> at which tripping is initiated   | Hz    | "                       | "                 | "            |
| Time duration of <b>System Frequency</b> below trip setting for tripping to be initiated   | S     | "                       | "                 | "            |
| Time delay from trip initiation to Tripping  | S     | "                       | "                 | "            |
| <b>Emergency Manual Load Disconnection</b>   |       |                         |                   |              |
| Method of achieving load disconnection   | Text  | Year ahead from week 24 | Annual in week 24 | OC6          |
| <b>Annual ACS Peak Demand (Active Power) at Connection Point</b> (requested under Schedule 11 - repeated here for reference)                                 | MW    | "                       | "                 | "            |
| Cumulative percentage of <b>Connection Point Demand (Active Power)</b> which can be disconnected by the following times from an instruction from <b>NGET</b> |       |                         |                   |              |
| 5 mins   | %     | "                       | "                 | "            |
| 10 mins  | %     | "                       | "                 | "            |
| 15 mins  | %     | "                       | "                 | "            |
| 20 mins  | %     | "                       | "                 | "            |
| 25 mins  | %     | "                       | "                 | "            |
| 30 mins  | %     | "                       | "                 | "            |

Notes:

1. **Network Operators** may delay the submission until calendar week 28.
2. No information collated under this Schedule will be transferred to the **Relevant Transmission Licensees** (or **Generators** undertaking **OTSDUW**).

**SCHEDULE 12A - AUTOMATIC LOW FREQUENCY DEMAND DISCONNECTION**  
**PAGE 1 OF 1**

Time Covered: Year ahead from week 24  
 Update Time: Annual in week 24

Data Category: OC6

| Grid Supply Point               | GSP Demand<br>MW | Low Frequency Demand Disconnection Blocks MW |              |             |             |             |             |             |             |             | Residual demand<br>MW |
|---------------------------------|------------------|--|--------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-----------------------|
|                                 |                  | 1<br>48.8Hz                                  | 2<br>48.75Hz | 3<br>48.7Hz | 4<br>48.6Hz | 5<br>48.5Hz | 6<br>48.4Hz | 7<br>48.2Hz | 8<br>48.0Hz | 9<br>47.8Hz |                       |
| GSP1                            |                  |  |              |             |             |             |             |             |             |             |                       |
| GSP2                            |                  |  |              |             |             |             |             |             |             |             |                       |
| GSP3                            |                  |  |              |             |             |             |             |             |             |             |                       |
| Total demand disconnected<br>MW |                  |  |              |             |             |             |             |             |             |             |                       |
| per block %                     |                  |  |              |             |             |             |             |             |             |             |                       |
| Total demand disconnection      |                  | MW ( % of aggregate demand of MW)            |              |             |             |             |             |             |             |             |                       |

Note: All demand refers to that at the time of forecast **National Electricity Transmission System** peak demand.

**Network Operators** may delay the submission until calendar week 28

No information collated under this schedule will be transferred to the **Relevant Transmission Licensees** (or **Generators** undertaking **OTSDUW**).

**Comment [A5]:** House Keeping - Bold  
**Formatted:** Font: Bold

**SCHEDULE 13 - FAULT INFEEED DATA**  
PAGE 1 OF 2

The data in this Schedule 13 is all **Standard Planning Data**, and is required from all **Existing-Users** other than **Generators** who are connected to the **National Electricity Transmission System** via a **Connection Point** (or who are seeking such a connection). A data submission is to be made each year in Week 24 (although **Network Operators** may delay the submission until Week 28). A separate submission is required for each node included in the **Single Line Diagram** provided in Schedule 5.

| DATA DESCRIPTION   | UNITS    | F.Yr. | F.Yr. | F.Yr. | F.Yr. | F.Yr. | F.Yr. | F.Yr. | F.Yr. | DATA to |                          |                                     |
|--|----------|-------|-------|-------|-------|-------|-------|-------|-------|---------|--------------------------|-------------------------------------|
|  |          | 0     | 1     | 2     | 3     | 4     | 5     | 6     | 7     | RTL     |                          |                                     |
| <u>SHORT CIRCUIT INFEEED TO THE NATIONAL ELECTRICITY TRANSMISSION SYSTEM FROM EXISTING-USERS SYSTEM AT A CONNECTION POINT</u><br>(P.C.A.2.5)                                     |          |       |       |       |       |       |       |       |       |         | CUSC Contract            | CUSC App. Form                      |
| Name of node or <b>Connection Point</b>  |          |       |       |       |       |       |       |       |       |         | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| Symmetrical three phase short-circuit current infeed   |          |       |       |       |       |       |       |       |       |         |                          |                                     |
| - at instant of fault  | kA       |       |       |       |       |       |       |       |       |         | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| - after subtransient fault current contribution has substantially decayed  | Ka       |       |       |       |       |       |       |       |       |         | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| Zero sequence source impedances as seen from the <b>Point of Connection</b> or node on the <b>Single Line Diagram</b> (as appropriate) consistent with the maximum infeed above: |          |       |       |       |       |       |       |       |       |         |                          |                                     |
| - Resistance   | % on 100 |       |       |       |       |       |       |       |       |         | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| - Reactance  | % on 100 |       |       |       |       |       |       |       |       |         | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| Positive sequence X/R ratio at instance of fault   |          |       |       |       |       |       |       |       |       |         | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| Pre-Fault voltage magnitude at which the maximum fault currents were calculated  | p.u.     |       |       |       |       |       |       |       |       |         | <input type="checkbox"/> | <input checked="" type="checkbox"/> |

**SCHEDULE 13 - FAULT INFEEED DATA**  
**PAGE 2 OF 2**

| DATA DESCRIPTION  | UNITS    | F.Yr. | F.Yr. | F.Yr. | F.Yr. | F.Yr. | F.Yr. | F.Yr. | F.Yr. | DATA to |                          |                                     |
|---|----------|-------|-------|-------|-------|-------|-------|-------|-------|---------|--------------------------|-------------------------------------|
|   |          | 0     | 1     | 2     | 3     | 4     | 5     | 6     | 7     | RTL     |                          |                                     |
| <u>SHORT CIRCUIT INFEEED TO THE NATIONAL ELECTRICITY TRANSMISSION SYSTEM FROM EXISTING-USER'S SYSTEM AT A CONNECTION POINT</u>  |          |       |       |       |       |       |       |       |       |         | CUSC Contract            | CUSC App. Form                      |
| Negative sequence impedances of <del>Existing</del> -User's System as seen from the <b>Point of Connection</b> or node on the <b>Single Line Diagram</b> (as appropriate). If no data is given, it will be assumed that they are equal to the positive sequence values. |          |       |       |       |       |       |       |       |       |         |                          |                                     |
| - Resistance  | % on 100 |       |       |       |       |       |       |       |       |         | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| - Reactance   | % on 100 |       |       |       |       |       |       |       |       |         | <input type="checkbox"/> | <input checked="" type="checkbox"/> |

## SCHEDULE 14 - FAULT INFEED DATA (GENERATORS INCLUDING UNIT TRANSFORMERS AND STATION TRANSFORMERS)

PAGE 1 OF 5

The data in this Schedule 14 is all **Standard Planning Data**, and is to be provided by **Generators**, with respect to all directly connected **Power Stations**, all **Embedded Large Power Stations** and all **Embedded Medium Power Stations** connected to the **Subtransmission System**. A data submission is to be made each year in Week 24.

### Fault infeeds via Unit Transformers

A submission should be made for each **Generating Unit** (including those which are part of a **Synchronous Power Generating Module**) with an associated **Unit Transformer**. Where there is more than one **Unit Transformer** associated with a **Generating Unit**, a value for the total infeed through all **Unit Transformers** should be provided. The infeed through the **Unit Transformer(s)** should include contributions from all motors normally connected to the **Unit Board**, together with any generation (eg **Auxiliary Gas Turbines**) which would normally be connected to the **Unit Board**, and should be expressed as a fault current at the **Generating Unit** terminals for a fault at that location.

Formatted: Font: Not Bold

Formatted: Font: Not Bold

| DATA DESCRIPTION  | UNITS    | F.Yr. 0 | F.Yr. 1 | F.Yr. 2 | F.Yr. 3 | F.Yr. 4 | F.Yr. 5 | F.Yr. 6 | F.Yr. 7 | DATA to RTL              |                                     |
|---|----------|---------|---------|---------|---------|---------|---------|---------|---------|--------------------------|-------------------------------------|
| (P.C.A.2.5)   |          |         |         |         |         |         |         |         |         | CUSC Contract            | CUSC App. Form                      |
| Name of <b>Power Station</b>  |          |         |         |         |         |         |         |         |         | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| Number of <b>Unit Transformer</b>   |          |         |         |         |         |         |         |         |         | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| Symmetrical three phase short-circuit current infeed through the <b>Unit Transformers(s)</b> for a fault at the <b>Generating Unit</b> terminals  |          |         |         |         |         |         |         |         |         |                          |                                     |
| - at instant of fault   | kA       |         |         |         |         |         |         |         |         | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| - after subtransient fault current contribution has substantially decayed   | kA       |         |         |         |         |         |         |         |         | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| Positive sequence X/R ratio at instance of fault  |          |         |         |         |         |         |         |         |         | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| Subtransient time constant (if significantly different from 40ms)   | ms       |         |         |         |         |         |         |         |         | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| Pre-fault voltage at fault point (if different from 1.0 p.u.)   |          |         |         |         |         |         |         |         |         | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| The following data items need only be supplied if the <b>Generating Unit</b> Step-up Transformer can supply zero sequence current from the <b>Generating Unit</b> side to the <b>National Electricity Transmission System</b> |          |         |         |         |         |         |         |         |         |                          |                                     |
| Zero sequence source impedances as seen from the <b>Generating Unit</b> terminals consistent with the maximum infeed above:   |          |         |         |         |         |         |         |         |         |                          |                                     |
| - Resistance  | % on 100 |         |         |         |         |         |         |         |         | <input type="checkbox"/> | <input checked="" type="checkbox"/> |



**SCHEDULE 14 - FAULT INFEEED DATA (GENERATORS INCLUDING UNIT TRANSFORMERS AND STATION TRANSFORMERS)**

Fault infeeds via Station Transformers

A submission is required for each **Station Transformer** directly connected to the **National Electricity Transmission System**. The submission should represent normal operating conditions when the maximum number of **Gensets** are **Synchronised** to the **System**, and should include the fault current from all motors normally connected to the **Station Board**, together with any Generation (eg **Auxiliary Gas Turbines**) which would normally be connected to the **Station Board**. The fault infeed should be expressed as a fault current at the hv terminals of the **Station Transformer** for a fault at that location.

If the submission for normal operating conditions does not represent the worst case, then a separate submission representing the maximum fault infeed that could occur in practice should be made.

| DATA DESCRIPTION  | UNITS    | F.Yr.<br>0 | F.Yr.<br>1 | F.Yr.<br>2 | F.Yr.<br>3 | F.Yr.<br>4 | F.Yr.<br>5 | F.Yr.<br>6 | F.Yr.<br>7 | DATA to<br>RTL           |                                     |
|---|----------|------------|------------|------------|------------|------------|------------|------------|------------|--------------------------|-------------------------------------|
| (PC.A.2.5)  |          |            |            |            |            |            |            |            |            | CUSC<br>Contract         | CUSC<br>App.<br>Form                |
| Name of <b>Power Station</b>  |          |            |            |            |            |            |            |            |            | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| Number of <b>Station Transformer</b>  |          |            |            |            |            |            |            |            |            | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| Symmetrical three phase short-circuit current infeed for a fault at the <b>Connection Point</b>                       |          |            |            |            |            |            |            |            |            |                          |                                     |
| - at instant of fault   | kA       |            |            |            |            |            |            |            |            | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| - after subtransient fault current contribution has substantially decayed   | kA       |            |            |            |            |            |            |            |            | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| Positive sequence X/R ratio<br>At instance of fault   |          |            |            |            |            |            |            |            |            | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| Subtransient time constant (if significantly different from 40ms)   | mS       |            |            |            |            |            |            |            |            | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| Pre-fault voltage (if different from 1.0 p.u.) at fault point (See note 1)  |          |            |            |            |            |            |            |            |            | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| Zero sequence source Impedances as seen from the <b>Point of Connection</b> Consistent with the maximum Infeed above: |          |            |            |            |            |            |            |            |            |                          |                                     |
| - Resistance  | % on 100 |            |            |            |            |            |            |            |            | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| - Reactance   | % on 100 |            |            |            |            |            |            |            |            | <input type="checkbox"/> | <input checked="" type="checkbox"/> |

Note 1. The pre-fault voltage provided above should represent the voltage within the range 0.95 to 1.05 that gives the highest fault current

Note 2. % on 100 is an abbreviation for % on 100 MVA



**SCHEDULE 14 - FAULT INFEED DATA (GENERATORS INCLUDING UNIT TRANSFORMERS AND STATION TRANSFORMERS)**

Fault infeeds from Power Park Modules

A submission is required for the whole **Power Park Module** and for each **Power Park Unit** type or equivalent. The submission shall represent operating conditions that result in the maximum fault infeed. The fault current from all motors normally connected to the **Power Park Unit's** electrical system shall be included. The fault infeed shall be expressed as a fault current at the terminals of the **Power Park Unit**, or the **Common Collection Busbar** if an equivalent **Single Line Diagram** and associated data as described in PC.A.2.2.2 is provided, and the **Grid Entry Point**, or **User System Entry Point** if **Embedded**, for a fault at the **Grid Entry Point**, or **User System Entry Point** if **Embedded**.

Should actual data in respect of fault infeeds be unavailable at the time of the application for a **CUSC Contract** or **Embedded Development Agreement**, a limited subset of the data, representing the maximum fault infeed that may result from all of the plant types being considered, shall be submitted. This data will, as a minimum, represent the root mean square of the positive, negative and zero sequence components of the fault current for both single phase and three phase solid faults at the **Grid Entry Point** (or **User System Entry Point** if **Embedded**) at the time of fault application and 50ms following fault application. Actual data in respect of fault infeeds shall be submitted to **NGET** as soon as it is available, in line with PC.A.1.2

| DATA DESCRIPTION  | UNITS | F.Yr. | F.Yr. | F.Yr. | F.Yr. | F.Yr. | F.Yr. | F.Yr. | F.Yr. | DATA to RTL | CUSC Contract            | CUSC App. Form                      |
|---|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------------|--------------------------|-------------------------------------|
|   |       | 0     | 1     | 2     | 3     | 4     | 5     | 6     | 7     |             |                          |                                     |
| <i>(PC.A.2.5)</i>   |       |       |       |       |       |       |       |       |       |             |                          |                                     |
| Name of <b>Power Station</b>  |       |       |       |       |       |       |       |       |       |             | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| Name of <b>Power Park Module</b>  |       |       |       |       |       |       |       |       |       |             | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| <b>Power Park Unit</b> type   |       |       |       |       |       |       |       |       |       |             | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| A submission shall be provided for the contribution of the entire <b>Power Park Module</b> and each type of <b>Power Park Unit</b> or equivalent to the positive, negative and zero sequence components of the short circuit current at the <b>Power Park Unit</b> terminals, or <b>Common Collection Busbar</b> , and <b>Grid Entry Point</b> or <b>User System Entry Point</b> if <b>Embedded</b> for |       |       |       |       |       |       |       |       |       |             |                          |                                     |
| (i) a solid symmetrical three phase short circuit   |       |       |       |       |       |       |       |       |       |             | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| (ii) a solid single phase to earth short circuit  |       |       |       |       |       |       |       |       |       |             | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| (iii) a solid phase to phase short circuit  |       |       |       |       |       |       |       |       |       |             | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| (iv) a solid two phase to earth short circuit   |       |       |       |       |       |       |       |       |       |             | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| at the <b>Grid Entry Point</b> or <b>User System Entry Point</b> if <b>Embedded</b> .   |       |       |       |       |       |       |       |       |       |             | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| If protective controls are used and active for the above conditions, a submission shall be provided in the limiting case where the protective control is not active. This case may require application of a non-solid fault, resulting in a retained voltage at the fault point.  |       |       |       |       |       |       |       |       |       |             | <input type="checkbox"/> | <input checked="" type="checkbox"/> |

**SCHEDULE 14 - FAULT INFEEED DATA (GENERATORS INCLUDING UNIT TRANSFORMERS AND STATION TRANSFORMERS)**

PAGE 4 OF 5

| <u>DATA DESCRIPTION</u>  | <u>UNITS</u>                             | <u>F.Yr.</u><br><u>0</u> | <u>F.Yr.</u><br><u>1</u> | <u>F.Yr.</u><br><u>2</u> | <u>F.Yr.</u><br><u>3</u> | <u>F.Yr.</u><br><u>4</u> | <u>F.Yr.</u><br><u>5</u> | <u>F.Yr.</u><br><u>6</u> | <u>F.Yr.</u><br><u>7</u> | <u>DATA to RTL</u> | <u>DATA DESCRIPTION</u> |
|--|--|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------|-------------------------|
|  |  |                          |                          |                          |                          |                          |                          |                          |                          | CUSC Contract      | CUSC App. Form          |
| - A continuous time trace and table showing the root mean square of the positive, negative and zero sequence components of the fault current from the time of fault inception to 140ms after fault inception at 10ms intervals | Graphical and tabular<br><br>kA versus s |                          |                          |                          |                          |                          |                          |                          |                          | □                  | ■                       |
| - A continuous time trace and table showing the positive, negative and zero sequence components of retained voltage at the terminals or <b>Common Collection Busbar</b> , if appropriate                                       | p.u. versus s                            |                          |                          |                          |                          |                          |                          |                          |                          | □                  | ■                       |
| - A continuous time trace and table showing the root mean square of the positive, negative and zero sequence components of retained voltage at the fault point, if appropriate   | p.u. versus s                            |                          |                          |                          |                          |                          |                          |                          |                          | □                  | ■                       |

**SCHEDULE 14 - FAULT INFEEED DATA (GENERATORS INCLUDING UNIT TRANSFORMERS AND STATION TRANSFORMERS)**  
PAGE 5 OF 5

| <u>DATA DESCRIPTION</u>   | <u>UNITS</u> | <u>F.Yr.</u><br><u>0</u> | <u>F.Yr.</u><br><u>1</u> | <u>F.Yr.</u><br><u>2</u> | <u>F.Yr.</u><br><u>3</u> | <u>F.Yr.</u><br><u>4</u> | <u>F.Yr.</u><br><u>5</u> | <u>F.Yr.</u><br><u>6</u> | <u>F.Yr.</u><br><u>7</u> | <u>DATA to RTL</u>       | <u>DATA DESCRIPTION</u>             |
|---|--------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|-------------------------------------|
|   |              |                          |                          |                          |                          |                          |                          |                          |                          | CUSC Contract            | CUSC App. Form                      |
| For <b>Power Park Units</b> that utilise a protective control, such as a crowbar circuit,             |              |                          |                          |                          |                          |                          |                          |                          |                          |                          |                                     |
| - additional rotor resistance applied to the <b>Power Park Unit</b> under a fault situation           | % on MVA     |                          |                          |                          |                          |                          |                          |                          |                          | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| - additional rotor reactance applied to the <b>Power Park Unit</b> under a fault situation.           | % on MVA     |                          |                          |                          |                          |                          |                          |                          |                          | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| Positive sequence X/R ratio of the equivalent at time of fault at the <b>Common Collection Busbar</b> |              |                          |                          |                          |                          |                          |                          |                          |                          | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| Minimum zero sequence impedance of the equivalent at a <b>Common Collection Busbar</b>                |              |                          |                          |                          |                          |                          |                          |                          |                          | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| <b>Active Power</b> generated pre-fault   | MW           |                          |                          |                          |                          |                          |                          |                          |                          | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| Number of <b>Power Park Units</b> in equivalent generator   |              |                          |                          |                          |                          |                          |                          |                          |                          | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| Power Factor (lead or lag)  |              |                          |                          |                          |                          |                          |                          |                          |                          | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| Pre-fault voltage (if different from 1.0 p.u.) at fault point (See note 1)                            | p.u.         |                          |                          |                          |                          |                          |                          |                          |                          | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| Items of reactive compensation switched in pre-fault  |              |                          |                          |                          |                          |                          |                          |                          |                          | <input type="checkbox"/> | <input checked="" type="checkbox"/> |

Note 1. The pre-fault voltage provided above should represent the voltage within the range 0.95 to 1.05 that gives the highest fault current

**SCHEDULE 15 – MOTHBALLED POWER GENERATING MODULE, MOTHBALLED GENERATING UNIT, MOTHBALLED POWER PARK MODULE (INCLUDING MOTHBALLED DC CONNECTED POWER PARK MODULES), MOTHBALLED HVDC SYSTEMS, MOTHBALLED HVDC CONVERTERS, MOTHBALLED DC CONVERTERS AT A DC CONVERTER STATION AND ALTERNATIVE FUEL DATA**

PAGE 1 OF 3

**MOTHBALLED POWER GENERATING MODULES, MOTHBALLED GENERATING UNIT, MOTHBALLED POWER PARK MODULE (INCLUDING MOTHBALLED DC CONNECTED POWER PARK MODULES), MOTHBALLED HVDC SYSTEMS, MOTHBALLED HVDC CONVERTERS OR MOTHBALLED DC CONVERTER AT A DC CONVERTER STATION AND ALTERNATIVE FUEL DATA**  
 The following data items must be supplied with respect to each **Mothballed Power Generating Module, Mothballed Generating Unit, Mothballed Power Park Module (including Mothballed DC Connected Power Park Modules), Mothballed HVDC Systems, Mothballed HVDC Converters or Mothballed DC Converters** at a DC Converter station

Power Station \_\_\_\_\_ Generating Unit, Power Park Module or DC Converter Name (e.g. Unit \_\_\_\_\_)

| DATA DESCRIPTION                          | UNITS | DATA CAT | GENERATING UNIT DATA |            |            |            |             | Total MW being returned |
|---|-------|----------|----------------------|------------|------------|------------|-------------|-------------------------|
|   |       |          | <1 month             | 1-2 months | 2-3 months | 3-6 months | 6-12 months |                         |
| MW output that can be returned to service | MW    | DPD II   |                      |            |            |            |             |                         |

**Notes**

- The time periods identified in the above table represent the estimated time it would take to return the **Mothballed Power Generating Module, Mothballed Generating Unit, Mothballed Power Park Module (Mothballed DC Connected Power Park Modules), Mothballed HVDC Systems, Mothballed HVDC Converters or Mothballed DC Converter** at a DC Converter Station to service once a decision to return has been made.
- Where a **Mothballed Power Generating Module, Mothballed Power Park Module (including a Mothballed DC Connected Power Park Module), Mothballed HVDC System, Mothballed HVDC Converter or Mothballed DC Converter** at a DC Converter Station can be physically returned in stages covering more than one of the time periods identified in the above table then information should be provided for each applicable time period.
- The estimated notice to physically return MW output to service should be determined in accordance with **Good Industry Practice** assuming normal working arrangements and normal plant procurement lead times.
- The MW output values in each time period should be incremental MW values, e.g. if 150MW could be returned in 2 – 3 months and an additional 50MW in 3 – 6 months then the values in the columns should be Nil, Nil, 150, 50, Nil, Nil, 200 respectively.
- Significant factors which may prevent the **Mothballed Power Generating Module, Mothballed Generating Unit, Mothballed Power Park Module (Mothballed DC Connected Power Park Module), Mothballed HVDC System, Mothballed HVDC Converter or Mothballed DC Converter** at a DC Converter Station achieving the estimated values provided in this table, excluding factors relating to **Transmission Entry Capacity**, should be appended separately.

Formatted Table

Formatted: Font: Not Bold

Formatted: Font: Bold

Formatted: Font: Bold

Formatted: Font: Bold

Formatted: Font: Not Bold

Formatted: Font: Bold

Formatted: Font: Bold

Formatted: Font: Not Bold

Formatted: Font: Bold

Formatted: Font: Bold

Formatted: Font: Not Bold

Formatted: Font: Bold

Formatted: Font: Bold

Formatted: Font: Not Bold

Formatted: Font: Bold

Formatted: Font: Not Bold

Formatted: Font: Not Bold

**SCHEDULE 15 -- MOTHBALLED POWER GENERATING MODULES, MOTHBALLED GENERATING UNIT, MOTHBALLED POWER PARK MODULE (INCLUDING DC CONNECTED POWER PARK MODULES), MOTHBALLED HVDC SYSTEMS, MOTHBALLED HVDC CONVERTERS, MOTHBALLED DC CONVERTERS AT A DC CONVERTER STATION AND ALTERNATIVE FUEL DATA**

**ALTERNATIVE FUEL INFORMATION**

The following data items for alternative fuels need only be supplied with respect to each **Generating Unit** whose primary fuel is gas including those which form part of a **Power Generating Module**.

| Power Station   | Generating Unit Name (e.g. Unit 1) |        |                                 |                                 |
|---|------------------------------------|--------|---------------------------------|---------------------------------|
|   | DATA DESCRIPTION                   | UNITS  | DATA CAT                        | GENERATING UNIT DATA            |
| Alternative Fuel Type<br>(*please specify)  | Text                               | DPD II | 1                               | 2                               |
|   |                                    |        | Oil distillate                  | Other gas*                      |
| CHANGEOVER TO ALTERNATIVE FUEL  |                                    |        |                                 |                                 |
| For off-line changeover:  |                                    |        |                                 |                                 |
| Time to carry out off-line fuel changeover  | Minutes                            | DPD II |                                 |                                 |
| Maximum output following off-line changeover  | MW                                 | DPD II |                                 |                                 |
| For on-line changeover:   |                                    |        |                                 |                                 |
| Time to carry out on-line fuel changeover   | Minutes                            | DPD II |                                 |                                 |
| Maximum output during on-line fuel changeover   | MW                                 | DPD II |                                 |                                 |
| Maximum output following on-line changeover   | MW                                 | DPD II |                                 |                                 |
| Maximum operating time at full load assuming:   |                                    |        |                                 |                                 |
| Typical stock levels  | Hours                              | DPD II |                                 |                                 |
| Maximum possible stock levels   | Hours                              | DPD II |                                 |                                 |
| Maximum rate of replacement of depleted stocks of alternative fuels on the basis of <b>Good Industry Practice</b> | MWh(electrical)/day                | DPD II |                                 |                                 |
| Is changeover to alternative fuel used in normal operating arrangements?  | Text                               | DPD II |                                 |                                 |
| Number of successful changeovers carried out in the last <b>NGET Financial Year</b> (** delete as appropriate)    | Text                               | DPD II | 0 / 1-5 / 6-10 / 11-20 / >20 ** | 0 / 1-5 / 6-10 / 11-20 / >20 ** |

Formatted: Font: 9 pt

Formatted: Font: Bold

Formatted: Font: 9 pt

Formatted: Font: 9 pt

Formatted: Font: 9 pt

Formatted: Font: 9 pt

Formatted: Font: 9 pt



**SCHEDULE 15 -- MOTHBALLED POWER GENERATING MODULES, MOTHBALLED GENERATING UNIT, MOTHBALLED POWER PARK MODULE (INCLUDING MOTHBALLED DC CONNECTED POWER PARK MODULES), MOTHBALLED HVDC SYSTEMS, MOTHBALLED HVDC CONVERTERS MOTHBALLED DC CONVERTERS AT A DC CONVERTER STATION AND ALTERNATIVE FUEL DATA**

| DATA DESCRIPTION   | UNITS                                | DATA CAT | GENERATING UNIT DATA |   |   |   |
|--|--------------------------------------|----------|----------------------|---|---|---|
|  |                                      |          | 1                    | 2 | 3 | 4 |
| <b>CHANGEOVER BACK TO MAIN FUEL</b><br>For off-line changeover:<br>Time to carry out off-line fuel changeover<br>For on-line changeover:<br>Time to carry out on-line fuel changeover<br>Maximum output during on-line fuel changeover | <br><br>Minutes<br><br>Minutes<br>MW |          |                      |   |   |   |

**Notes**

1. Where a **Generating Unit** has the facilities installed to generate using more than one alternative fuel type details of each alternative fuel should be given.
2. Significant factors and their effects which may prevent the use of alternative fuels achieving the estimated values provided in this table (e.g. emissions limits, distilled water stocks etc.) should be appended separately.

- No information collated under this Schedule will be transferred to the **Relevant Transmission Licensees**



**SCHEDULE 16 - BLACK START INFORMATION**  
**PAGE 1 OF 1**

| <b>BLACK START INFORMATION</b>  | Units                | Data Category |
|---|----------------------|---------------|
| <p>The following data/text items are required from each <b>Generator</b> for each <b>BM Unit</b> at a <b>Large Power Station</b> as detailed in PC.A.5.7. Data is not required for <b>Generating Units</b> that are contracted to provide <b>Black Start Capability</b>, <b>Power Generating Modules</b>, <b>Power Park Modules</b> or <b>Generating Units</b> that have an <b>Intermittent Power Source</b>. The data should be provided in accordance with PC-A.1.2 and also, where possible, upon request from NGET during a <b>Black Start</b>.</p> |                      |               |
| <p>Data Description<br/> (PC.A.5.7) (■ CUSC Contract)</p>   |                      |               |
| <p>Assuming all <b>BM Units</b> were running immediately prior to the <b>Total Shutdown</b> or <b>Partial Shutdown</b> and in the event of loss of all external power supplies, provide the following information:</p>  |                      |               |
| <p>a) Expected time for the first and subsequent <b>BM Units</b> to be <b>Synchronised</b>, from the restoration of external power supplies, assuming external power supplies are not available for up to 24hrs</p>   | Tabular or Graphical | DPD II        |
| <p>b) Describe any likely issues that would have a significant impact on a <b>BM Unit's</b> time to be <b>Synchronised</b> arising as a direct consequence of the inherent design or operational practice of the <b>Power Station</b> and/or <b>BM Unit</b>, e.g. limited barring facilities, time from a <b>Total Shutdown</b> or <b>Partial Shutdown</b> at which batteries would be discharged.</p>  | Text                 | DPD II        |
| <p><b>Block Loading Capability:</b></p>   |                      |               |
| <p>c) Provide estimated <b>Block Loading Capability</b> from 0MW to <b>Registered Capacity</b> of each <b>BM Unit</b> based on the unit being 'hot' (run prior to shutdown) and also 'cold' (not run for 48hrs or more prior to the shutdown). The <b>Block Loading Capability</b> should be valid for a frequency deviation of 49.5Hz – 50.5Hz. The data should identify any required 'hold' points.</p>   | Tabular or Graphical | DPD II        |

**Formatted:** Font: Bold



## SCHEDULE 18 - OFFSHORE TRANSMISSION SYSTEM DATA

PAGE 1 OF 24

The data in this Schedule 18 is required from **Generators** who are undertaking **OTSDUW** and connecting to a **Transmission Interface Point**.

| DATA DESCRIPTION  | UNITS      | DATA to                  |                                     | DATA CAT.                      | GENERATING UNIT OR STATION DATA |       |       |       |       |       |       |   |
|---|------------|--------------------------|-------------------------------------|--------------------------------|---------------------------------|-------|-------|-------|-------|-------|-------|---|
|   |            | RTL                      | CUSC                                |                                | F.Yr0                           | F.Yr1 | F.Yr2 | F.Yr3 | F.Yr4 | F.Yr5 | F.Yr6 |   |
|   |            | CUSC Cont ract           | App. Form                           |                                |                                 |       |       |       |       |       |       | 6 |
| <b>INDIVIDUAL OTSDUW DATA</b>   |            |                          |                                     |                                |                                 |       |       |       |       |       |       |   |
| <b>Interface Point Capacity</b> (PC.A.3.2.2 (a))  | MW<br>MVAr | <input type="checkbox"/> | <input checked="" type="checkbox"/> |                                |                                 |       |       |       |       |       |       |   |
| Performance Chart at the <b>Transmission Interface Point for OTSDUW Plant and Apparatus</b> (PC.A.3.2.2(f)(iv))   |            | <input type="checkbox"/> | <input checked="" type="checkbox"/> |                                |                                 |       |       |       |       |       |       |   |
| <b>OTSDUW DEMANDS</b>   |            |                          |                                     |                                |                                 |       |       |       |       |       |       |   |
| <b>Demand</b> associated with the <b>OTSDUW Plant and Apparatus</b> (excluding OTSDUW DC Converters – see Note 1) supplied at each <b>Interface Point</b> . The <b>Existing-User</b> should also provide the <b>Demand</b> supplied to each <b>Connection Point</b> on the <b>OTSDUW Plant and Apparatus</b> . (PC.A.5.2.5) |            |                          |                                     |                                |                                 |       |       |       |       |       |       |   |
| - The maximum <b>Demand</b> that could occur.   | MW<br>MVAr | <input type="checkbox"/> |                                     | <b>DPD I</b>                   |                                 |       |       |       |       |       |       |   |
| - <b>Demand</b> at specified time of annual peak half hour of <b>National Electricity Transmission System Demand at Annual ACS Conditions</b> .   | MW<br>MVAr | <input type="checkbox"/> |                                     | <b>DPD I</b><br><b>DPD II</b>  |                                 |       |       |       |       |       |       |   |
| - <b>Demand</b> at specified time of annual minimum half-hour of <b>National Electricity Transmission System Demand</b> .   | MW<br>MVAr | <input type="checkbox"/> |                                     | <b>DPD II</b><br><b>DPD II</b> |                                 |       |       |       |       |       |       |   |
| (Note 1 – <b>Demand</b> required from <b>OTSDUW DC Converters</b> should be supplied under page 2 of Schedule 18).  |            |                          |                                     |                                |                                 |       |       |       |       |       |       |   |

## SCHEDULE 18 - OFFSHORE TRANSMISSION SYSTEM DATA

PAGE 2 OF 24

### OTSDUW USERS SYSTEM DATA

| DATA DESCRIPTION  | UNITS        | DATA to RTL   |                | DATA CATEGORY |
|---|--------------|---------------|----------------|---------------|
|   |              | CUSC Contract | CUSC App. Form |               |
| <b>OFFSHORE TRANSMISSION SYSTEM LAYOUT</b><br><i>(PC.A.2.2.1, PC.A.2.2.2 and P.C.A.2.2.3)</i>   |              |               |                |               |
| A <b>Single Line Diagram</b> showing connectivity of all of the <b>Offshore Transmission System</b> including all <b>Plant and Apparatus</b> between the <b>Interface Point</b> and all Connection <b>Points</b> is required.   |              | ■             | ■              | SPD           |
| This <b>Single Line Diagram</b> shall depict the arrangement(s) of all of the existing and proposed load current carrying <b>Apparatus</b> relating to both existing and proposed <b>Interface Points</b> and <b>Connection Points</b> , showing electrical circuitry (ie. overhead lines, underground cables (including subsea cables), power transformers and similar equipment), operating voltages, circuit breakers and phasing arrangements |              | ■             | ■              | SPD           |
| <b>Operational Diagrams</b> of all substations within the <b>OTSDUW Plant and Apparatus</b>   |              | ■             | ■              | SPD           |
| <b>SUBSTATION INFRASTRUCTURE</b> <i>(PC.A.2.2.6)</i>  |              |               |                |               |
| For the infrastructure associated with any <b>OTSDUW Plant and Apparatus</b>  |              |               |                |               |
| Rated 3-phase rms short-circuit withstand current   | kA           | ■             | ■              | SPD           |
| Rated 1-phase rms short-circuit withstand current   | kA           | ■             | ■              | SPD           |
| Rated Duration of short-circuit withstand   | s            | ■             | ■              | SPD           |
| Rated rms continuous current  | A            | ■             | ■              | SPD           |
| <b>LUMPED SUSCEPTANCES</b> <i>(PC.A.2.3)</i>  |              |               |                |               |
| Equivalent Lumped Susceptance required for all parts of the User's Subtransmission System (including OTSDUW Plant and Apparatus) which are not included in the Single Line Diagram.   |              | ■             | ■              |               |
| This should not include:  |              | ■             | ■              |               |
| (a) independently switched reactive compensation equipment identified above.  |              | ■             | ■              |               |
| (b) any susceptance of the <b>OTSDUW Plant and Apparatus</b> inherent in the <b>Demand (Reactive Power)</b> data provided on Page 1 and 2 of this Schedule 14.  |              | ■             | ■              |               |
| Equivalent lumped shunt susceptance at nominal <b>Frequency</b> .   | % on 100 MVA | ■             | ■              |               |

**SCHEDULE 18 - OFFSHORE TRANSMISSION SYSTEM DATA**  
**PAGE 3 OF 24**

**OFFSHORE TRANSMISSION SYSTEM DATA**  
 Branch Data (PC.A.2.2.4)

| Node<br>1 | Node<br>2 | Rated<br>Voltage<br>(kV) | Operating<br>Voltage (kV) | Circuit | PPS PARAMETERS    |                   |                    | ZPS PARAMETERS    |                   |                   | Maximum Continuous<br>Ratings |                          |                 | Length<br>(km) |
|-----------|-----------|--------------------------|---------------------------|---------|-------------------|-------------------|--------------------|-------------------|-------------------|-------------------|-------------------------------|--------------------------|-----------------|----------------|
|           |           |                          |                           |         | R1<br>%100<br>MVA | X1<br>%100<br>MVA | B 1<br>%100<br>MVA | R0<br>%100<br>MVA | X0<br>%100M<br>VA | B0<br>%100M<br>VA | Winter<br>(MVA)               | Sping<br>Autumn<br>(MVA) | Summer<br>(MVA) |                |
|           |           |                          |                           |         |                   |                   |                    |                   |                   |                   |                               |                          |                 |                |
|           |           |                          |                           |         |                   |                   |                    |                   |                   |                   |                               |                          |                 |                |
|           |           |                          |                           |         |                   |                   |                    |                   |                   |                   |                               |                          |                 |                |
|           |           |                          |                           |         |                   |                   |                    |                   |                   |                   |                               |                          |                 |                |

**Notes**

1. For information equivalent STC Reference: STCP12-1m Part 3 – 2.1 Branch Data
2. In the case where an overhead line exists within the OTSDUW Plant and Apparatus the Mutual inductances should also be provided.

**SCHEDULE 18 - OFFSHORE TRANSMISSION SYSTEM DATA**  
**PAGE 4 OF 24**

**OFFSHORE TRANSMISSION SYSTEM DATA**

2 Winding Transformer Data (PC.A.2.2.5)

The data below is **Standard Planning Data**, and details should be shown below of all transformers shown on the **Single Line Diagram**

| HV Node | HV (kV) | LV Node | LV (kV) | Rating (MVA) | Transformer | Positive Phase Sequence Reactance % on 100MVA |         |          | Positive Phase Sequence Resistance % on 100 MVA |         |          | Tap Changer    |             |      | Winding Arr. | Earthing Method (Direct /Res /Reac) | Earthing Impedance method |
|---------|---------|---------|---------|--------------|-------------|---|---------|----------|---|---------|----------|----------------|-------------|------|--------------|-------------------------------------|---------------------------|
|         |         |         |         |              |             | Max Tap                                       | Min Tap | Norm Tap | Max Tap   | Min Tap | Norm Tap | Range +% to -% | Step size % | type |              |                                     |                           |
|         |         |         |         |              |             |   |         |          |   |         |          |                |             |      |              |                                     |                           |
|         |         |         |         |              |             |   |         |          |   |         |          |                |             |      |              |                                     |                           |

Notes

1 For information the corresponding STC Reference is STCP12-1: Part 3 – 2.4 Transformers



**SCHEDULE 18 - OFFSHORE TRANSMISSION SYSTEM DATA**

**PAGE 6 OF 24**

**OFFSHORE TRANSMISSION SYSTEM DATA**

Circuit Breaker Data (PC.A.2.2.6(a))

The data below is all **Standard Planning Data**, and should be provided for all **OTSUA** switchgear (ie. circuit breakers, load disconnectors and disconnectors)

| Location | Circuit Breaker Data |               |                   |      |       |      |                   | Assumed Operating Times |                                      |                 | 3 Phase               |  |   |   | 1 Phase  |  |   |   | DC time constant at testing of asymmetrical breaking ability (s) |  |  |  |
|----------|----------------------|---------------|-------------------|------|-------|------|-------------------|-------------------------|--------------------------------------|-----------------|-----------------------|--|---|---|--|--|---|---|--|--|--|--|
|          | Name                 | Rated Voltage | Operating Voltage | Make | Model | Type | Year Commissioned | Circuit Breaker (mS)    | Minimum Protection & Trip Relay (mS) | Total Time (mS) | Continuous Rating (A) | Fault Rating (RMS Symmetrical) (3 phase) (MVA) | Fault Break Rating (RMS Symmetrical) (3 phase) (kA) | Fault Break Rating (Peak Asymmetrical) (3 phase) (kA) | Fault Make Rating (Peak Asymmetrical) (3 phase) (kA) | Fault Rating (RMS Symmetrical) (1 phase) (MVA) | Fault Break Rating (RMS Symmetrical) (1 phase) (kA) | Fault Break Rating (Peak Asymmetrical) (1 phase) (kA) |  | Fault Make Rating (Peak Asymmetrical) (1 phase) (kA) |  |  |
|          |                      |               |                   |      |       |      |                   |                         |                                      |                 |                       |  |   |   |  |  |   |   |  |  |  |  |



**SCHEDULE 18 - OFFSHORE TRANSMISSION SYSTEM DATA**  
**PAGE 7 OF 24**

**OFFSHORE TRANSMISSION SYSTEM DATA**

REACTIVE COMPENSATION EQUIPMENT (PC.A.2.4(e))

| <b>Item</b> | <b>Node</b> | <b>kV</b> | <b>Device No.</b> | <b>Rating (MVar)</b> | <b>P Loss (kW)</b> | <b>Tap range</b> | <b>Connection Arrangement</b> |
|-------------|-------------|-----------|-------------------|----------------------|--------------------|------------------|-------------------------------|
|             |             |           |                   |                      |                    |                  |                               |
|             |             |           |                   |                      |                    |                  |                               |

Notes:

1. For information STC Reference: STCP12-1: Part 3 - 2.5 Reactive Compensation Equipment
2. Data relating to continuously variable reactive compensation equipment (such as statcoms or SVCs) should be entered on the SVC Modelling table.
3. For the avoidance of doubt this includes any AC Reactive Compensation equipment included within the OTSDUW DC Converter other than harmonic filter data which is to be entered in the harmonic filter data table.

|                      |  |
|----------------------|--|
| <i>PC.A.2.4.1(e)</i> | A mathematical representation in block diagram format to model the control of any dynamic compensation plant. The model should be suitable for RMS dynamic stability type studies in which the time constants used should not be less than 10ms. |
|----------------------|--|

**SCHEDULE 18 - OFFSHORE TRANSMISSION SYSTEM DATA**  
**PAGE 8 OF 24**

**OFFSHORE TRANSMISSION SYSTEM DATA**  
 REACTIVE COMPENSATION - SVC Modelling Data (PC.A.2.4.1(e)(iii))

| HV Node | LV Node | Control Node | Normal Voltage (kV) | Target Voltage (kV) | Max MVAR at HV | Min MVAR at HV | Slope % | Voltage Dependant Q Limit | Normal Running Mode | R1 PPS_R | X1 PPS_X | R0 ZPS_R | X0 ZPS_X | Transf. Winding Type | Connection (Direct/Tertiary) |
|---------|---------|--------------|---------------------|---------------------|----------------|----------------|---------|---------------------------|---------------------|----------|----------|----------|----------|----------------------|------------------------------|
|         |         |              |                     |                     |                |                |         |                           |                     |          |          |          |          |                      |                              |

Notes:

1. For information the equivalent SVC Reference is: STCP12-1: Part 3 - 2.7 SVC Modelling Data



## SCHEDULE 18 - OFFSHORE TRANSMISSION SYSTEM DATA

PAGE 10 OF 24

### Information for Transient Overvoltage Assessment (DPD I) (PC.A.6.2 ■ CUSC Contract)

The information listed below may be requested by **NGET** from each **Existing-User** undertaking **OTSDUW** with respect to any **Interface Point** or **Connection Point** to enable **NGET** to assess transient overvoltage on the **National Electricity Transmission System**.

- (a) Busbar layout plan(s), including dimensions and geometry showing positioning of any current and voltage transformers, through bushings, support insulators, disconnectors, circuit breakers, surge arresters, etc. Electrical parameters of any associated current and voltage transformers, stray capacitances of wall bushings and support insulators, and grading capacitances of circuit breakers;
- (b) Electrical parameters and physical construction details of lines and cables connected at that busbar. Electrical parameters of all plant e.g., transformers (including neutral earthing impedance or zig-zag transformers if any), series reactors and shunt compensation equipment connected at that busbar (or to the tertiary of a transformer) or by lines or cables to that busbar;
- (c) Basic insulation levels (BIL) of all **Apparatus** connected directly, by lines or by cables to the busbar;
- (d) Characteristics of overvoltage **Protection** devices at the busbar and at the termination points of all lines, and all cables connected to the busbar;
- (e) Fault levels at the lower voltage terminals of each transformer connected to each **Interface Point** or **Connection Point** without intermediate transformation;
- (f) The following data is required on all transformers within the **OTSDUW Plant and Apparatus**.
- (g) An indication of which items of equipment may be out of service simultaneously during **Planned Outage** conditions.

### Harmonic Studies (DPD I) (PC.A.6.4 ■ CUSC Contract)

The information given below, both current and forecast, where not already supplied in this Schedule 14 may be requested by **NGET** from each **Existing-User** if it is necessary for **NGET** to evaluate the production/magnification of harmonic distortion on **National Electricity Transmission System**. The impact of any third party **Embedded** within the **Existing-User's System** should be reflected:-

- (a) Overhead lines and underground cable circuits (including subsea cables) of the **Existing-User's OTSDUW Plant and Apparatus** must be differentiated and the following data provided separately for each type:-
  - Positive phase sequence resistance
  - Positive phase sequence reactance
  - Positive phase sequence susceptance
- (b) for all transformers connecting the **OTSDUW Plant and Apparatus** to a lower voltage:-
  - Rated MVA
  - Voltage Ratio
  - Positive phase sequence resistance
  - Positive phase sequence reactance

## SCHEDULE 18 - OFFSHORE TRANSMISSION SYSTEM DATA

PAGE 11 OF 24

- (c) at the lower voltage points of those connecting transformers:-

Equivalent positive phase sequence susceptance  
Connection voltage and MVA rating of any capacitor bank and component design parameters if configured as a filter

Equivalent positive phase sequence interconnection impedance with other lower voltage points  
The minimum and maximum **Demand** (both MW and MVA) that could occur  
Harmonic current injection sources in Amps at the Connection Points and Interface Points

- (d) an indication of which items of equipment may be out of service simultaneously during **Planned Outage** conditions

### Voltage Assessment Studies (DPD I) (PC.A.6.5 ■ CUSC Contract)

The information listed below, where not already supplied in this Schedule 14, may be requested by **NGET** from each **Existing-User** undertaking **OTSDUW** with respect to any **Connection Point** or **Interface Point** if it is necessary for **NGET** to undertake detailed voltage assessment studies (eg to examine potential voltage instability, voltage control co-ordination or to calculate voltage step changes on the **National Electricity Transmission System**).

- (a) For all circuits of the **Existing-User's OTSDUW Plant and Apparatus**:-

Positive Phase Sequence Reactance  
Positive Phase Sequence Resistance  
Positive Phase Sequence Susceptance  
MVA rating of any reactive compensation equipment

- (b) for all transformers connecting the **Existing-User's OTSDUW Plant and Apparatus** to a lower voltage:-

Rated MVA  
Voltage Ratio  
Positive phase sequence resistance  
Positive Phase sequence reactance  
Tap-changer range  
Number of tap steps  
Tap-changer type: on-load or off-circuit  
AVC/tap-changer time delay to first tap movement  
AVC/tap-changer inter-tap time delay

- (c) at the lower voltage points of those connecting transformers

Equivalent positive phase sequence susceptance  
MVA rating of any reactive compensation equipment  
Equivalent positive phase sequence interconnection impedance with other lower voltage points  
The maximum **Demand** (both MW and MVA) that could occur  
Estimate of voltage insensitive (constant power) load content in % of total load at both winter peak and 75% off-peak load conditions

**SCHEDULE 18 - OFFSHORE TRANSMISSION SYSTEM DATA**  
**PAGE 12 OF 24**

Short Circuit Analyses:(DPD I) (PC.A.6.6 ■ CUSC Contract)

The information listed below, both current and forecast, and where not already supplied under this Schedule 14, may be requested by **NGET** from each **Existing-User** undertaking **OTSDUW** with respect to any **Connection Point or Interface Point** where prospective short-circuit currents on equipment owned by a **Transmission Licensee** or operated or managed by **NGET** are close to the equipment rating.

(a) For all circuits of the **Existing-User's OTSDUW Plant and Apparatus:-**

- Positive phase sequence resistance
- Positive phase sequence reactance
- Positive phase sequence susceptance
- Zero phase sequence resistance (both self and mutuals)
- Zero phase sequence reactance (both self and mutuals)
- Zero phase sequence susceptance (both self and mutuals)

(b) for all transformers connecting the **Existing-User's OTSDUW Plant and Apparatus** to a lower voltage:-

- Rated MVA
- Voltage Ratio
- Positive phase sequence resistance (at max, min and nominal tap)
- Positive Phase sequence reactance (at max, min and nominal tap)
- Zero phase sequence reactance (at nominal tap)
- Tap changer range
- Earthing method: direct, resistance or reactance
- Impedance if not directly earthed

(c) at the lower voltage points of those connecting transformers:-

The maximum **Demand** (in MW and MVA<sub>r</sub>) that could occur Short-circuit infeed data in accordance with PC.A.2.5.6(a) unless the **Existing-User's OTSDUW Plant and Apparatus** runs in parallel with the **Subtransmission System**, when to prevent double counting in each node infeed data, a  $\pi$  equivalent comprising the data items of PC.A.2.5.6(a) for each node together with the positive phase sequence interconnection impedance between the nodes shall be submitted.

**Formatted:** Numbered + Level: 1 +  
Numbering Style: a, b, c, ... + Start at: 1 +  
Alignment: Left + Aligned at: 0.63 cm +  
Indent at: 1.48 cm



**SCHEDULE 18 - OFFSHORE TRANSMISSION SYSTEM DATA**  
**PAGE 14 OF 24**

| DATA DESCRIPTION   | UNITS                                       | F.  | F.  | F.  | F.  | F.  | F.  | F.  | F.  | F.  | DATA to |                          |                                     |
|--|---|-----|-----|-----|-----|-----|-----|-----|-----|-----|---------|--------------------------|-------------------------------------|
|  |   | Yr. | Yr. | Yr. | Yr. | Yr. | Yr. | Yr. | Yr. | Yr. | RTL     |                          |                                     |
|  |   | 0   | 1   | 2   | 3   | 4   | 5   | 6   | 7   |     |         | CUSC Contract            | CUSC App. Form                      |
| - A continuous time trace and table showing the root mean square of the positive, negative and zero sequence components of the fault current from the time of fault inception to 140ms after fault inception at 10ms intervals | Graphical and tabular<br><br>kA<br>versus s |     |     |     |     |     |     |     |     |     |         | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| - A continuous time trace and table showing the positive, negative and zero sequence components of retained voltage at the <b>Interface Point</b> and each <b>Connection Point</b> , if appropriate                            | p.u. versus s                               |     |     |     |     |     |     |     |     |     |         | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| - A continuous time trace and table showing the root mean square of the positive, negative and zero sequence components of retained voltage at the fault point, if appropriate   | p.u. versus s                               |     |     |     |     |     |     |     |     |     |         | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| Positive sequence X/R ratio of the equivalent at time of fault at the <b>Interface Point</b> and each <b>Connection Point</b>  |   |     |     |     |     |     |     |     |     |     |         | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| Minimum zero sequence impedance of the equivalent at the <b>Interface Point</b> and each <b>Connection Point</b>   |   |     |     |     |     |     |     |     |     |     |         | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| <b>Active Power</b> transfer at the Interface Point and each Connection Point pre-fault  | MW  |     |     |     |     |     |     |     |     |     |         | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| Power Factor (lead or lag)   |   |     |     |     |     |     |     |     |     |     |         | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| Pre-fault voltage (if different from 1.0 p.u.) at fault point (See note 1)   | p.u.  |     |     |     |     |     |     |     |     |     |         | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| Items of reactive compensation switched in pre-fault   |   |     |     |     |     |     |     |     |     |     |         | <input type="checkbox"/> | <input checked="" type="checkbox"/> |

Note 1. The pre-fault voltage provided above should represent the voltage within the range 0.95 to 1.05 that gives the highest fault current



**SCHEDULE 18 - OFFSHORE TRANSMISSION SYSTEM DATA**  
**PAGE 15 OF 24**

Thermal Ratings Data (PC.A.2.2.4)

|                         |
|-------------------------|
|                         |
| <b>Voltage</b><br>132kV |

**CIRCUIT RATING SCHEDULE**

|                         |                   |
|-------------------------|-------------------|
|                         |                   |
| <b>Offshore TO Name</b> | <b>Issue Date</b> |

**CIRCUIT Name from Site A – Site B**

| OVERALL CCT RATINGS   | Winter |       |      |      | Spring/Autumn |       |      |      | Summer |       |      |     |     |
|---|--------|-------|------|------|---------------|-------|------|------|--------|-------|------|-----|-----|
|   | %Nom   | Limit | Amps | MVA  | %Nom          | Limit | Amps | MVA  | %Nom   | Limit | Amps | MVA |     |
| Pre-Fault Continuous  | 84%    | Line  | 485  | 111  | 84%           | Line  | 450  | 103  | 84%    | Line  | 390  | 89  |     |
| Post-Fault Continuous   | 100%   | Line  | 580  | 132  | 100%          | Line  | 540  | 123  | 100%   | Line  | 465  | 106 |     |
| Prefault load exceeds line prefault continuous rating                               | 6hr    | 95%   | Line | 580  | 132           | 95%   | Line | 540  | 123    | 95%   | Line | 465 | 106 |
|   | 20m    |       | Line | 580  | 132           |       | Line | 540  | 123    |       | Line | 465 | 106 |
|   | 10m    | mva   | Line | 580  | 132           | mva   | Line | 540  | 123    | mva   | Line | 465 | 106 |
|   | 5m     | 125   | Line | 580  | 132           | 116   | Line | 540  | 123    | 100   | Line | 465 | 106 |
| Short Term Overloads  | 3m     |       | Line | 580  | 132           |       | Line | 540  | 123    |       | Line | 465 | 106 |
|   | 6hr    | 90%   | Line | 580  | 132           | 90%   | Line | 540  | 123    | 90%   | Line | 465 | 106 |
|   | 20m    |       | Line | 580  | 132           |       | Line | 540  | 123    |       | Line | 465 | 106 |
|   | 10m    | mva   | Line | 580  | 132           | mva   | Line | 540  | 123    | mva   | Line | 465 | 106 |
| Limiting Item and permitted overload values for different times and pre-fault loads | 5m     | 118   | Line | 580  | 132           | 110   | Line | 540  | 123    | 95    | Line | 465 | 106 |
|   | 3m     |       | Line | 580  | 132           |       | Line | 540  | 123    |       | Line | 465 | 106 |
|   | 6hr    | 84%   | Line | 580  | 132           | 84%   | Line | 540  | 123    | 84%   | Line | 465 | 106 |
|   | 20m    |       | Line | 590  | 135           |       | Line | 545  | 125    |       | Line | 470 | 108 |
| Limiting Item and permitted overload values for different times and pre-fault loads | 10m    | mva   | Line | 630  | 144           | mva   | Line | 580  | 133    | mva   | Line | 495 | 113 |
|   | 5m     | 110   | Line | 710  | 163           | 103   | Line | 655  | 149    | 89    | Line | 555 | 126 |
|   | 3m     |       | Line | 810  | 185           |       | Line | 740  | 170    |       | Line | 625 | 143 |
|   | 6hr    | 75%   | Line | 580  | 132           | 75%   | Line | 540  | 123    | 75%   | Line | 465 | 106 |
| Limiting Item and permitted overload values for different times and pre-fault loads | 20m    |       | Line | 595  | 136           |       | Line | 555  | 126    |       | Line | 475 | 109 |
|   | 10m    | mva   | Line | 650  | 149           | mva   | Line | 600  | 137    | mva   | Line | 510 | 116 |
|   | 5m     | 99    | Line | 760  | 173           | 92    | Line | 695  | 159    | 79    | Line | 585 | 134 |
|   | 3m     |       | Line | 885  | 203           |       | Line | 810  | 185    |       | Line | 685 | 156 |
| Limiting Item and permitted overload values for different times and pre-fault loads | 6hr    | 60%   | Line | 580  | 132           | 60%   | Line | 540  | 123    | 60%   | Line | 465 | 106 |
|   | 20m    |       | Line | 605  | 138           |       | Line | 560  | 128    |       | Line | 480 | 110 |
|   | 10m    | mva   | Line | 675  | 155           | mva   | Line | 620  | 142    | mva   | Line | 530 | 121 |
|   | 5m     | 79    | Line | 820  | 187           | 73    | Line | 750  | 172    | 63    | Line | 635 | 145 |
| Limiting Item and permitted overload values for different times and pre-fault loads | 3m     |       | Line | 985  | 226           |       | Line | 900  | 206    |       | Line | 755 | 173 |
|   | 6hr    | 30%   | Line | 580  | 132           | 30%   | Line | 540  | 123    | 30%   | Line | 465 | 106 |
|   | 20m    |       | Line | 615  | 141           |       | Line | 570  | 130    |       | Line | 490 | 112 |
|   | 10m    | mva   | Line | 710  | 163           | mva   | Line | 655  | 150    | mva   | Line | 555 | 127 |
| Limiting Item and permitted overload values for different times and pre-fault loads | 5m     | 39    | Line | 895  | 205           | 36    | Line | 820  | 187    | 31    | Line | 690 | 158 |
|   | 3m     |       | Line | 1110 | 255           |       | Line | 1010 | 230    |       | Line | 845 | 193 |

**SCHEDULE 18 - OFFSHORE TRANSMISSION SYSTEM DATA**  
**PAGE 16 OF 24**

|                                |     |  |  |  |  |  |  |  |  |  |  |  |
|--------------------------------|-----|--|--|--|--|--|--|--|--|--|--|--|
|                                | 6hr |  |  |  |  |  |  |  |  |  |  |  |
|                                | 20m |  |  |  |  |  |  |  |  |  |  |  |
|                                | 10m |  |  |  |  |  |  |  |  |  |  |  |
|                                | 5m  |  |  |  |  |  |  |  |  |  |  |  |
|                                | 3m  |  |  |  |  |  |  |  |  |  |  |  |
|                                | 6hr |  |  |  |  |  |  |  |  |  |  |  |
|                                | 20m |  |  |  |  |  |  |  |  |  |  |  |
|                                | 10m |  |  |  |  |  |  |  |  |  |  |  |
| 5m                             |     |  |  |  |  |  |  |  |  |  |  |  |
| 3m                             |     |  |  |  |  |  |  |  |  |  |  |  |
| Notes or Restrictions Detailed |     |  |  |  |  |  |  |  |  |  |  |  |

Notes: 1. For information the equivalent STC Reference: STCP12-1: Part 3 - 2.6 Thermal Ratings  
2. The values shown in the above table is example data.

**SCHEDULE 18 - OFFSHORE TRANSMISSION SYSTEM DATA**  
**PAGE 17 OF 24**

**Protection Policy** (PC.A.6.3)

To include details of the protection policy

**Protection Schedules**(PC.A.6.3)

Data schedules for the protection systems associated with each primary plant item including:

Protection, Intertrip Signalling & operating times  
Intertripping and protection unstabilisation initiation  
Synchronising facilities  
Delayed Auto Reclose sequence schedules

**Automatic Switching Scheme Schedules** (PC.A.2.2.7)

A diagram of the scheme and an explanation of how the system will operate and what plant will be affected by the scheme's operation.

**SCHEDULE 18 - OFFSHORE TRANSMISSION SYSTEM DATA**  
**PAGE 18 OF 24**

**GENERATOR INTERTRIP SCHEMES** (PC.A.2.2.7(b))

Substation: \_\_\_\_\_

Details of Generator Intertrip Schemes:

A diagram of the scheme and an explanation of how the system will operate and what plant will be effected by the schemes operation.

**DEMAND INTERTRIP SCHEMES** (PC.A.2.2.7(b))

Substation: \_\_\_\_\_

Details of Demand Intertrip Schemes:

A diagram of the scheme and an explanation of how the system will operate and what plant will be effected by the schemes operation

**SCHEDULE 18 - OFFSHORE TRANSMISSION SYSTEM DATA**  
**PAGE 19 OF 24**

*Specific Operating Requirements (CC.5.2.1)*

SUBSTATION OPERATIONAL GUIDE

**Substation:** \_\_\_\_\_

**Location Details:**

| <b>Postal Address:</b>         | <b>Telephone Nos.</b> | <b>Map Ref.</b> |
|--------------------------------|-----------------------|-----------------|
|                                |                       |                 |
| <b>National Grid Interface</b> |                       |                 |
|                                |                       |                 |
| <b>Generator Interface</b>     |                       |                 |
|                                |                       |                 |

- 1. Substation Type:**
  
- 2. Voltage Control:** *(short description of voltage control system. To include mention of modes ie Voltage, manual etc. Plus control step increments ie 0.5%-0.33kV?)*
  
- 3. Energisation Switching Information:** *(The standard energisation switching process from dead.)*
  
- 4. Intertrip Systems:**
  
- 5. Reactive Plant Outage:** *(A short explanation of any system re-configurations required to facilitate the outage of any reactive plant which form part of the OTSDUW Plant and Apparatus equipment. Also any generation restrictions required).*
  
- 6. Harmonic Filter Outage:** *(An explanation as to any OTSDUW Plant and Apparatus reconfigurations required to facilitate the outage and maintain the system within specified Harmonic limits, also any generation restrictions required).*

**SCHEDULE 18 - OFFSHORE TRANSMISSION SYSTEM DATA**  
**PAGE 20 OF 24**

**OTSDUW DC CONVERTER TECHNICAL DATA**

**OTSDUW DC CONVERTER NAME**

**DATE:** \_\_\_\_\_

| Data Description   | Units     | DATA to                  |                                     | Data Category    | DC Converter Station Data |
|--|-----------|--------------------------|-------------------------------------|------------------|---------------------------|
|  |           | RTL                      |                                     |                  |                           |
| <i>(PC.A.4 and PC.A.5.2.5)</i>   |           |                          |                                     |                  |                           |
|  |           | CUSC Contract            | CUSC App-Form                       |                  |                           |
| <b>OTSDUW DC CONVERTER (CONVERTER DEMANDS):</b>  |           |                          |                                     |                  |                           |
| <b>Demand</b> supplied through <b>Station Transformers</b> associated with the <b>OTSDUW DC Converter</b> at each <b>Interface Point</b> and each <b>Offshore Connection Point Grid Entry Point [PC.A.4.1]</b> |           |                          |                                     |                  |                           |
| - <b>Demand</b> with all <b>OTSDUW DC Converters</b> operating at <b>Interface Point Capacity</b> .  | MW<br>MVA | <input type="checkbox"/> | <input type="checkbox"/>            | DPD II<br>DPD II |                           |
| - <b>Demand</b> with all <b>OTSDUW DC Converters</b> operating at maximum <b>Interface Point</b> flow from the <b>Interface Point</b> to each <b>Offshore Grid Entry Point</b> .                               | MW<br>MVA | <input type="checkbox"/> | <input type="checkbox"/>            | DPD II<br>DPD II |                           |
| - The maximum <b>Demand</b> that could occur.  | MW<br>MVA | <input type="checkbox"/> | <input type="checkbox"/>            | DPD II<br>DPD II |                           |
| - <b>Demand</b> at specified time of annual peak half hour of <b>NGET Demand</b> at <b>Annual ACS Conditions</b> .   | MW<br>MVA | <input type="checkbox"/> | <input type="checkbox"/>            | DPD II<br>DPD II |                           |
| - <b>Demand</b> at specified time of annual minimum half-hour of <b>NGET Demand</b> .  | MW<br>MVA | <input type="checkbox"/> | <input type="checkbox"/>            | DPD II           |                           |
| <b>OTSDUW DC CONVERTER DATA</b>  | Text      | <input type="checkbox"/> | <input checked="" type="checkbox"/> | SPD+             |                           |
| Number of poles, i.e. number of <b>OTSDUW DC Converters</b>  | Text      | <input type="checkbox"/> | <input checked="" type="checkbox"/> | SPD+             |                           |
| Pole arrangement (e.g. monopole or bipole)   | Diagram   | <input type="checkbox"/> |                                     |                  |                           |
| Return path arrangement  |           |                          |                                     |                  |                           |
| Details of each viable operating configuration   |           |                          |                                     |                  |                           |
| Configuration 1  | Diagram   | <input type="checkbox"/> | <input checked="" type="checkbox"/> | SPD+             |                           |
| Configuration 2  | Diagram   | <input type="checkbox"/> | <input checked="" type="checkbox"/> |                  |                           |
| Configuration 3  | Diagram   | <input type="checkbox"/> | <input checked="" type="checkbox"/> |                  |                           |
| Configuration 4  | Diagram   | <input type="checkbox"/> | <input checked="" type="checkbox"/> |                  |                           |
| Configuration 5  | Diagram   | <input type="checkbox"/> | <input checked="" type="checkbox"/> |                  |                           |
| Configuration 6  | Diagram   | <input type="checkbox"/> | <input checked="" type="checkbox"/> |                  |                           |

Formatted: Left

**SCHEDULE 18 - OFFSHORE TRANSMISSION SYSTEM DATA**  
**PAGE 21 OF 24**

| Data Description  | Units          | DATA to RTL  |  | Data Category | Operating Configuration |   |   |   |   |   |
|---|----------------|--|--|---------------|-------------------------|---|---|---|---|---|
|   |                | CUSC Contract  | CUSC App. Form   |               | 1                       | 2 | 3 | 4 | 5 | 6 |
| <b>OTSDUW DC CONVERTER DATA</b><br>(PC.A.3.3.1(d))  |                |  |  |               |                         |   |   |   |   |   |
| OTSDUW DC Converter Type (e.g. current or Voltage source)   | Text           | <input type="checkbox"/>                             | <input checked="" type="checkbox"/>  | SPD           |                         |   |   |   |   |   |
| If the busbars at the <b>Interface Point</b> or <b>Connection Point</b> are normally run in separate sections identify the section to which the <b>OTSDUW DC Converter</b> configuration is connected | Section Number | <input type="checkbox"/>                             | <input checked="" type="checkbox"/>  | SPD           |                         |   |   |   |   |   |
|   | MW             | <input type="checkbox"/>                             | <input checked="" type="checkbox"/>  | SPD+          |                         |   |   |   |   |   |
| <b>Rated MW</b> import per pole (PC.A.3.3.1)  | MW             | <input type="checkbox"/>                             | <input checked="" type="checkbox"/>  | SPD+          |                         |   |   |   |   |   |
| <b>Rated MW</b> export per pole (PC.A.3.3.1)  | MW             | <input type="checkbox"/>                             | <input checked="" type="checkbox"/>  | SPD+          |                         |   |   |   |   |   |
| <b>ACTIVE POWER TRANSFER CAPABILITY</b><br>(PC.A.3.2.2)   |                |  |  |               |                         |   |   |   |   |   |
| <b>Interface Point Capacity</b>   | MW<br>MVA      | <input type="checkbox"/><br><input type="checkbox"/> | <input checked="" type="checkbox"/><br><input checked="" type="checkbox"/> | SPD<br>SPD    |                         |   |   |   |   |   |
| <b>OTSDUW DC CONVERTER TRANSFORMER</b><br>(PC.A.5.4.3.1)  |                |  |  |               |                         |   |   |   |   |   |
| Rated MVA   | MVA            | <input type="checkbox"/>                             |  | DPD II        |                         |   |   |   |   |   |
| Winding arrangement   | kV             | <input type="checkbox"/>                             |  | DPD II        |                         |   |   |   |   |   |
| Nominal primary voltage   | kV             | <input type="checkbox"/>                             |  | DPD II        |                         |   |   |   |   |   |
| Nominal secondary (converter-side) voltage(s)   | kV             | <input type="checkbox"/>                             |  | DPD II        |                         |   |   |   |   |   |
| Positive sequence reactance   |                | <input type="checkbox"/>                             |  |               |                         |   |   |   |   |   |
| Maximum tap   | % on           | <input type="checkbox"/>                             |  | DPD II        |                         |   |   |   |   |   |
| Nominal tap   | MVA            | <input type="checkbox"/>                             |  | DPD II        |                         |   |   |   |   |   |
| Minimum tap   | % on           | <input type="checkbox"/>                             |  | DPD II        |                         |   |   |   |   |   |
| Positive sequence resistance  | MVA            | <input type="checkbox"/>                             |  | DPD II        |                         |   |   |   |   |   |
| Maximum tap   | % on           | <input type="checkbox"/>                             |  | DPD II        |                         |   |   |   |   |   |
| Nominal tap   | MVA            | <input type="checkbox"/>                             |  | DPD II        |                         |   |   |   |   |   |
| Minimum tap   | % on           | <input type="checkbox"/>                             |  | DPD II        |                         |   |   |   |   |   |
| Zero phase sequence reactance   | MVA            | <input type="checkbox"/>                             |  | DPD II        |                         |   |   |   |   |   |
| Tap change range  | % on           | <input type="checkbox"/>                             |  | DPD II        |                         |   |   |   |   |   |
| Number of steps   | MVA            | <input type="checkbox"/>                             |  | DPD II        |                         |   |   |   |   |   |
|   | % on           |  |  | DPD II        |                         |   |   |   |   |   |
|   | MVA            |  |  | DPD II        |                         |   |   |   |   |   |
|   | % on           |  |  | DPD II        |                         |   |   |   |   |   |
|   | MVA            |  |  | DPD II        |                         |   |   |   |   |   |
|   | % on           |  |  | DPD II        |                         |   |   |   |   |   |
|   | MVA            |  |  | DPD II        |                         |   |   |   |   |   |
|   | % on           |  |  | DPD II        |                         |   |   |   |   |   |
|   | MVA            |  |  | DPD II        |                         |   |   |   |   |   |
|   | % on           |  |  | DPD II        |                         |   |   |   |   |   |
|   | MVA            |  |  | DPD II        |                         |   |   |   |   |   |
|   | % on           |  |  | DPD II        |                         |   |   |   |   |   |
|   | MVA            |  |  | DPD II        |                         |   |   |   |   |   |
|   | % on           |  |  | DPD II        |                         |   |   |   |   |   |
|   | MVA            |  |  | DPD II        |                         |   |   |   |   |   |
|   | % on           |  |  | DPD II        |                         |   |   |   |   |   |
|   | MVA            |  |  | DPD II        |                         |   |   |   |   |   |
|   | % on           |  |  | DPD II        |                         |   |   |   |   |   |
|   | MVA            |  |  | DPD II        |                         |   |   |   |   |   |
|   | % on           |  |  | DPD II        |                         |   |   |   |   |   |
|   | MVA            |  |  | DPD II        |                         |   |   |   |   |   |
|   | % on           |  |  | DPD II        |                         |   |   |   |   |   |
|   | MVA            |  |  | DPD II        |                         |   |   |   |   |   |
|   | % on           |  |  | DPD II        |                         |   |   |   |   |   |
|   | MVA            |  |  | DPD II        |                         |   |   |   |   |   |
|   | % on           |  |  | DPD II        |                         |   |   |   |   |   |
|   | MVA            |  |  | DPD II        |                         |   |   |   |   |   |
|   | % on           |  |  | DPD II        |                         |   |   |   |   |   |
|   | MVA            |  |  | DPD II        |                         |   |   |   |   |   |
|   | % on           |  |  | DPD II        |                         |   |   |   |   |   |
|   | MVA            |  |  | DPD II        |                         |   |   |   |   |   |
|   | % on           |  |  | DPD II        |                         |   |   |   |   |   |
|   | MVA            |  |  | DPD II        |                         |   |   |   |   |   |
|   | % on           |  |  | DPD II        |                         |   |   |   |   |   |
|   | MVA            |  |  | DPD II        |                         |   |   |   |   |   |
|   | % on           |  |  | DPD II        |                         |   |   |   |   |   |
|   | MVA            |  |  | DPD II        |                         |   |   |   |   |   |
|   | % on           |  |  | DPD II        |                         |   |   |   |   |   |
|   | MVA            |  |  | DPD II        |                         |   |   |   |   |   |
|   | % on           |  |  | DPD II        |                         |   |   |   |   |   |
|   | MVA            |  |  | DPD II        |                         |   |   |   |   |   |
|   | % on           |  |  | DPD II        |                         |   |   |   |   |   |
|   | MVA            |  |  | DPD II        |                         |   |   |   |   |   |
|   | % on           |  |  | DPD II        |                         |   |   |   |   |   |
|   | MVA            |  |  | DPD II        |                         |   |   |   |   |   |
|   | % on           |  |  | DPD II        |                         |   |   |   |   |   |
|   | MVA            |  |  | DPD II        |                         |   |   |   |   |   |
|   | % on           |  |  | DPD II        |                         |   |   |   |   |   |
|   | MVA            |  |  | DPD II        |                         |   |   |   |   |   |
|   | % on           |  |  | DPD II        |                         |   |   |   |   |   |
|   | MVA            |  |  | DPD II        |                         |   |   |   |   |   |
|   | % on           |  |  | DPD II        |                         |   |   |   |   |   |
|   | MVA            |  |  | DPD II        |                         |   |   |   |   |   |
|   | % on           |  |  | DPD II        |                         |   |   |   |   |   |
|   | MVA            |  |  | DPD II        |                         |   |   |   |   |   |
|   | % on           |  |  | DPD II        |                         |   |   |   |   |   |
|   | MVA            |  |  | DPD II        |                         |   |   |   |   |   |
|   | % on           |  |  | DPD II        |                         |   |   |   |   |   |
|   | MVA            |  |  | DPD II        |                         |   |   |   |   |   |
|   | % on           |  |  | DPD II        |                         |   |   |   |   |   |
|   | MVA            |  |  | DPD II        |                         |   |   |   |   |   |
|   | % on           |  |  | DPD II        |                         |   |   |   |   |   |
|   | MVA            |  |  | DPD II        |                         |   |   |   |   |   |
|   | % on           |  |  | DPD II        |                         |   |   |   |   |   |
|   | MVA            |  |  | DPD II        |                         |   |   |   |   |   |
|   | % on           |  |  | DPD II        |                         |   |   |   |   |   |
|   | MVA            |  |  | DPD II        |                         |   |   |   |   |   |
|   | % on           |  |  | DPD II        |                         |   |   |   |   |   |
|   | MVA            |  |  | DPD II        |                         |   |   |   |   |   |
|   | % on           |  |  | DPD II        |                         |   |   |   |   |   |
|   | MVA            |  |  | DPD II        |                         |   |   |   |   |   |
|   | % on           |  |  | DPD II        |                         |   |   |   |   |   |
|   | MVA            |  |  | DPD II        |                         |   |   |   |   |   |
|   | % on           |  |  | DPD II        |                         |   |   |   |   |   |
|   | MVA            |  |  | DPD II        |                         |   |   |   |   |   |
|   | % on           |  |  | DPD II        |                         |   |   |   |   |   |
|   | MVA            |  |  | DPD II        |                         |   |   |   |   |   |
|   | % on           |  |  | DPD II        |                         |   |   |   |   |   |
|   | MVA            |  |  | DPD II        |                         |   |   |   |   |   |
|   | % on           |  |  | DPD II        |                         |   |   |   |   |   |
|   | MVA            |  |  | DPD II        |                         |   |   |   |   |   |
|   | % on           |  |  | DPD II        |                         |   |   |   |   |   |
|   | MVA            |  |  | DPD II        |                         |   |   |   |   |   |
|   | % on           |  |  | DPD II        |                         |   |   |   |   |   |
|   | MVA            |  |  | DPD II        |                         |   |   |   |   |   |
|   | % on           |  |  | DPD II        |                         |   |   |   |   |   |
|   | MVA            |  |  | DPD II        |                         |   |   |   |   |   |
|   | % on           |  |  | DPD II        |                         |   |   |   |   |   |
|   | MVA            |  |  | DPD II        |                         |   |   |   |   |   |
|   | % on           |  |  | DPD II        |                         |   |   |   |   |   |
|   | MVA            |  |  | DPD II        |                         |   |   |   |   |   |
|   | % on           |  |  | DPD II        |                         |   |   |   |   |   |
|   | MVA            |  |  | DPD II        |                         |   |   |   |   |   |
|   | % on           |  |  | DPD II        |                         |   |   |   |   |   |
|   | MVA            |  |  | DPD II        |                         |   |   |   |   |   |
|   | % on           |  |  | DPD II        |                         |   |   |   |   |   |
|   | MVA            |  |  | DPD II        |                         |   |   |   |   |   |
|   | % on           |  |  | DPD II        |                         |   |   |   |   |   |
|   | MVA            |  |  | DPD II        |                         |   |   |   |   |   |
|   | % on           |  |  | DPD II        |                         |   |   |   |   |   |
|   | MVA            |  |  | DPD II        |                         |   |   |   |   |   |
|   | % on           |  |  | DPD II        |                         |   |   |   |   |   |
|   | MVA            |  |  | DPD II        |                         |   |   |   |   |   |
|   | % on           |  |  | DPD II        |                         |   |   |   |   |   |
|   | MVA            |  |  | DPD II        |                         |   |   |   |   |   |
|   | % on           |  |  | DPD II        |                         |   |   |   |   |   |
|   | MVA            |  |  | DPD II        |                         |   |   |   |   |   |
|   | % on           |  |  | DPD II        |                         |   |   |   |   |   |
|   | MVA            |  |  | DPD II        |                         |   |   |   |   |   |
|   | % on           |  |  | DPD II        |                         |   |   |   |   |   |
|   | MVA            |  |  | DPD II        |                         |   |   |   |   |   |
|   | % on           |  |  | DPD II        |                         |   |   |   |   |   |
|   | MVA            |  |  | DPD II        |                         |   |   |   |   |   |
|   | % on           |  |  | DPD II        |                         |   |   |   |   |   |
|   | MVA            |  |  | DPD II        |                         |   |   |   |   |   |
|   | % on           |  |  | DPD II        |                         |   |   |   |   |   |
|   | MVA            |  |  | DPD II        |                         |   |   |   |   |   |
|   | % on           |  |  | DPD II        |                         |   |   |   |   |   |
|   | MVA            |  |  | DPD II        |                         |   |   |   |   |   |
|   | % on           |  |  | DPD II        |                         |   |   |   |   |   |
|   | MVA            |  |  | DPD II        |                         |   |   |   |   |   |
|   | % on           |  |  | DPD II        |                         |   |   |   |   |   |
|   | MVA            |  |  | DPD II        |                         |   |   |   |   |   |
|   | % on           |  |  | DPD II        |                         |   |   |   |   |   |
|   | MVA            |  |  | DPD II        |                         |   |   |   |   |   |
|   | % on           |  |  | DPD II        |                         |   |   |   |   |   |
|   | MVA            |  |  | DPD II        |                         |   |   |   |   |   |
|   | % on           |  |  | DPD II        |                         |   |   |   |   |   |
|   | MVA            |  |  | DPD II        |                         |   |   |   |   |   |
|   | % on           |  |  | DPD II        |                         |   |   |   |   |   |
|   | MVA            |  |  | DPD II        |                         |   |   |   |   |   |
|   | % on           |  |  | DPD II        |                         |   |   |   |   |   |
|   | MVA            |  |  | DPD II        |                         |   |   |   |   |   |
|   | % on           |  |  | DPD II        |                         |   |   |   |   |   |
|   | MVA            |  |  | DPD II        |                         |   |   |   |   |   |
|   | % on           |  |  | DPD II        |                         |   |   |   |   |   |
|   | MVA            |  |  | DPD II        |                         |   |   |   |   |   |
|   | % on           |  |  | DPD II        |                         |   |   |   |   |   |
|   | MVA            |  |  | DPD II        |                         |   |   |   |   |   |
|   | % on           |  |  | DPD II        |                         |   |   |   |   |   |
|   | MVA            |  |  | DPD II        |                         |   |   |   |   |   |
|   | % on           |  |  | DPD II        |                         |   |   |   |   |   |
|   | MVA            |  |  | DPD II        |                         |   |   |   |   |   |
|   | % on           |  |  | DPD II        |                         |   |   |   |   |   |
|   | MVA            |  |  | DPD II        |                         |   |   |   |   |   |
|   | % on           |  |  | DPD II        |                         |   |   |   |   |   |
|   | MVA            |  |  | DPD II        |                         |   |   |   |   |   |
|   | % on           |  |  | DPD II        |                         |   |   |   |   |   |
|   | MVA            |  |  | DPD II        |                         |   |   |   |   |   |
|   | % on           |  |  | DPD II        |                         |   |   |   |   |   |
|   | MVA            |  |  | DPD II        |                         |   |   |   |   |   |
|   | % on           |  |  |               |                         |   |   |   |   |   |

**SCHEDULE 18 - OFFSHORE TRANSMISSION SYSTEM DATA**  
**PAGE 22 OF 24**

| Data Description  | Units                  | DATA to RTL  |                | Data Category                  | Operating configuration |   |   |   |   |   |  |
|---|------------------------|--|----------------|--------------------------------|-------------------------|---|---|---|---|---|--|
|   |                        | CUSC Contract  | CUSC App. Form |                                | 1                       | 2 | 3 | 4 | 5 | 6 |  |
| <b>OTSDUW DC CONVERTER NETWORK DATA</b><br>(PC.A.5.4.3.1 (c))<br><br>Rated DC voltage per pole<br>Rated DC current per pole<br><br>Details of the <b>OTSDUW DC Network</b> described in diagram form including resistance, inductance and capacitance of all DC cables and/or DC lines. Details of any line reactors (including line reactor resistance), line capacitors, DC filters, earthing electrodes and other conductors that form part of the <b>OTSDUW DC Network</b> should be shown. | kV<br>A<br><br>Diagram | <input type="checkbox"/><br><input type="checkbox"/><br><br><input type="checkbox"/> |                | DPD II<br>DPD II<br><br>DPD II |                         |   |   |   |   |   |  |



**SCHEDULE 18 - OFFSHORE TRANSMISSION SYSTEM DATA**  
**PAGE 23 OF 24**

| Data Description   | Units   | DATA to       |                | Data Category | Operating configuration |   |   |   |   |   |  |
|--|---------|---------------|----------------|---------------|-------------------------|---|---|---|---|---|--|
|  |         | RTL           |                |               | 1                       | 2 | 3 | 4 | 5 | 6 |  |
|  |         | CUSC Contract | CUSC App. Form |               |                         |   |   |   |   |   |  |
| <b>OTSDUW DC CONVERTER CONTROL SYSTEMS</b><br>(PC.A.5.4.3.2)   |         |               |                |               |                         |   |   |   |   |   |  |
| Static $V_{DC} - P_{DC}$ (DC voltage – DC power) or<br>Static $V_{DC} - I_{DC}$ (DC voltage – DC current)<br>characteristic (as appropriate) when<br>operating as<br>–Rectifier<br>–Inverter   | Diagram |               |                | DPD II        |                         |   |   |   |   |   |  |
|  | Diagram |               |                | DPD II        |                         |   |   |   |   |   |  |
| Details of rectifier mode control system,<br>in block diagram form together with<br>parameters showing transfer functions of<br>individual elements.   | Diagram |               |                | DPD II        |                         |   |   |   |   |   |  |
|  | Diagram |               |                | DPD II        |                         |   |   |   |   |   |  |
| Details of inverter mode control system,<br>in block diagram form showing transfer<br>functions of individual elements including<br>parameters (as applicable).  | Diagram |               |                | DPD II        |                         |   |   |   |   |   |  |
|  | Diagram |               |                | DPD II        |                         |   |   |   |   |   |  |
| Details of <b>OTSDUW DC Converter</b><br>transformer tap changer control system in<br>block diagram form showing transfer<br>functions of individual elements including<br>parameters.   | Diagram |               |                | DPD II        |                         |   |   |   |   |   |  |
|  | Diagram |               |                | DPD II        |                         |   |   |   |   |   |  |
| Details of AC filter control systems in block<br>diagram form showing transfer functions of<br>individual elements including parameters  | Diagram |               |                | DPD II        |                         |   |   |   |   |   |  |
|  | Diagram |               |                | DPD II        |                         |   |   |   |   |   |  |
| Details of any frequency and/or load control<br>systems in block diagram form showing<br>transfer functions of individual elements<br>including parameters.  | Diagram |               |                | DPD II        |                         |   |   |   |   |   |  |
|  | Diagram |               |                | DPD II        |                         |   |   |   |   |   |  |
| Details of any large or small signal<br>modulating controls, such as power<br>oscillation damping controls or sub-<br>synchronous oscillation damping<br>controls, that have not been submitted as<br>part of the above control system data. | Diagram |               |                | DPD II        |                         |   |   |   |   |   |  |
|  | Diagram |               |                | DPD II        |                         |   |   |   |   |   |  |
| Transfer block diagram representation of the<br>reactive power control at converter ends for a<br>voltage source converter.  |         |               |                |               |                         |   |   |   |   |   |  |

**SCHEDULE 18 - OFFSHORE TRANSMISSION SYSTEM DATA**  
**PAGE 24 OF 24**

| Data Description  | Units        | DATA to       |                | Data Category                  | Operating configuration |   |   |   |   |   |   |
|---|--------------|---------------|----------------|--------------------------------|-------------------------|---|---|---|---|---|---|
|   |              | CUSC Contract | CUSC App. Form |                                | RTL                     | 1 | 2 | 3 | 4 | 5 | 6 |
| <b>LOADING PARAMETERS (PC.A.5.4.3.3)</b>  |              |               |                |                                |                         |   |   |   |   |   |   |
| MW Export from the <b>Offshore Grid Entry Point to the Transmission Interface Point</b><br>Nominal loading rate<br>Maximum (emergency) loading rate | MW/s<br>MW/s |               |                |                                |                         |   |   |   |   |   |   |
| Maximum recovery time, to 90% of pre-fault loading, following an AC system fault or severe voltage depression.                                      | s            | □             |                | <b>DPD I</b><br><b>DPD I</b>   |                         |   |   |   |   |   |   |
| Maximum recovery time, to 90% of pre-fault loading, following a transient DC Network fault.   | s            | □             |                | <b>DPD II</b><br><b>DPD II</b> |                         |   |   |   |   |   |   |

## SCHEDULE 19 – EXISTING USER DATA FILE STRUCTURE

PAGE 1 OF 2

The structure of the **User Data File Structure** is given below.

| i.d.   | Folder name                  | Description of contents  |
|--|------------------------------|--|
| <b>Part A: Commercial &amp; Legal</b>        |                              |  |
| <b>A2</b>                                    | Commissioning                | Commissioning & Test Programmes                                |
| <b>A3</b>                                    | Statements                   | Statements of Readiness  |
| <b>A9</b>                                    | AS Monitoring                | Ancillary Services Monitoring                                  |
| <b>A10</b>                                   | Self Certification           | User Self Certification of Compliance                          |
| <b>A11</b>                                   | Compliance statements        | Compliance Statement   |
| <b>Part 1: Safety &amp; System Operation</b> |                              |  |
| <b>1.1</b>                                   | Interface Agreements         | Interface Agreements   |
| <b>1.2</b>                                   | Safety Rules                 | Safety Rules   |
| <b>1.3</b>                                   | Switching Procedures         | Local Switching Procedures                                     |
| <b>1.4</b>                                   | Earthing                     | Earthing   |
| <b>1.5</b>                                   | SRS                          | Site Responsibility Schedules                                  |
| <b>1.6</b>                                   | Diagrams                     | Operational and Gas Zone Diagrams                              |
| <b>1.7</b>                                   | Drawings                     | Site Common Drawings   |
| <b>1.8</b>                                   | Telephony                    | Control Telephony  |
| <b>1.9</b>                                   | Safety Procedures            | Local Safety Procedures  |
| <b>1.10</b>                                  | Co-ordinators                | Safety Co-ordinators   |
| <b>1.11</b>                                  | RISSP                        | Record of Inter System Safety Precautions                      |
| <b>1.12</b>                                  | Tel Numbers                  | Telephone Numbers for Joint System Incidents                   |
| <b>1.13</b>                                  | Contact Details              | Contact Details (fax, tel, email)                              |
| <b>1.14</b>                                  | Restoration Plan             | Local Joint Restoration Plan (incl. black start if applicable) |
| <b>1.15</b>                                  | Maintenance                  | Maintenance Standards  |
| <b>Part 2: Connection Technical Data</b>     |                              |  |
| <b>2.1</b>                                   | DRC Schedule 5               | DRC Schedule 5 – Users System Data                             |
| <b>2.2</b>                                   | Protection Report            | Protection Settings Reports                                    |
| <b>2.3</b>                                   | Special Automatic Facilities | Special Automatic Facilities e.g. intertrip                    |
| <b>2.4</b>                                   | Operational Metering         | Operational Metering   |
| <b>2.5</b>                                   | Tariff Metering              | Tariff Metering  |
| <b>2.6</b>                                   | Operational Comms            | Operational Communications                                     |
| <b>2.7</b>                                   | Monitoring                   | Performance Monitoring   |
| <b>2.8</b>                                   | Power Quality                | Power Quality Test Results (if required)                       |

## SCHEDULE 19 – EXISTING USER DATA FILE STRUCTURE

PAGE 2 OF 2

| <b>Part 3: Generator Technical Data</b>  |                              |   |
|--|------------------------------|---|
| 3.1  | DRC Schedule 1               | DRC Schedule 1 - Generating Unit,- <u>Power Generating Module, HVDC System and DC Converter Technical Data</u>                        |
| 3.2  | DRC Schedule 2               | DRC Schedule 2 - Generation Planning Data   |
| 3.3  | DRC Schedule 4               | DRC Schedule 4 – Frequency Droop & Response   |
| 3.4  | DRC Schedule 14              | DRC Schedule 14 – Fault Infeed Data – Generators  |
| 3.5  | Special Generator Protection | Special Generator Protection eg Pole slipping; islanding  |
| 3.6  | Compliance Tests             | Compliance Tests & Evidence   |
| 3.7  | Compliance Studies           | Compliance Simulation Studies   |
| 3.8  | Site Specific                | Bilateral Connections Agreement Technical Data & Compliance   |
| <b>Part 4: General DRC Schedules</b>   |                              |   |
| 4.1  | DRC Schedule 3               | DRC Schedule 3 – Large Power Station Outage Information   |
| 4.2  | DRC Schedule 6               | DRC Schedule 6 – Users Outage Information   |
| 4.3  | DRC Schedule 7               | DRC Schedule 7 – Load Characteristics   |
| 4.4  | DRC Schedule 8               | DRC Schedule 8 – BM Unit Data (if applicable)   |
| 4.5  | DRC Schedule 10              | DRC Schedule 10 –Demand Profiles  |
| 4.6  | DRC Schedule 11              | DRC Schedule 11 – Connection Point Data   |
| <b>Part 5: OTSDUW Data And Information</b><br>(if applicable and prior to <b>OTSUA Transfer Time</b> ) |                              |   |
|  |                              | Diagrams<br>Circuits Plant and Apparatus<br>Circuit Parameters<br>Protection Operation and Autoswitching<br>Automatic Control Systems |
|  |                              | Mathematical model of dynamic compensation plant  |

< END OF DATA REGISTRATION CODE >

