

Grid Code Frequency Response Working Group

Stewart Whyte – System Development



Synthetic Inertia
13th January 2011

Presentation Outline



- Summary of results on delay
- Synthetic Inertia ramp amendment
- Future system scenarios
 - Overview of scenarios
 - Response characteristic
 - Synthetic inertia requirement
- National Grid views on Synthetic inertia
 - One shot vs df/dt
 - Power Recovery
 - Power extraction

Summary of delay results

- At the last FR tech sub group meeting National Grid presented that a delay of a short time could be tolerated.
- National Grid looked at delay but did not reduce the speed of the inertial response
- Some of the group thought this would be useful
 - delays have now been studied for certain systems



75% wind on 25GW system

- 0.5s delay and 0.5s ramp





75% wind on 25GW system

- 1s delay and 2s ramp





75% wind on 25GW system

- 1s delay and 3s ramp





75% wind on 25GW system, one shot

- 0.5s delay and 0.5s ramp



75% wind on 25GW system, one shot lower loss 500MW

- 0.5s delay and 0.5s ramp



SI key questions

- What can be achieved?
- How fast can it be achieved?
- Recovery period
 - At what wind speeds is the recovery period worst
 - How can it be minimised
- Cost

SI issues

- df/dt deadband
- Appropriateness of df/dt control
- National Grid models used
- Control scheme interactions
 - FRT and SI
 - Frequency Response and SI
 - Reactive and SI
- Recovery period
- Filtering of df/dt
- ROCOF


Df/dt vs One Shot

-
- Appropriateness of df/dt has been questioned from the outset
 - Df/dt would be excellent for augmenting power in proportion to the incident compared to the one shot
 - Major disadvantage of df/dt is the measurement of the signal
 - Trigger
 - Further augmentation of power
 - What else could be done with df/dt to make it more appropriate
 - More time to measure for a trigger
 - Trigger on df/dt and Δf
 - Greater filtering of signal required


Power Recovery

-
- Manufacturer liaison has identified an issue with the recovery period
 - Recovery period characteristics
 - Wind speed dependant
 - Under worst case can be as deep as 25% of MW output resulting a double dip
 - Recovery can last for as long as 40s
 - Recovery at lower wind speeds is manageable – examples provided in previous meetings
 - There is no recovery period when operation is at or beyond rated wind speed
 - Reduce the upfront power extraction
 - Manufacturer meetings have led National Grid to believe that the return to optimal rotational speed can be controlled

Load Factor of Wind v National Demand



National Demand Duration Curve



Generation Mix - Future Scenario for Response and Inertia

GG Year:2020						
Generation Capacities	Low Demand 25GW		Median Demand 35GW		High Demand 45GW	
Demand						
Additional Demand (ie Pumping)	25	25	35	35	45	45
Total Demand	27	27	35	35	45	45
Generation						
"Must Run" generation						
Nuclear	11.2	6.7	6.7	7.9	7.9	9.6
Wind	26.8	20.1	0	21.4	1.3	24.1
Other	4.5	2.9	2.9	3.4	3.4	4.1
Total "Must Run" Capacity	42.5	29.8	9.7	32.7	12.6	37.7
Total Generation Capacity	100.0					
Primary Response Requirement						
Static Response	2.0	2.0	1.7	1.7	1.4	1.4
Net Response Req	0.2	0.2	0.2	0.2	0.2	0.2
Response on Synchronous Plant	1.5	1.8	1.5	1.5	1.2	1.2
Response on Asynchronous Plant	0.21	1.80	0.51	1.50	0.88	1.20
Response on Synchronous Plant Assumed Loading Point						
Assumed Deload/Response Ratio	65%	65%	75%	65%	85%	85%
Responsive Plant Deload	0.6	5.0	1.0	4.2	1.2	2.2
Power Output on Responsive Plant	1.7	14.4	4.1	12.0	8.2	14.6
Estimated number of machines (modules @800MW)	3	25	7	21	12	22
Response on Asynchronous Plant Assumed Loading Point						
Assumed Deload/Response Ratio	65%	85%	85%	85%	85%	85%
Responsive Plant Deload	4.5	0.0	1.8	0.0	1.0	0.0
Power Output on Responsive Plant	12.7	0.0	12.1	0.0	6.4	0.0
Estimated number of machines	2862	0.0	2315	0.0	1228	0.0
Additional Balancing (Pullback)	0.0	0.0	0.0	0.0	0.0	0.0
Power Output on Non-responsive Plant	2.5	0.0	7.5	0.0	16.7	0.0
Aggregate Response						
Power Output on Responsive Plant	14.4	14.4	16.2	12.0	14.6	14.6
Responsive Plant Deload	5.0	5.0	2.8	4.2	2.2	2.2
Additional Output Req	1.7	22.4	4.1	26.6	8.3	32.2
Power on Synchronous Machines						
H = 4	6.7	6.7	8.2	8.2	10.1	10.1
H = 6	4.6	20.3	7.2	25.5	11.7	33.5
Capacity on Synchronous Machines (based on 0.85pf capability)	11.4	27.0	15.4	33.7	21.9	43.7
Power on Asynchronous Machines						
H = 4	10.3	10.3	9.3	9.3	11.2	11.2
H = 6 (non-responsive)	3.4	3.4	3.7	3.7	4.1	4.1
H = 6 (deloaded for response)	2.7	22.9	6.0	19.1	11.1	19.8
Pre-2013 Asynchronous Capacity (no SI)	7.4	5.5	0.0	5.9	0.4	6.6
Power on SI Capable Asynchronous Generation	10.1	0.0	13.7	1.0	16.5	1.0
Max Power on Non-Responsive SI Capable Asynchronous Generation	2.9	0.0	7.5	1.0	16.5	1.0
Max Power Available on Non-Responsive SI Capable Asynchronous Generation	2.9	0.0	7.5	1.0	16.5	1.0
Total Generation	27.0	27.0	35.0	35.0	45.0	45.0

GG Year: 2025						
Generation Capacities	Low Demand 25GW		Median Demand 35GW		High Demand 45GW	
Demand						
Additional Demand (ie Pumping)	25	25	35	35	45	45
Total Demand	27	27	35	35	45	45
Generation						
"Must Run" generation						
Nuclear	9.4	5.6	5.6	6.6	6.6	8.0
Wind	38.1	28.6	0	30.5	1.9	34.3
Other	12.9	2.5	2.5	7.4	7.4	12.6
Total "Must Run" Capacity	60.4	36.7	8.1	44.5	15.9	54.9
Total Generation Capacity	111.8					
Primary Response Requirement						
Static Response	2.0	2.0	1.7	1.7	1.4	1.4
Net Response Req	0.2	0.2	0.2	0.2	0.2	0.2
Response on Synchronous Plant	1.8	1.8	1.8	1.5	1.5	1.2
Response on Asynchronous Plant	0.0	1.80	0.00	1.50	0.00	1.20
Response on Synchronous Plant Assumed Loading Point						
Assumed Deload/Response Ratio	65%	65%	50%	55%	55%	55%
Responsive Plant Deload	0.0	5.0	0.0	2.7	0.0	2.2
Power Output on Responsive Plant	0.0	14.4	0.0	18.3	0.0	14.6
Estimated number of machines (modules @800MW)	0	25	0	27	0	22
Response on Asynchronous Plant Assumed Loading Point						
Assumed Deload/Response Ratio	65%	85%	85%	85%	85%	85%
Responsive Plant Deload	5.0	0.0	3.0	0.0	2.2	0.0
Power Output on Responsive Plant	14.4	0.0	12.0	0.0	14.6	0.0
Estimated number of machines	3240	0.0	2500	0.0	2805	0.0
Additional Balancing (Pullback)	4.7	0.0	6.5	0.0	7.7	0.0
Power Output on Non-responsive Plant	4.5	0.0	9.0	0.0	9.8	0.0
Aggregate Response						
Power Output on Responsive Plant	14.4	14.4	12.0	18.3	14.6	14.6
Responsive Plant Deload	5.0	5.0	3.0	2.7	2.2	2.2
Additional Output Req	0.0	23.9	0.0	21.8	0.0	24.8
Power on Synchronous Machines						
H = 4	5.6	5.6	11.3	11.3	17.5	17.5
H = 6	2.5	21.4	2.7	21.8	3.0	25.6
Capacity on Synchronous Machines (based on 0.85pf capability)	8.1	27.0	14.0	33.1	20.5	43.1
Power on Asynchronous Machines						
H = 4	9.0	9.0	7.7	7.7	9.4	9.4
H = 6 (non-responsive)	2.9	2.9	3.1	3.1	3.5	3.5
H = 6 (deloaded for response)	0.0	22.9	0.0	24.7	0.0	19.8
Pre-2013 Asynchronous Capacity (no SI)	5.5	0.0	5.9	0.4	6.6	0.4
Power on SI Capable Asynchronous Generation	13.3	0.0	15.1	1.5	17.9	1.5
Max Power on Non-Responsive SI Capable Asynchronous Generation	4.5	0.0	9.0	1.5	9.8	1.5
Max Power Available on Non-Responsive SI Capable Asynchronous Generation	9.2	0.0	15.5	1.5	17.5	1.5
Total Generation	27.0	27.0	35.0	35.0	45.0	45.0

GG Generation Capacities as Scaled by factors

Total assumed requirement
LF Triggered response
Response required from generation

Response provided for a given deload

Drives response ramp rate assumption

Response provided for a given deload

Drives response ramp rate assumption
Pullback assumed on Wind
Used to derive SI capable plant (for scenarios where concurrent response and SI is not feasible)

Used to drive 'natural' inertia assumption

Generation Completed before 2013

Check - should balance demand

Plant Running Scaling Factors

	Low Demand 25GW		Median Demand 35GW		High Demand 45GW	
	High Wind	Low Wind	High Wind	Low Wind	High Wind	Low Wind
Nuclear	60%	60%	70%	70%	85%	85%
Wind	75%	0%	80%	5%	90%	5%
Other	75%	75%	80%	80%	90%	90%

Assumed Response Characteristic

Load Point (pu)	Response (pu)	Response/Deload
0.55	0.125	28%
0.65	0.125	36%
0.75	0.125	50%
0.85	0.082	55%
1	0	0%

Power Supplied Over Cumulative Hours for the 3 year period July 2007 - Oct 2010

