

# Grid Code Frequency Response Working Group Requirements for System Inertia

Antony Johnson, System Technical Performance



**nationalgrid**

The power of action.™

# Overview

---

- ◆ Summary or Work to Date
- ◆ Pre / Post fault Wind Curtailment
- ◆ Manufacturer Engagement
- ◆ Further Work

# Summary of Work Completed to Date

---

- ◆ Additional Study work
  - ◆ Spread Sheet
  - ◆ Digsilent Power Factory
  - ◆ BM Dashboard – Network Operations
- ◆ The effect of Inertia on the Transmission System
- ◆ Manufacturer Engagement
- ◆ Assessment of manufacturer capabilities
  - ◆ Power Recovery
  - ◆ Patents
- ◆ Further Work

# Spread Sheet Results – Effect of Inertia – 1800 MW Loss 1

---


- ◆ The spread sheet calculation has been developed to demonstrate the effect of inertia:-
- ◆ Key Points
  - ◆ 25 GW load
  - ◆ 23.2GW of Coal
  - ◆ 3.6 GW of Pumped Storage (Response)
  - ◆ 50% Delivery of Pumped Storage – ie 1.8GW
  - ◆ Generation Loss = 1.8GW
  - ◆ Demand Reduction – 2%/Hz
  - ◆ Zero Secondary Response Provided – Beyond Study Timescales

# Spread Sheet Results – Effect of Inertia – 1800MW loss 2



---

H Equivalent (MWs/MVA)	ROCOF (Hz/s)	Loss (MW)	Min Frequency (Hz)	Time to Min Frequency (s)
0	0.67	1800	47.99	5.75
1	0.466	1800	48.37	6.6
2	0.3575	1800	48.62	7.1
3	0.2898	1800	48.8	7.6
4	0.2437	1800	48.94	7.85
5	0.2102	1800	49.05	8.1
6	0.1848	1800	49.14	8.3
7	0.16492	1800	49.22	8.5
8	0.148875	1800	49.28	8.7
9	0.13567	1800	49.33	8.7
10	0.124625	1800	49.37	8.8
11	0.11524	1800	49.42	8.9
12	0.107168	1800	49.45	8.9



# A summary of the Requirement / Issue




# Deadband




# High Level Requirements (1)



# High Level Requirements (2) – Detail of initial Short term Power Injection



# High Level Requirements (2)



# Power Injection Capability and Recovery

Courtesy of Enercon – Taken from Figures 6 and 7 of Reference [1]




Figure 6 - Power Control including Rotational Speed – Note black dotted lines with extrapolated additional values additional to original figure quoted by Enercon




Figure 7 - Power Control excluding Rotational Speed – Note black dotted lines with extrapolated additional values additional to original figure quoted by Enercon

# Power Injection Capability and Recovery

Courtesy of Vestas – Taken from Figure 8 of Reference [3]




Figure 8 - Wind Power with Inertia emulation – Note black dotted lines with extrapolated additional values additional to original figure quoted by Vestas




# Manufacturer Engagement

---

- ◆ High level principles and concepts were issued to a wide range of manufacturers at the end of June 2010
- ◆ Ongoing dialogue
- ◆ Early stages but issues include
  - ◆ Power Recovery
  - ◆ Recovery time
  - ◆ Variations in wind speed
  - ◆ Patents
  - ◆ Impact of response on the Power System
  - ◆ Further modelling work required

# Study Results (1) – Spread Sheet Without Energy Recovery

							Scenarios			
							Gone Green			
Generation	GW generating	GW capacity H	trip size (GW)	Provide response?			2020	2025	2030	
Wind	16.36	17.4	0	0.6			16.5	9.5	2.8	
Nuclear	6.90	6.9	6.5	1.8			6.9	9.7	10.6	
Carbon capture	0.00	0	0	0			1.6	5.8	11.6	
SCC	0.00	0	0	0						
Conventional Coal	0.00	0	0	0						
Conventional Gas	0.00	0	0	0						
Pumped storage	1.80	3.6	4.5	1						
Demonstration	0.00	0	0	0	post trip H	1.89				
Total	25.06	27.9	2.19	1.8			Totals	25	25	25



calculation step size	0.1
no. of steps to measure ROCOF	100
ROCOF measured over (secs)	10
<b>ROCOF (Hz/sec)</b>	<b>0.06847</b>

# Study Results (1) – Spread Sheet – H = 0 Without Energy Recovery

response characteristic			wind specific response	
%output	time	slope		
0	0	50	0	0
10	0.2	-1.21212	0	4
6	3.5	-1.33333	2	5
4	5	-0.83333	12	9
1.5	8	-0.75	16	13
0	10	0	16	15
0	12		16	20





Chart Area

max percentage response =	10
capacity (GW) =	17.4
percentage of plant providing response =	60
pre-fault generation (GW) =	16.356

# Study Results (2) – Spread Sheet – H = 0 With Energy Recovery


response characteristic			wind specific response	
%output	time	slope		
0	0	100	0	0
10	0.1	-0.93023	0	4
-2	13	-0.5	2	5
-3	15	0.083333	12	9
-2.75	18	0.161765	16	13
0	35	0	16	15
0	20		16	20



max percentage response = 10  
 capacity (GW) = 17.3  
 percentage of plant providing response = 50  
 pre-fault generation (GW) = 16.435

# Study Results (2) – Spread Sheet With Energy Recovery


Generation	GW generating	GW capacity	H	trip size (GW)	Provide response?	Gone Green				
						2020	2025	2030		
Wind	16.44	17.3	0	1.8	0.5		16.5	9.5	2.8	
Nuclear	6.90	6.9	6.5	1.8	0		6.9	9.7	10.6	
Carbon capture	0.00	0	0		0		1.6	5.8	11.6	
SCC	0.00	0	0		0					
Conventional Coal	0.00	0	0	0	0					
Conventional Gas	0.00	0	0		0					
Pumped storage	1.80	3.6	4.5		1					
Demonstration	0.00	0	0	0	0	post trip H	1.90			
Total	25.14	27.8	2.20	1.8			Totals	25	25	25



calculation step size	0.1
no. of steps to measure ROCOF	100
ROCOF measured over (secs)	10
<b>ROCOF (Hz/sec)</b>	<b>0.065601</b>

# Study Results (3) – Spread Sheet With Energy Recovery


Generation	GW generating	GW capacity	H	trip size (GW)	Provide response?	Gone Green			
						2020	2025	2030	
Wind	16.40	17.3	0	0	0.52	16.5	9.5	2.8	
Nuclear	6.90	6.9	6.5	1.8	0	6.9	9.7	10.6	
Carbon capture	0.00	0	0	0	0	1.6	5.8	11.6	
SCC	0.00	0	0	0	0				
Conventional Coal	0.00	0	0	0	0				
Conventional Gas	0.00	0	0	0	0				
Pumped storage	1.80	3.6	4.5	0	1				
Demonstration	0.00	0	0	0	0	post trip H	1.90		
Total	25.10	27.8	2.20	1.8		Totals	25	25	25



calculation step size	0.1
no. of steps to measure ROCOF	100
ROCOF measured over (secs)	10
<b>ROCOF (Hz/sec)</b>	<b>0.068605</b>

# Study Results (3) – Spread Sheet – H = 0 With Energy Recovery


response characteristic			wind specific response	
%output	time	slope		
0	0	50	0	0
10	0.2	-1.01695	0	4
-2	12	-0.16667	2	5
-2.5	15	0.1	12	9
-2	20	0.066667	16	13
0	50	0	16	15
0	60		16	20



# Frequency Control Capability

## Example of a Secured Incident *26 May 2003 (1175 MW loss)*

Frequency Trace, 26-May-2003



# Further Work Required

---

- ◆ Finalise modelling to determine settings based on the minimum needs of the Transmission System taking energy recovery into account
- ◆ Compare model results
  - ◆ Spread Sheet
  - ◆ Digsilent Power Factory
  - ◆ BM Dashboard
- ◆ Understand manufacturers Capabilities in more detail
  - ◆ Power Recovery, Recovery Time, Impact on the Transmission System
  - ◆ Effect of Wind Speed
- ◆ Finalise Settings
  - ◆ Maximum value of PIncrease / Time duration
  - ◆ Exponential decay requirements / Power recovery
  - ◆ Deadband settings
  - ◆ Active Power injection during lower rates of change of system frequency
- ◆ Legal drafting
- ◆ Timescales

# References / Further Information

---

- ◆ [1] Contribution of Wind Energy Converters with Inertia Emulation to frequency control and frequency stability in Power Systems – Stephan Wachtel and Alfred Beekmann – Enercon – Presented at the 8<sup>th</sup> International Workshop on Large Scale Integration of Wind Power into Power Systems as well as on Offshore Wind Farms, Bremen Germany, 14 – 15 October 2009.
- ◆ [2] Variable Speed Wind Turbines Capability for Temporary Over-Production – German Claudio Tarnowski, Philip Carne Kjaer, Poul E Sorensen and Jacob Ostergaard
- ◆ [3] Study on Variable Speed Wind Turbine Capability for Frequency Response - German Claudio Tarnowski, Philip Carne Kjaer, Poul E Sorensen and Jacob Ostergaard
- ◆ [4] GE Energy – WindINERTIA™ Control fact sheet – Available on GE Website at :-  
[http://www.ge-energy.com/businesses/ge\\_wind\\_energy/en/downloads/GEA17210.pdf](http://www.ge-energy.com/businesses/ge_wind_energy/en/downloads/GEA17210.pdf)
- ◆ [5] Transmission Provider Technical Requirements for the Connection of Power Plants to the Hydro-Quebec Transmission System – February 2006
- ◆ [6] Amendment Report SQSS Review Request GSR007 Review of Infeed Loss limits – Prepared by the SQSS Review Group for Submission to the Authority – 10<sup>th</sup> September 2009 available at:- [http://www.nationalgrid.com/NR/rdonlyres/EF5C0829-1C5E-4258-8F73-70DC62C43F49/36936/SQSS1320Reportv10\\_final.pdf](http://www.nationalgrid.com/NR/rdonlyres/EF5C0829-1C5E-4258-8F73-70DC62C43F49/36936/SQSS1320Reportv10_final.pdf)