

Risk Assessment of Loss of Mains Protection – Phase II

23 March 2015


Adam Dyśko

University of Strathclyde

Glasgow, UK

e-mail: a.dysko@strath.ac.uk

Outline



- WP1 – Hardware testing based characterisation of DG – PNDC

- WP3 – Risk assessment calculation
 - DG connection register analysis (WPD)
 - Establishing dominant connection groups
 - Mixing generation profiles
 - Methodology

- WP2 – Simulation based characterisation of DG

WP1 – Hardware testing based characterisation of DG – PNDC

Test Setup


- PV emulator supplying single phase 3kW Fronius inverter.
 - Desired power output set (power levels depend on test).
 - PV emulator outputs DC voltage and current within set limits using MPPT curve.
- Fluke power quality analyser measurements at:
 - Inverter output.
 - PCC (convention set as export to grid).
- Single phase load bank used as local load (1kW steps).



WP1 – Hardware testing based characterisation of DG – PNDC

Tests conducted


- Islanding: 2kW load while inverter output is adjusted to minimise PCC power flow. The public grid is used in this case.
- Frequency ramps: ramp down then ramp up between 49.5-48.5Hz at a +/-0.5Hz/s rate. The MG set is used in this case.
- HV fault: 60Ω single phase earth fault applied on the upstream 11kV network. The MG set is used in this case.



WP1 – Hardware testing based characterisation of DG – PNDC

Islanding results – Inverter Power


- At the point of islanding:
 - Measured inverter output around 2.03kW and -20VAr.
 - Measured PCC export around +/-2W and 140VAr.
- Inverter trips within 4 cycles.



WP1 – Hardware testing based characterisation of DG – PNDC




Islanding results – Inverter Voltage



WP1 – Hardware testing based characterisation of DG – PNDC




Islanding results – Inverter Current



WP1 – Hardware testing based characterisation of DG – PNDC




Islanding results – PCC Power



WP1 – Hardware testing based characterisation of DG – PNDC


Islanding results – PCC Voltage



WP1 – Hardware testing based characterisation of DG – PNDC




Islanding results – PCC Current



WP1 – Hardware testing based characterisation of DG – PNDC

Frequency ramp results – Frequency profile


- MG set speed controlled tightly using RTDS:
 - Ramp up and down rate of $\pm 0.5\text{Hz/s}$ within 49.5Hz – 48.5Hz band.
 - Band selected to avoid HV network protection or inverter tripping caused by MG set speed control overshoot.
- Inverter remains stable during and after ramps.




WP1 – Hardware testing based characterisation of DG – PNDC

Frequency ramp results – Frequency profile

- MG set speed controlled tightly using RTDS:
 - Ramp up and down rate of $\pm 0.5\text{Hz/s}$ within $49.5\text{Hz} - 48.5\text{Hz}$ band.
 - Band selected to avoid HV network protection or inverter tripping caused by MG set speed control overshoot.
- Inverter remains stable during and after ramps.




ROCOF



WP1 – Hardware testing based characterisation of DG – PNDC

Frequency ramp results – Inverter Power

- Load bank set to 2kW.
- Inverter output set to around 1.4kW.
- Measured inverter output reactive power of around 20VAr.



WP1 – Hardware testing based characterisation of DG – PNDC



Next steps

- In the process of ordering further inverters for further testing:
 - 5kW SMA SunnyBoy.
 - 5kW ABB (PowerOne).
 - 5kW Kaco.
 - 10kW SMA TriPower (three phase).
- Testing will include up to 2 single phase inverters simultaneously.
- Installation of new inverters and testing planned for second half of April.
- Build working group feedback into upcoming testing.

WP3 – Risk assessment calculation



DG register analysis (WPD)

WP3 – Risk assessment calculation



- Technology mapping (based on WPD data).

Primary substation	Generator type	Connected export capacity [kW]	Accepted not yet connected export capacity [kW]	Total export capacity [kW]
Abington 33/11kv	Photovoltaic	79.38	0	79.38
Acreage Lane 33/11kv	Hydro	3.56	0	3.56
Acreage Lane 33/11kv	Landfill Gas Sewage Gas Biogas (not CHP)	11700	0	11700
Acreage Lane 33/11kv	Other Generation	1200	0	1200
Acreage Lane 33/11kv	Photovoltaic	503.21	0	503.21
Alford 33/11kv	Photovoltaic	260.389	0	260.389
Allenton 33/11kv	Micro CHP (Domestic)	0.215	0	0.215
Allenton 33/11kv	Photovoltaic	883.01	0	883.01
Alliance & Leicester 33/11kv	Biomass & Energy Crops (not CHP)	1850	0	1850
Alliance & Leicester 33/11kv	Landfill Gas Sewage Gas Biogas (not CHP)	2590	0	2590
Alliance & Leicester 33/11kv	Other Generation	1000	0	1000
Alliance & Leicester 33/11kv	Photovoltaic	225.564	0	225.564
Ambergate 33/11kv	Onshore Wind	91	225	316
Ambergate 33/11kv	Photovoltaic	131.36	0	131.36
Anderson Lane 33/11kv	Photovoltaic	597.94	0	597.94
Annesley (Kirkby) 11kv S Stn	Onshore Wind	11	500	511


WP3 – Risk assessment calculation



- Technology mapping (based on WPD data).
 - All types of connections were mapped onto 5 main generating technologies

Biomass & Energy Crops (not CHP)	SM
Hydro	IM
Landfill Gas Sewage Gas Biogas (not CHP)	SM
Large CHP (≥ 50 mw)	SM
Medium CHP (>5 MW <50 MW)	SM
Micro CHP (Domestic)	SM
Mini CHP (<1 MW)	SM
Offshore Wind	PMSG
Onshore Wind	DFIG
Other Generation	SM
Photovoltaic	PV
Small CHP (>1 MW <5 MW)	SM
Waste Incineration (not CHP)	SM

WP3 – Risk assessment calculation




- Technologies with cumulative contribution of 10% or less were removed from the mix.
- The remaining generation was scaled up to the full capacity installed at the primary substation

WP3 – Risk assessment calculation



- Establishing dominant groups.



WP3 – Risk assessment calculation




Group	Substations	Percentage
SM	60	5.5
PV	544	49.5
DFIG	5	0.5
IM	0	0.0
PMSG	0	0.0
SM, PV	283	25.8
SM, DFIG	10	0.9
SM, IM	1	0.1
SM, PMSG	0	0.0
PV, DFIG	139	12.7
PV, IM	10	0.9
PV, PMSG	1	0.1
DFIG, IM	0	0.0
DFIG, PMSG	0	0.0
IM, PMSG	0	0.0
SM, PV, DFIG	39	3.6
SM, PV, IM	1	0.1
SM, PV, PMSG	0	0.0
SM, DFIG, IM	0	0.0
SM, DFIG, PMSG	0	0.0
SM, IM, PMSG	0	0.0
PV, DFIG, IM	3	0.3
PV, DFIG, PMSG	1	0.1
PV, IM, PMSG	0	0.0
DFIG, IM, PMSG	0	0.0
SM, PV, DFIG, IM	1	0.1
SM, PV, DFIG, PMSG	0	0.0
SM, PV, IM, PMSG	0	0.0
SM, DFIG, IM, PMSG	0	0.0
PV, DFIG, IM, PMSG	0	0.0
Total	1098	100.0

- Establishing dominant groups.
- Groups of primary substations with more than 5% of the total population were only considered for risk assessment analysis.

WP3 – Risk assessment calculation


- Distribution of dominant groups.



WP3 – Risk assessment calculation

Generation profile mixing

Example: 33% SM (fixed PQ), 33% PV (solar), 33% DFIG (wind)



WP3 – Risk assessment calculation

Methodology/assumptions



- Perform risk assessment based on the number of possible islands rather (substations) than number of generators.
- Represent each predominant island group with an equivalent NDZ. Five predominant have been identified. The largest population is formed by single generation PV for which ROCOF setting change will have no impact.
- Profiles for predominant groups are synthesised using the available generation profiles.
- In NDZ assessment and generation profile mixing it is assumed all technologies have equal contribution. Cumulative contributions of less than 10% are removed though. (discuss)
- Risk assessment will be performed systematically based on group capacity distribution in substations.

WP3 – Risk assessment calculation



Data still desirable

- Monitoring data
 - 1s resolution data from example 11kV feeder or substation in WPD with min load <5MW (**pending**)
 - 1s or 5s resolution data (P, Q) of small PV unit output in different seasons (summer, winter, mid-season) (**pending – contact from Michael has not responded**)
- Number of primes in WPD?

WP2 – Simulation based characterisation of DG




- Most popular generation mixes have been considered.
- Synchronous, PV-Inverter, PMSG-Inverter, DFIG and Asynchronous based generation were modelled.

WP2 – Simulation based characterisation of DG

Individual Connection Stability Studies


Synchronous Generator



WP2 – Simulation based characterisation of DG



Synchronous Generator

Synchronous generator can be Ssable during LOM event



Assess Non Detection Zone for Active and Reactive Power.


Active Power Imbalance: 0%
Reactive Power Imbalance: 0%



WP2 – Simulation based characterisation of DG

Synchronous Generator

Non Detection Zone Assessment




	Setting Option 1 0.13 Hz/s , 0 Sec	Setting Option 2 0.2 Hz/s , 0 Sec	Setting Option 3 1.0 Hz/s , 0.5 Sec
NDZ-P [%]	1.3	1.4	9.44
NDZ-Q [%]	7.9	9.14	43

WP2 – Simulation based characterisation of DG

Individual Connection Stability Studies


Photovoltaic Panels




WP2 – Simulation based characterisation of DG

Active Power Imbalance: 0%
Reactive Power Imbalance: 0%

Photovoltaic Panels are unstable during LOM event, even for complete Active and Reactive power balance at PCC.




No NDZ



WP2 – Simulation based characterisation of DG

Individual Connection Stability Studies


Induction Generator




WP2 – Simulation based characterisation of DG

Active Power Imbalance: 0%
Reactive Power Imbalance: 0%

Induction Generator creates high ROCOF + frequency shifts according to generator slip




No NDZ



WP2 – Simulation based characterisation of DG

Individual Connection Stability Studies


DFIG



WP2 – Simulation based characterisation of DG


Model 1

Active Power Imbalance: 0%
Reactive Power Imbalance: 0%



Model 2


Active Power Imbalance: 0%
Reactive Power Imbalance: 0%



WP2 – Simulation based characterisation of DG

Generation Mix Stability Studies


Synchronous Generator & Induction Generator



WP2 – Simulation based characterisation of DG

Total Power : 2 MVA	
SG [%]	IG [%]
90	10

Induction






Synchronous

Active Power Imbalance: 0%
Reactive Power Imbalance: 0%

Active Power Imbalance: 5%
Reactive Power Imbalance: 0%


Active Power Imbalance: 0%
Reactive Power Imbalance: 5%



WP2 – Simulation based characterisation of DG

Total Power : 2 MVA	
SG [%]	IG [%]
80	20

Induction






Synchronous

Active Power Imbalance: 0%
Reactive Power Imbalance: 0%


Active Power Imbalance: 5%
Reactive Power Imbalance: 0%

Active Power Imbalance: 0%
Reactive Power Imbalance: 5%



WP2 – Simulation based characterisation of DG




Total Power : 2 MVA	
SG [%]	IG [%]
70	30



Active Power Imbalance: 0%
Reactive Power Imbalance: 0%

Active Power Imbalance: 5%
Reactive Power Imbalance: 0%


Active Power Imbalance: 0%
Reactive Power Imbalance: 5%



WP2 – Simulation based characterisation of DG


Generation Mix Stability Studies

Synchronous Generator & Photovoltaic Panels



WP2 – Simulation based characterisation of DG

Total Power : 2 MVA	
SG [%]	PV [%]
95	5






Synch...

Active Power Imbalance: 0%
Reactive Power Imbalance: 0%


Active Power Imbalance: 5%
Reactive Power Imbalance: 0%

Active Power Imbalance: 0%
Reactive Power Imbalance: 5%




WP2 – Simulation based characterisation of DG

Total Power : 2 MVA	
SG [%]	PV [%]
90	10




Synch..


Active Power Imbalance: 0%
Reactive Power Imbalance: 0%



Active Power Imbalance: 5%
Reactive Power Imbalance: 0%




Active Power Imbalance: 0%
Reactive Power Imbalance: 5%




WP2 – Simulation based characterisation of DG


Total Power : 2 MVA	
SG [%]	PV [%]
80	20




Active Power Imbalance: 0%
Reactive Power Imbalance: 0%



Active Power Imbalance: 5%
Reactive Power Imbalance: 0%




Active Power Imbalance: 0%
Reactive Power Imbalance: 5%




WP2 – Simulation based characterisation of DG


Total Power : 2 MVA	
SG [%]	PV [%]
70	30




Active Power Imbalance: 0%
Reactive Power Imbalance: 0%



Active Power Imbalance: 5%
Reactive Power Imbalance: 0%




Active Power Imbalance: 0%
Reactive Power Imbalance: 5%




WP2 – Simulation based characterisation of DG


Total Power : 2 MVA	
SG [%]	PV [%]
60	40




Active Power Imbalance: 0%
Reactive Power Imbalance: 0%



Active Power Imbalance: 5%
Reactive Power Imbalance: 0%




Active Power Imbalance: 0%
Reactive Power Imbalance: 5%



WP2 – Simulation based characterisation of DG




Total Power : 2 MVA	
SG [%]	PV [%]
50	50



Active Power Imbalance: 0%
Reactive Power Imbalance: 0%

Active Power Imbalance: 5%
Reactive Power Imbalance: 0%

Active Power Imbalance: 0%
Reactive Power Imbalance: 5%



WP2 – Simulation based characterisation of DG

■ ROCOF setting options

LOM Option	LOM Protection Type	Settings
1	ROCOF	0.13 Hz/s (no time delay)
2	ROCOF	0.2 Hz/s (no time delay)
3 (prev. 5)	ROCOF	0.5 Hz/s (0.5s delay)
4 (prev. 6)	ROCOF	1.0 Hz/s (0.5s delay)
5 (prev. 7)	V & f Only	G59 Recommended

- Due to large amounts of testing and limited access to RTDS facility it is proposed to perform NDZ assessment using an existing ROCOF relay model (?).

