

## 300 200 100 -300 -400 M -500 -600 -700 20 n k -800 g e -900

Around 600MW STOR was utilised during the evening peak. Late in the evening, technical issues in the control room required additional response to be held until the issues were resolved. SpinGen was also utilised to assist with positive reserve levels.

System issues were limited to ROCOF and Voltage; these were resolved via trades on interconnectors and BM units. No BM actions were required.

Note: A new category - Other Reserve - has been more clearly defined. Costs in this category used to be mapped to either Positive Reserve or Fast Re serve. These costs include BM Startup, Fast Start and some Hydro services. These changes have been made to align with the new Monthly Balancing Services Summary report.