





Date: 25/11/2018

BSUoS Charge Estimate: £1.05/MWh
Total Outturn: £1.15m


Daily Balancing Costs



■ BM Cost (Indicative)
■ AS Cost (Estimate)



SBP/SSP Vs NIV 25-Nov-2018



Western Link status: Available

Commentary

550MW of STOR was run over the darkness peak to cover for the late return of a circuit and replace constrained generation
Trades were carried out on the Interconnectors for ROCOF in the early morning and on a BM unit just before midnight. A small number of BM actions were required over the darkness peak for a constraint in the North East. Due to low wind generation all plant requirements for voltage management were met by the market.