

## Power Available and High Wind Speed Shutdown



Andrew Kensley

11 September 2012

# Operating the Transmission System

---

As System Operator, National Grid's ability to balance generation and demand within the capability of the Transmission System is dependent upon accurate real time and forecast data

- Grid Code obligation currently requires a best estimate from generators of their output as Physical Notifications (PNs)
- The ability to manage extreme system events such as High Wind Speed Shutdown of wind turbines is also dependent on forecast and real time data
- Lack of accurate information in these areas may lead to increased balancing costs and reduced security of supply

## High Level Requirements

---

- An appropriately accurate measure of output
- Available power to measure:
  - Headroom capability
  - Footroom capability
  - Frequency response capability
- A measure of uncertainty in the estimate of output


Local and regional effects – ability to manage constraints

National effects – ability to manage frequency

# High Wind Speed Shutdown


David Lenaghan

# High Winds – 8<sup>th</sup> December 2011






# Wind Generation – Forecast and Actual





High winds caused cut-outs and lowered output to half of expected

- Initial Forecast Value
- Latest Forecast Value
- Out-turn Forecast Value

# Net Imbalance Volume




# Forecast for this Thursday night...



## Physical Notification versus Metered Output



# Wind BMU PN accuracy



## Comparing all Wind BMUs


---

**Percentage error for PN following is typically around 15%**


In general:

- the accuracy of PNs increases as real time approaches
- there is no bias towards either 'under' or 'over' forecasting


## Recent analysis




# Recent Examples



## Recent Examples



# Recent Examples



## 16<sup>th</sup> August 2012 NRAPM

---

- At 17:20 hours a Local NRAPM (Negative Reserve Active Power Margin) Warning was issued for Scotland for the period 00:30 – 06:00 hours.
- A shortfall of 600MW of available bid volume was identified
- High wind was forecast for this period
- Generation output was lower than forecast and at 00:00 hours the NRAPM Warning was cancelled

Questions?

