


Grid Code Compliance using a Hybrid Statcom

Mick Barlow, Application Director,
Europe, Middle East and Africa
S&C Electric Europe Ltd






4. Demonstration of Potential Effects on Dynamic Stability



- System comprises of ~400MW of generation connected to a grid system via 60km and 80km of OHL with a 150MW WF connected 60km from the Power Station and operating at 21% of it full rating.
- A short circuit is applied to OHL 1 with full reactive capability available from the WF via Statcom 1.
- The fault on the line is cleared by tripping OHL 1 after 140ms.
- The study is then repeated with the Statcom output limited to 33% of its rating.
- The following slide shows the effect of limiting reactive capability on dynamic stability for the above operating conditions.

Results of Dynamic Stability Study – Power Flow from Synchronous M/C's

nationalgrid




This study demonstrates how limiting the reactive capability of dynamic voltage support can effect:

- **Dynamic Stability of Synchronous Generation on the System and therefore...**
- **The transfer capability of a transmission system**


A few comments

- The case being used is dynamically unstable and not transiently unstable.
- It should not be expected to solve a dynamically unstable with a SVC or Statcom.
- Potential Overload rating of Statcom has been ignored,
- We had a problem with our DSTATCOM Powerfactory model in the latest version of Powerfactory.
- We did our comparison with a PSS/E model.


No Statcom
PowerFactory (NGET) Result




47(54)MVar Statcom
PowerFactory (NGET) Result




16(18)MVar Statcom
PowerFactory (NGET) Result




No Statcom
PSS/E Result





47(54)MVar Statcom
PSS/E Result





16(18)MVar Statcom
PSS/E Result





47(54)MVar Statcom
PowerFactory (NGET) Result





47(54)MVar Fully-rated
DStatcom





42(48)MVar Fully-rated
DStatcom





47(54)MVar Statcom
PowerFactory (NGET) Result



47(54)MVar DStatcom (POD out)
16MVar Inverter + 2x19MVar SSDs



47(54)MVar DStatcom (POD in)
16MVar Inverter + 2x19MVar SSDs



Can NGET Requirements be met with Current Technology

Required to:-

- ✓ Ensure system voltage is maintained within SQSS limits any dips below 0.85pu last <2.5secs to prevent cascade tripping on FRT
- ✓ Ensure an initial reactive power response within 1 second as currently defined in the GB Grid Code
- ✓ Ensure delivery of available reactive reserves during critical events
- ?? Ensure repeatable response within DAR and operator time scales
- ✓ Ensure consistency with RfG
- ✓ Ensure a response provided in the event of interactions with similar equipments in adjacent Power Parks
- ✓ Ensure repeatable response such that contingency and defence studies produce reliable results

Conclusions

- An Hybrid Statcom performs equally well as a fully rated Statcom.
- The Grid Code should only define the performance of the device at it's terminals and should not specify any internal performance.