






Date: **Thursday 31 Oct 2019**

**BSUoS Charge Estimate: £1.64/MWh**  
**Total Outturn: £2.20m**

# Daily Balancing Costs

- BM Cost (Indicative)
- AS Cost (Estimate)



## Commentary

The market was generally long, with short peaks mainly between midday and late afternoon, and late evening briefly. Some Interconnector Trades for Margin were required in the afternoon. Thermal import constraints in the South East alleviated by Interconnector Trades from 5am onwards through the day. Some brief BM Actions were required to manage the effects of this early morning. Overnight Voltage Control supported by BM Actions in the Midlands and South East. Trades overnight for RoCoF.

**Western Link status: Available**