

Grid Code Review Panel

Paper GCRP 01/14

Summary of Actions from meeting on 17 May 2001

Name	Min No.	Topic	Details	Status	Comments
KJB HPJ	442 472	Frequency Response	Keep under review the issue about what requirements, if any, need to be placed on Minor Independent Generating Plant in the Grid Code.	Ongoing (Feb 2002)	NGC is keeping the situation under review, and gave annual updates in February 1999, 2000 and 2001
GJC GJC	876 933	Administration	Prepare paper with proposals for changes to Panel Membership Produce Consultation paper on proposed Panel membership	Complete (May 2001) Complete (Sep 2001)	Consultation complete. Report sent to Ofgem 28/08/01
GJC	754	ROCOF reporting	Provide a further annual report in September 2001	Ongoing (Sep 2001)	See Paper GCRP 01/24
DP	905	OC5 Review	Prepare Consultation paper on proposed OC5 changes	Complete (Sep 2001)	Consultation complete. Report sent to Ofgem 17/08/01
DP	914	NGC Demand and National Demand	Prepare Consultation paper on proposed clarifications to definitions	Complete (Sep 2001)	Consultation complete. Report sent to Ofgem 10/08/01
NF	918	Data Buffering	Report back to Panel with NGC proposals for dealing with issue of planned outages becoming unplanned outages.	September GCRP Meeting	See Paper GCRP 01/15
GJC	923	BOA's going to the wall	NGC issues BOA's that take generators to the end of the BM period then expect generator to return to PN. This causes technical and commercial difficulty for generator. Investigate and propose GC changes if necessary	November GCRP Meeting	
GJC	942	Embedded Large Power Stations and Distribution constraints	Prepare Consultation paper on Grid Code changes suggested by Malcolm Taylor acting on behalf of certain generators	Complete (Sep 2001)	Paper issued. Consultation in progress.