



GC0154

Incorporation of interconnector ramping requirements into the Grid Code as per SOGL Article 119

Meeting
21st July 2022

Action Log Review

Action Number	Action	Owner	Due by	Status
1	Review the definition of EA with Ben Marshall	Tom I	April 2022	Propose to close



TSO Engagement Plan

Tom Ireland – National Grid ESO Code Administrator

CBA update

CBA update

- ESO will tender for external consultancy to complete the CBA. ESO will update the timeline when a consultant is appointed if required
- Key drivers for the change is to ensure resilience for security of supply in the future with increased interconnection, ensuring costs for consumers is minimal whilst meeting the requirements of SOGL A119
- Expect to include the status quo (100mw/min) the dynamic solution and the static option presented last workgroup
- ESO will include why we have not chosen to review out of scope options in this CBA

Input required

- We will possibly require information from Interconnectors to ensure a rounded and robust CBA is completed
- We are keen to understand what questions stakeholders like to be considered in the CBA
- Thoughts on the timescales to review/model- next 2-5 years? Longer?

This is not exhaustive – it is the start of a discussion for the workgroup- we would welcome your thoughts to share to the consultant

Preferred ESO Solutions (In scope)

Option 1 - Dynamic

- Preferred NGENSO option
- Allows control over ramping with a pre agreed process
- Applied base rate value to ramping using dynamic tool to release additional ramping based on rate of change in demand share
- Resilient for the future
- Risks- not tested


Option 2- Static

- Reduces ramp rate at all times not just when operational challenges exist
- Same ramp rate as BMU
- More of an interim solution to allow for testing

ESO Recommended Solution - Dynamic ramp rate

- Process to manage ramping when met by system needs
- Base ramp rate to be applied to IC at all times with increased ramp rates to be made available if system conditions allow
- We would allow for IC to ramp slower than the base rate at all times
- IC should follow base ramp rate when moving opposite to demand direction

Data	Why?
Base Rate Value 50 MW/min	As per BMU restrictions within the Grid Code
Additional available ramping cap of 100MW/min	As per current arrangements
Additional GB ramping made available when rate of demand change is >50MW/min: 250 MW/min	Our current continental European interconnectors ramp at 100MW/min, a total of 500MW/min if they all ramp at the same time. This increase of 250MW/min, when in the same direction as demand, equates to 100MW/min on each existing interconnector.
Notice for IC for extra ramping available:	Prior to the interconnector day ahead auctions



Advantages

- Resilient for the future
- Allows the control room to work with a pre agreed process set out in the code
- Have more flexibility to manage cost in the control room which in turn is a benefit to the end consumer
- The process can be a relatively simple file transfer

Dynamic ramp rate Process Flow Diagram

Prior to the IC day ahead auction

Demand Forecast

Control Room
NGESO

Control Room
Dynamic Ramp
Rate Tool

What is
rate of
change of
demand?

Below
50MW/min

Above 50
MW/min

Base Rate
50MW/min

Additional GB
ramping available:
250 MW/min

NGESO to inform I/Cs
that extra ramping is
available

Inform all ICs
about extra
available
ramping

Release final ramp
rates via file
transfer

I/Cs to inform NGESO if they
want additional ramping


ICs

When our demand change is above 50MW/min we are able to offer an increased ramp rate to the interconnectors, if moving in the same direction as demand. Times when we can offer this will depend on the predicted demand shape.

Our current continental European interconnectors ramp at 100MW/min, a total of 500MW/min if they all ramp at the same time. This increase of 250MW/min, when in the same direction as demand, equates to 100MW/min on each existing interconnector.

Initial base rate proposal. The value will be subject to change in the future depending on system conditions and future ramp rates arrangements with BMUs

Possible to extend ramping period from 10 min to 20 min



What questions do we still have?

Open questions

- What is the solution impact on the control room and IT systems?
- Impacts to the remote end TSOs?
- Emergency protocol if forecasting demand change is uncertain?
- How we intend to integrate into the future balancing system?

Mitigations

- Potential for a phased approach of implementation to support transition
- Plan in place to seek feedback with remote TSO after workgroup
- Make ESO data transparent
- Plan in place to begin impact assessment to internal ESO IT system
- Ongoing conversations with IT about future impact assessments

Summary of feedback received (to 8th July)

Feedback	ESO Comments
100MW/Min to be included in the codes complies with the ask from Ofgem (SOGL)	Noted, this is the simple option, however it does not seek to resolve the operational issues we have shared as a result of fast IC ramping. Not addressing now could then require a further code change to be raised
Key driver for a dynamic solution is to impose more onerous ramping restrictions and has expanded the scope of what is required	The ESO wishes to have more control over the times when ramping is moving faster than demand. This approach does not seek to impose continuous restrictions, just when the system requires them
Examples provided do not show significant justification that IC cause increasing balancing costs in certain system conditions	The ESO has tried to share examples to demonstrate the operational issues with increasing number of IC on the network. This will increase as more IC connect unless a change is made
The time that a CBA may take to complete could mean further delays to compliance	Yes, this a concern, however as this change is seeking to ensure resilience to the network, ESO is keen to keep progressing and updating stakeholders on its progress
A review of ramping should be done as a wider review of balancing costs to allow careful consideration it deserves	Ramping for BMU is not in scope of this work as ramping restrictions are already in place. The ESO would like to recommend that the BMU ramping is reviewed should the dynamic solution be implemented for IC ramping
Impacts on the current tri-lateral agreements in place with each TSO	There will be engagement with the TSO to review these documents and the solution – including any impacts. This will be shared to the workgroup where possible
Understanding how the IC will be impacted financially and if there will be compensation payments made should this be the case	The ESO is keen to ensure that there is a fair solution for all parties and one that benefits the end consumer. Any costs that the IC are concerned about should be shared as part of the CBA. We would welcome this data being shared to understand where the impact lies

Feedback discussion

To discuss email sent on the 13th July 2022

Draft high level timeline with CBA

The Chair will provide an update on the timeline;

- **Timeline still likely to change- Requires consultant shares timescales to complete work before sending to panel for approval**
- Workgroup and panel meetings to be rescheduled into the timeline when the CBA timeline is confirmed
- Workgroups to continue to discuss solution and workgroup consultation questions whilst the CBA and IA are in progress

Annex



Assumptions

The aim is to map the requirements of Article 119 to the Grid Code as requested by Ofgem.

This will require the ESO and stakeholders to work collaboratively to find a solution that aligns with the text which has been written and approved.

The solution needs to consider the requirements of the transmission system now and be resilient enough for the future.

Cross –border ramping is a shared decision with the remote end EU System Operator. Therefore, their involvement and coordination with this process is key to ensure a mutually acceptable solution.

Ramping for BMUs is not in scope of this modification

Ramping restriction for active power output - Article 119 (c)

LFC block operational agreements

1. By 12 months after entry into force of this Regulation, all TSOs of each LFC block shall jointly develop common proposals for:
 - (a) where the LFC block consists of more than one LFC area, FRCE target parameters for each LFC area defined in accordance with Article 128(4);
 - (b) LFC block monitor in accordance with Article 134(1);
 - (c) **ramping restrictions for active power output in accordance with Article 137 (3)* and (4)**

*outstanding action

Ramping restriction for active power output

Article 137 (3) & (4) of SOGL

Code
mapping

3. All connecting TSOs of an HVDC interconnector shall have the right to determine in the LFC block operational agreement common restrictions for the active power output of that HVDC interconnector to limit its influence on the fulfilment of the FRCE target parameter of the connected LFC blocks by agreeing on ramping periods and/or maximum ramping rates for this HVDC interconnector. Those common restrictions shall not apply for imbalance netting, frequency coupling as well as cross-border activation of FRR and RR over HVDC interconnectors. All TSOs of the GB synchronous area shall coordinate these measures within the synchronous area.

4. All TSOs of an LFC block shall have the right to determine in the LFC block operational agreement the following measures to support the fulfilment of the FRCE target parameter of the LFC block and to alleviate deterministic frequency deviations, taking into account the technological restrictions of power generating modules and demand units:

- (a) obligations on ramping periods and/or maximum ramping rates for power generating modules and/or demand units;
- (b) obligations on individual ramping starting times for power generating modules and/or demand units within the LFC block; and
- (c) coordination of the ramping between power generating modules, demand units and active power consumption within the LFC block.

BC1.A.1.1

Highlighted to show gap to close

Text taken from the SOGL

nationalgridESO

LFC Block Operational Methodology for Article 119 (1) (c)

A119 Methodology text to map to codes	Supporting paper reference
1. Rules for ramping restrictions on the active power output of each HVDC interconnector between a LFC Block of another synchronous area and the GB LFC block, in accordance with SOGL Article 137(3):	N/A
a. The ESO, and the connecting TSOs supervising a LFC block of an HVDC interconnector shall have the right to determine common ramping restrictions in the form of ramping periods and/or maximum ramping rates and shall enter into agreement with the TSOs responsible for operating the interconnector, to determine the processes and mechanisms by which these restrictions will be put in place. These ramping restrictions shall not apply to imbalance netting, frequency coupling, cross-border activation of FRR or cross-border activation of RR. These ramping restrictions shall not apply to any service aimed at maintaining or returning one of the connected electricity systems to a normal system state.	The ESO has sought to maintain simplicity of application in that compliant regimes already exist on all GB connecting HVDC interconnectors, where the ramping restrictions and manner in which they are applied is agreed and defined in the operational agreements

LFC Block Operational Methodology for Article 119 (1) (c)

A119 Methodology text to map to codes	Supporting paper reference
<p>b. The ramping restrictions for each interconnector shall be applied in a non-discriminatory manner. The ESO shall ensure alignment of ramping restrictions between all HVDC interconnectors linking the same two synchronous areas, taking into account the technical capabilities of each HVDC interconnector;</p>	<p>The ESO wants to demonstrate that all interconnector parties are being treated fairly, but highlights that rules between different synchronous areas may differ as ramping-restrictions imposed from another synchronous area may, if more onerous than those sought by the ESO, result in different rules for those particular interconnectors.</p>
<p>c. A summary of the ramping-restrictions to be applied to HVDC interconnectors connecting to the GB LFC Block, shall be published by the ESO on its website at least one week before the rules are enforced, in accordance with the obligations in SOGL Article 8;</p>	<p>Transparency and fairness is demonstrated by publishing a summary of the ramping-restrictions being applied to GB interconnectors on the internet.</p>

LFC Block Operational Methodology for Article 119 (1) (c)

A119 Methodology text to map to codes	Supporting paper reference
<p>d. The ESO, in order to prevent the GB LFC block from entering into an emergency state, may restrict equitably the ramp rates of GB interconnectors between GB and the same connecting synchronous areas, in coordination with the affected national TSOs and affected interconnector operators according to the terms referred to paragraph (a) of this Article;</p>	<p>There is a need to be able to reduce the ramping-rates being applied to interconnectors when there is a current need or anticipated situation which, without action, would result in Great Britain entering an emergency state. Under these circumstances, the ESO will follow procedures to be determined in the operational agreements between parties to apply reduced ramp-rates to all market-based transfer programs on all the affected interconnectors.</p>
<p>e. Within 30 calendar days of an incident which restricted one or more of the HVDC interconnectors, under the process referred to in paragraph (d), the ESO shall prepare a report containing an explanation of the rationale, implementation and impact of this action and submit it to the relevant regulatory authority in accordance with Article 37 of Directive 2009/72/EC and neighbouring TSOs, and also make the report available to all significantly affected system users.</p>	<p>For transparency purposes, the ESO will publish information on the circumstances leading up to the need to reduce ramping-rates and the actions followed until operations were returned to normal ramping-rules.</p>

Possible solutions discussed (Not in scope)

Not in scope for GC0154	Justification
Working with ESO, to understand how the new technology (i.e. battery) and new market design can help ESO manage ramping for ICs and other generation assets	Manages ramp rates but does not solve root ramping problem, fits more so into balancing services programme of work.
Effective utilisation and design of additional services with ICs and other technologies	Does not solve root ramping problem
Change of GB wholesale market design and IC capacity market which might be the enduring solution	High complexity, would require market reform, timescales not aligned with OFGEM/ESO expectations
Establish cross border Frequency response on all borders through the ICs	Would provide assistance to manage ramping but not necessarily solving the problem.
Change to a 5 minute settlement period to address the root cause.	Exemption already in place for 15 min ISP under EBR. This would involve total change of market design which is not in scope for this mod.
Create a market for ramp rates.	High complexity, would require market reform/lengthy process, also may seek to solve swings rather than ramp rates.
NGESO set a maximum ramp rate for each period of the day and then interconnectors bid for the use of this ramp rate.	High complexity, requires creating a market for ramp rates leading to same reasons not in scope as above.
Changes to the GB wholesale market design to be more compatible with cross border capacity market	Major change to the GB market – potential long term solution but not in scope with OFGEM or ESO expectations for solution timescales
Change cross border capacity markets	Complex to change and implement, requires holistic European agreement


Possible solutions discussed (In scope)

In scope for GC0154	Justification
Dynamic ramping rate - based on an assessment, NGENSO will decide if any ramp rate limit needs to be amended	Provides a flexible, dynamic ramping solution to ensure ICs are given the max ramp rate possible (reduces imbalance compared to other options). Allow IC to move with system needs and capability providing future system resilience.
Apply a reduced static interconnector ramp rate limit	Provides a simple interim solution to the problem, providing the same ramp rates as BMUs. However, would require reviewing as the system changes and not a future resilience solution
Include current bespoke ramping arrangements, as they are, in the Grid Code BC1.A1.1	Provides compliance within Grid Code, however does not solve the operability problem, so lacks future resilience as security of supply is threatened Maintains current high costs and operational challenges due to IC ramping and aggravates with new IC. Also has the potential to create disparity within generation mix. Least preferred NGENSO option.
Develop additional services with the interconnector and EU Transmission System Operators (TSOs) to mitigate ramping e.g. slow or delay	An additional service could be use in conjunction with other options to meets compliance and operational needs in addition to a commercial service to the IC. However. additional services are in scope of other NGENSO work streams (TCA/Ancillary services)
A dynamic overall ramping rate, is only derived based on a verified market condition if above market solution doesn't work	This would allow more control over ramping across different periods with a pre agreed process. However, this does not provide NGENSO enough time to manage the ramping issues (i.e. if IC gates reduce to 1hr), especially with increasing connecting IC.
Stagger ramping windows so only 1 or 2 ICs are ramping in the same period. this reduces the combined IC ramp rate meaning all ICs could continue to utilise 100MW/min. To reduce the imbalance exposure, ICs could move to a value such that the "area under the curve" is the same volume as the volume in the Market energy block	This would work with our current systems and energy market, by allowing for smoother ramping profile and allow for reduced ramping imbalance costs, however is not a future proofed solution due to the increasing IC numbers and may not fit with European markets.
Codifying the current IC ramping limit of 100 MW/min.	This suits compliance, but does not address the operational issues and therefore not future resilient, due to the increasing number of interconnectors.
Apply current BMU ramping rates to the interconnectors as per BC1.A.1.1	Provides compliance within Grid Code and provides parity across all GB connected generation units. However, is not a future proof solution as we would lose the benefit of faster ramping. This could also lead to an increased cost to GB consumer, due to imbalances created, whilst not being reflective of future generation mix.


Operational Analysis – Costs of repositioning all the plants

Example of 24th March 2022 07:00


Data minute by minute FPNs




BOAs



Demand




ICs




Close to 7:00 am – we can see the highest volume of Bid and Offer Acceptance close to IC ramp before gate change

The high volume of BOA taken has a direct influence on high Energy Imbalance Costs for this Settlement Period as well as Frequency Control Costs


Data SP by SP




Frequency Control Costs



Positive Reserve Costs





Negative Reserve Costs



Operational Analysis – Costs of repositioning all the plants

Example of BOA costs with large Ramping and without large Ramping




Operational Analysis – Costs of repositioning all the plants

Example of BOA costs with large Ramping and without large Ramping

The whole week in March 22


Example Week 21/03 to 27/03



Operational Analysis – Costs of repositioning all the plants

Wind during the week: Low (between 1-3 GW)

Example of BOA costs with large Ramping and without large Ramping



Operational Analysis – Costs of repositioning all the plants

Wind during the week: Low (between 1-3 GW)

Example of BOA costs with large Ramping and without large Ramping

