

OPERATING CODE NO. 9

(OC9)

GRID CODE MODIFICATION GC0156
DATED 18 NOVEMBER 2022
TRACK CHANGED MARKED – COMPARED WITH ORIGINAL

CONTINGENCY PLANNING

CONTENTS

(This contents page does not form part of the Grid Code)

<u>Paragraph No/Title</u>	<u>Page Number</u>
OC9.1 INTRODUCTION.....	2
OC9.2 OBJECTIVE	3
OC9.3 SCOPE.....	4
OC9.4 BLACK START.....	4
OC9.4.1 - OC9.4.4 Total Shutdown And Partial Shutdown.....	4
OC9.4.5 Black Start Stations	4
OC9.5 RE-SYNCHRONISATION OF DE-SYNCHRONISED ISLANDS.....	22
OC9.5.2 Options	23
OC9.5.3 Choice Of Option.....	25
OC9.5.4 Agreeing Procedures.....	26
OC9.6 JOINT SYSTEM INCIDENT PROCEDURE.....	28

OC9.1 INTRODUCTION

Operating Code No.9 ("OC9") covers the following processes and procedures by which The Company in coordination and liaison with Users, will restore the Total System or parts of the System following a Total Shutdown or Partial Shutdown.

OC9.1.1 Black Starts Approach to System Restoration

The implementation of recovery procedures following a ~~_____~~ **Total Shutdown or Partial Shutdown**. **The Company** is obliged through its Licence to achieve **System Restoration** within the parameters of the **Electricity System Restoration Standard**.

Electricity system **Demand** in the "**Electricity System Restoration Standard**", is treated by **The Company** to be the forecast peak **National Demand** which would have occurred within the 24 hour period following the start of the **Total Shutdown or Partial Shutdown** had the **Total Shutdown or Partial Shutdown** not occurred.

Following a **Total Shutdown or Partial Shutdown**, there are two ways in which the **Total System** (or the disconnected part of the **System** in the case of a **Partial Shutdown**) can be re-established. These being a top-down approach using **Local Joint Restoration Plans** or a bottom-up approach using **Distribution Restoration Zone Plans**.

Any **Local Joint Restoration Plan** and/or **Distribution Restoration Zone Plan** comprising common **Network Operator** or **Restoration Service Provider** assets cannot be activated at the same time. However this would not preclude a **Local Joint Restoration Plan** or **Distributed Restoration Zone Plan** from being activated at the same site(s) where there is segregation between them

OC9.1.2 Re-Synchronisation Of Islands

The ~~_____~~ Following the establishment of **Power Islands** (either through the implementation of **Local Joint Restoration Plans** or **Distribution Restoration Zone Plans**), **The Company** will then co-ordinate the **Re-Synchronisation** of parts of the **Total System** which have become **Out of Synchronism** with each other irrespective of whether or not a **Total Shutdown or Partial Shutdown** has occurred.

OC9.1.3 Joint System Incident Procedure

~~The~~ **A Joint System Incident** procedure requires the establishment of ~~a~~ communication ~~route/routes~~ and arrangements between senior management representatives of **The Company** and **Users** involved in, or who may be involved in, an actual or potential serious or widespread disruption to the **Total System** or a part of the **Total System**, which requires, or may require, urgent managerial response, day or night, but which does not fall within the provisions of OC9.1.4.

OC9.1.4 Relevant Transmission Licensees shall comply with OC9.4 and OC9.5 as provided for in STCPXXX and any relevant Local Joint Restoration Plan or OC9 De-Synchronised Island Procedure where and to the extent that such matters apply to them.

OC9.1.5 Directions Issued by the Secretary of State

It should be noted that under section 96 of the **Act**, the **Secretary of State** may give directions to **The Company** and/or any **Generator** and/or any **Supplier**, for the purpose of "mitigating the effects of any civil emergency which may occur" (ie. for the purposes of planning for a civil emergency); a civil emergency is defined in the **Act** as "any natural disaster or other emergency which, in the opinion of the **Secretary of State**, is or may be likely to disrupt electricity supplies". Under the Energy Act 1976, the **Secretary of State** has powers to make orders and give directions controlling the production, supply, acquisition or use of electricity, where an Order in Council under section 3 is in force declaring that there is an actual or imminent emergency affecting electricity supplies. In the event that any such directions are given, or orders made under the **Energy Act 1976**, the provisions of the **Grid Code** will be suspended in so far as they are inconsistent with them.

~~OC9.1.5 The Company shall procure that Relevant Transmission Licensees shall comply with OC9.4 and OC9.5 and any relevant Local Joint Restoration Plan or OC9 De-Synchronised Island Procedure where and to the extent that such matters apply to them.~~

OC9.2 OBJECTIVE

The overall objectives of **OC9** are:

OC9.2.1 To achieve, ~~as far as possible, restoration~~ the requirements of the **Total Electricity System** and associated **Demand** in the shortest possible time **Restoration Standard**, taking into account ~~Power Station~~ the capability of **Restoration Service Providers Plant and Apparatus** as well as other **Users' Plant and Apparatus** capabilities, including **Embedded Generating Units**, and **External Interconnections** and the operational constraints of the **Total System**.

~~OC9.2.2~~ OC9.2.2 **The Company** in agreement with **Network Operators, Transmission Licensees** and **Restoration Service Providers** will initiate the restoration process through the activation of **Local Joint Restoration Plans** and/or **Distribution Restoration Zone Plans** followed by the subsequent reconnection and expansion of **Power Islands**. This will require **The Company, Network Operators, Relevant Transmission Licensees** and **Restoration Service Providers** to work collectively together such that there is sufficient generation available which, via switching on the **Total System**, can be used to restore 60% of **National Demand** within 24 hours across all **System Restoration Regions**. OC9.2.3 To achieve the **Re-Synchronisation** of parts of the **Total System** which have become **Out of Synchronism** with each other.

OC9.2.34 To ensure that communication routes and arrangements are available to enable senior management representatives of **The Company** and **Users**, who are authorised to make binding decisions on behalf of **The Company** or the relevant **User**, as the case may be, to communicate with each other in the situation described in OC9.1.3.

OC9.2.45 To describe the role that ~~in respect of Transmission Systems~~ **The Company, Relevant Transmission Licensees** and **Network Operators** may have in the restoration processes as detailed in the relevant **OC9 De-Synchronised Island Procedures** ~~and~~ **Local Joint Restoration Plans** and **Distribution Restoration Zone Plans**.

OC9.2.56 To identify and address as far as possible the events and processes necessary to enable the restoration of the **Total System**, after a **Total Shutdown** or **Partial Shutdown**. This is likely to require the following key processes to be implemented, typically, but not necessarily, in the order given below:

- (i) ~~(i)~~ Selectively implement **Local Joint Restoration Plans**
- (ii) ~~(ii)~~ Selectively implement **Distribution Restoration Zone Plans** in conjunction with **Network Operators**
- (iii) Expand **Power Islands** to supply **Power Stations**
- ~~(iiiiv)~~ Expand and merge **Power Islands** leading to **Total System** energisation
- ~~(ivv)~~ Selectively reconnect **Demand**

- (vi) Facilitate and co-ordinate returning the **Total System** back to normal operation
- (vii) Resumption of the **Balancing Mechanism** if suspended in accordance with the provisions of the **BSC**.

OC9.3 SCOPE

OC9.3.1 **OC9** applies to **The Company** and to **Users**, which in **OC9** means:-

- (a) **Generators**;
- (b) **Network Operators**; ~~and~~
- (c) **Non-Embedded Customers**;
- (d) HVDC System Owners
- (e) DC Converter owners including DC Converter Station owners
- (f) Restoration Service Providers

OC9.3.2 The procedure for the establishment of emergency support/contingency planning between **The Company** and **Externally Interconnected System Operators** is set out in the **Interconnection Agreement** with each **Externally Interconnected System Operator**.

OC9.3.3 In respect of **Transmission Systems**, OC9.4 and OC9.5 also apply to **Relevant Transmission Licensees**.

OC9.4 ~~BLACK START~~SYSTEM RESTORATION

Total Shutdown ~~And~~ and Partial Shutdown

OC9.4.1 A "**Total Shutdown**" is the situation existing when all generation has ceased and there is no electricity supply from **External Interconnections**. Therefore, the **Total System** has shutdown with the result that it is not possible for the **Total System** to begin to function again without ~~The Company's~~ Company's directions relating to a Black Start System Restoration.

OC9.4.2 A "**Partial Shutdown**" is the same as a **Total Shutdown** except that all generation has ceased in a separate part of the **Total System** and there is no electricity supply from **External Interconnections** or other parts of the **Total System** to that part of the **Total System**. Therefore, that part of the **Total System** is shutdown with the result that it is not possible for that part of the **Total System** to begin to function again without **The Company's** directions relating to a Black Start System Restoration.

OC9.4.3 During a **Total Shutdown** or **Partial Shutdown** and during the subsequent recovery, the **Licence Standards** may not apply and the **Total System** may be operated outside normal voltage and **Frequency** standards.

OC9.4.4 In a **Total Shutdown** and in a **Partial Shutdown** and during the subsequent recovery, it is likely to be necessary for **The Company** to issue **Emergency Instructions** in accordance with BC2.9.

OC9.4.5 ~~Black Start~~Contribution to System Restoration

The Company will initially start to restore the System following a Total Shutdown or Partial Shutdown by issuing instructions directly to Restoration Service Providers through one or more Local Joint Restoration Plans as provided for in OC9.4.5.1 and by instructing Network Operators to activate one or more Distribution Restoration Zone Plans as provided for in OC9.4.5.2

OC9.4.5.1 ~~Black Start~~Local Joint Restoration

OC9.4.5.1.1 Local Joint Restoration Plans are dependent upon Anchor Restoration Service Providers are registered pursuant to the Bilateral Agreement as having who upon instruction from The Company (or Relevant Transmission Licensee in Scotland), have the capability to **Start-Up** from **Shutdown** and to energise a part of the **Total System**, or be **Synchronised** to the **System**, upon instruction from The Company within two hours, without an external electrical power supply ("**Black Start Capability**"). Local Joint Restoration Plans may also be dependent upon Top Up Restoration Service Providers.

OC9.4.5.1.2 For each ~~Black Start Station~~ and ~~Black Start HVDC System~~, a Local Joint Restoration Plan will be produced jointly by The Company, the Relevant Transmission Licensees, relevant ~~Black Start Restoration Service Provider~~ Providers and relevant Network Operator Operators in accordance with the provisions of OC9.4.7.12. The Local Joint Restoration Plan will detail the agreed method and procedure by which a Genset at a ~~Black Start Station~~ (possibly with other Gensets at that ~~Black Start Station~~) and ~~Black Start HVDC Systems~~ Anchor Plant will energise part of the **Total System** and, in combination with Top Up Restoration Plant (where necessary) to meet complementary local **Demand** so as to form a **Power Island**.

OC9.4.5.3 In respect of ~~Scottish Transmission Systems~~, a Local Joint Restoration Plan may cover more than one ~~Black Start Station~~ or ~~Black Start HVDC System~~ and may be produced with and include obligations on ~~Relevant Scottish Transmission Licensees~~, ~~Generators~~ responsible for Gensets not at a ~~Black Start Station~~ and other Users including ~~HVDC System Owners~~ and ~~DC Converter Station Owners~~...

OC9.4.6 Black Start Situation

OC9.4.5.2 Distribution Restoration Zones

OC9.4.5.2.1 Distribution Restoration Zone Plans are dependent upon Anchor Restoration Service Providers who, upon instruction from relevant Network Operators, have the capability to **Start-Up** from **Shutdown** and to energise a part of a Network Operator's System, or be **Synchronised** to a Network Operator's System, within eight hours, without an external electrical power supply. A Distribution Restoration Zone Plan may also be dependent upon Top Up Restoration Service Providers.

OC9.4.5.2.2 For each Distribution Restoration Zone, a Distribution Restoration Zone Plan will be produced jointly by the Network Operator, The Company, relevant Transmission Licensee, and Restoration Service Providers in accordance with the provisions of OC9.4.7.6.2. The Distribution Restoration Zone Plan will detail the agreed method and procedure by which an Anchor Plant will energise part of the **Total System** in combination with Top Up Restoration Plant (where necessary) to meet complementary local **Demand** so as to form a **Power Island**.

OC9.4.6 Situaitons requiring System Restoration

In the event of a **Total Shutdown** or **Partial Shutdown**, The Company will, as soon as reasonably practical, inform **Users** (or, in the case of a **Partial Shutdown**, **Users** which in The Company's opinion need to be informed) and the **BSCCo** that a **Total Shutdown**, or, as the case may be, a **Partial Shutdown**, exists and that The Company intends to implement a Black Start System Restoration. The Company shall (as soon as is practicable) determine, in its reasonable opinion, the time and date with effect from which the **Total Shutdown** or **Partial Shutdown** commenced and notify the **BSCCo** of that time and date.

In the event of a **Total Shutdown** and following such notification, in accordance with the provisions of the **BSC**, the **BSCCo** will determine the **Settlement Period** with effect from which the **Balancing Mechanism** is suspended.

In the event of a **Partial Shutdown** and following such notification, the **Balancing Mechanism** will not be suspended until such time and date that the **Market Suspension Threshold** has been met, or deemed to have been met, in accordance with the provisions of the **BSC**. The Company shall carry out the monitoring activities required by paragraph G3.1 of the **BSC**.

Following determination by The Company pursuant to its obligations under the **BSC** that the

Market Suspension Threshold has been met, or deemed to have been met, **The Company** shall (as soon as practicable) inform the **BSCCo** of that time and date at which the **Market Suspension Threshold** was met, or deemed to have been met, and the **BSCCo** will determine the **Settlement Period** in accordance with the provisions of the **BSC** with effect from which the **Balancing Mechanism** will be suspended.

Should **The Company** determine that the **Total System** is capable of returning to normal operation without meeting the **Market Suspension Threshold**, **The Company** will follow the procedure given in **OC9.4.7.9**.

The ~~Black Start~~**System Restoration** will conclude with effect from the time and date determined in accordance with **OC9.4.7.10**.

In respect of **Scottish Transmission Systems**, in exceptional circumstances, as specified in the **Local Joint Restoration Plan**, **SPT** or **SHETL**, may invoke such **Local Joint Restoration Plan** for its own **Transmission System** and **Scottish Offshore Transmission Systems** connected to it and operate within its provisions. Scottish Transmission Licensees, may instruct relevant Network Operators to activate one or more Distribution Restoration Zone Plans.

OC9.4.7 Black StartSystem Restoration Procedure

OC9.4.7.1 The procedure necessary for a recovery from a **Total Shutdown** or **Partial Shutdown** is known as a "Black Start"-System Restoration. The procedure for a **Partial Shutdown** is the same as that for a **Total Shutdown** except that it applies only to a part of the **Total System**. It should be remembered that a **Partial Shutdown** may affect parts of the **Total System** which are not themselves shutdown.

OC9.4.7.2 The complexities and uncertainties of recovery from a **Total Shutdown** or **Partial Shutdown** require that **OC9** is sufficiently flexible in order to accommodate the full range of **User's Plant** and **Apparatus** and **Total System** characteristics and operational possibilities, and this precludes the setting out in the **Grid Code** itself of concise chronological sequences. The overall strategy will, in general, include the overlapping phases of ~~establishment~~the use of Genset(s)-generating Plant, at an isolated **Power Station**, or isolated **HVDC System** or isolated **DC Converter Station**, together with complementary local **Demand**, termed "**Power Islands**", a step by step integration of these **Power Islands** into larger sub-systems which includes utilising the procedures in **OC9.5** (**Re-Synchronisation of De-Synchronised IslandPower Islands**) and eventually re-establishment of the complete **Total System**. This process is illustrated digramatically in Appendix 2 of this OC9.

The Company Instructions

OC9.4.7.3 ~~The procedures for a Black Start will, therefore, be those specified by The Company at the time will determine and instruct relevant Users to start System Restoration.~~ These instructions will normally recognise any applicable **Local Joint Restoration Plan**, ~~Users and/or Distribution Restoration Zone Plan.~~ User's shall abide by **The Company's** instructions during a Black Start**System Restoration** situation, even if these conflict with the general overall strategy outlined in **OC9.4.7.2** or any applicable **Local Joint Restoration Plan**, ~~and/or Distribution Restoration Zone Plan.~~ The Company's and/or Network Operators instructions may (although this list should not be regarded as exhaustive) be to ~~a Black Start Station or Black Start HVDC System:-~~

- (a) Restoration Service Providers relating to the ~~commencement~~start of supplying **Active Power**, ~~to~~ and subsequent pick up of Demand;
- (b) a **Network Operator** or **Non-Embedded Customer** relating to the restoration of **Demand**, ~~and to:-~~
- (c) a ~~Power Station~~Generator or **HVDC System Owner** or **DC Converter Station owner** relating to the preparations for starting to ~~preparation for commencement of supplying supply~~ **Active Power** when an external power supply is made available to it, ~~and in each case:-~~
- (d) a Network Operator to activate a Distribution Restoration Zone Plan.

Each of the above cases may include the requirement to undertake switching.

In respect of **Scottish Transmission Systems**, **SPT** and **SHETL** will act on **The Company's** behalf in accordance with its duties under the relevant **Local Joint Restoration Plan**, **Scottish Users** or **Distribution Restoration Zone Plan**. **Restoration Service Providers in Scotland** shall abide by **SPT's** or **SHETL's** instructions given in accordance with the **Local Joint Restoration Plan** or **Distribution Restoration Zone Plan** during a **Black Start System Restoration** situation.

OC9.4.7.4

(a) ~~Black Start~~ **System Restoration** following a **Total Shutdown** or where the **Balancing Mechanism** has been suspended following a **Partial Shutdown**

During ~~a Black Start situation~~ **System Restoration** where the **Balancing Mechanism** has been suspended, all instructions to **Users** will be deemed to be **Emergency Instructions** under BC2.9.2.2 (iii). All such **Emergency Instructions** will recognise any differing operational capabilities (however termed) set out in the relevant **Ancillary Services Agreement** in preference to the declared operational capability as registered pursuant to **BC1** (or as amended from time to time in accordance with the **BC**).

Instructions issued to **Network Operators** in England and Wales to activate a **Distribution Restoration Zone Plan** to energise a **Distribution Restoration Zone** will be issued by **The Company** to **Network Operators** as **Emergency Instructions**. **Network Operators** will then proceed in accordance with the provisions of the **Distribution Restoration Zone Plan**. Such instructions will be deemed to be **Emergency Instructions** under BC2.9.2.2 (iv). The **Network Operator** will be responsible for the operation of the **Distribution Restoration Zone** which will take into account the capabilities of **Restoration Service Providers' Plant** and other **Plant** and **Apparatus** within the **Network Operator's System** including the **Distribution Restoration Zone Control System**. Such instructions would be pursuant to the terms of the **Distribution Restoration Zone Plan**. In Scotland, **Scottish Transmission Licensees** will issue instructions to **Users** in Scotland (which shall be deemed to be **Emergency Instructions**) to relevant Scottish **Network Operators** to activate a **Distribution Restoration Zone Plan**.

(b) ~~Black Start System Restoration~~ following a **Partial Shutdown** where the **Balancing Mechanism** has not been suspended

i.) Local Joint Restoration Plans

Instructions in relation to **Anchor Power Stations** and/or **Anchor HVDC Systems** and/or **Anchor DC Converter Stations Owners** and to **Network Operators** and **Top Up Restoration Service Providers** which are part of an activated **Local Joint Restoration Plan** will be deemed to be **Emergency Instructions** under BC2.9.2.2 (iv) and will recognise any differing operational capabilities (however termed) set out in the relevant **Ancillary Services Agreement** in preference to the declared operational capability as registered pursuant to **BC1** (or as amended from time to time in accordance with the **BC**). For the purposes of these instructions the **Black Start System Restoration** will be an emergency circumstance under BC2.9.

In Scotland, **Gensets** or **HVDC Systems** or **DC Converter Station** that are not at **Black Start Stations** or **Black Start HVDC Systems**, but which are part of a **Local Joint Restoration Plan**, may issue instructions to **Restoration Service Providers** may be instructed in accordance with the provisions of that **Local Joint Restoration Plan**.

(b) ~~Black Start~~ following a **Partial Shutdown** where the **Balancing Mechanism** has not been suspended

During a **Black Start** situation where the **Balancing Mechanism** has not been suspended, instructions in relation to **Black Start Stations** and to **Network Operators, Black Start HVDC Systems** which are part of an invoked **Local Joint Restoration Plan** will (unless **The Company** specifies otherwise) be deemed to be **Emergency Instructions** under BC2.9.2.2 (iv) and will recognise any differing **Black Start** operational capabilities (however termed) set out in the relevant **Ancillary Services Agreement** in preference to the declared operational capability or to **User's** at subsequent stages of the wider restoration process as registered pursuant to **BC1** (or as amended from time to time in accordance with the **BC**). For the purposes of these instructions the **Black Start** will be an emergency circumstance under BC2.9.

During a **Black Start** situation where the **Balancing Mechanism** has not been suspended, **The Company** may issue instructions to **Users** other than **Black Start Stations** and **Network Operators** which are part of an invoked **Local Joint Restoration Plan** provided for in **OC9.4.7.8 – OC9.4.7.12**. Such instructions would be **Emergency Instructions** pursuant to BC2.9.1.2(e)(i) subject to the requirements of BC2.9.2.2 being met.

- ii.) In Scotland, **Gensets** and **HVDC Systems** or **DC Converter Station** that are not at **Black Start Stations** or **Black Start HVDC Systems**, but which are part of an invoked **Local Joint Distribution Restoration Plan**, may be instructed **Zone Plans**

During a **System Restoration** where the **Balancing Mechanism** has not been suspended, **The Company** may issue instructions to **Network Operators** in England and Wales to activate a **Distribution Restoration Zone Plan** to energise one or more **Distribution Restoration Zones** in accordance with the provisions of that **Local Joint the Distribution Restoration Zone Plan**. Such instructions will be deemed to be **Emergency Instructions** under BC2.9.2.2 (iv). The **Network Operator** will be responsible for the operation of the **Distribution Restoration Zone** which will take into account the capabilities of **Restoration Service Providers' Plant** and other **Plant and Apparatus** within the **Network Operator's System** including the **Distribution Restoration Zone Control System**. Such instructions would be pursuant to the terms of the **Distribution Restoration Zone Plan**.

(e) In Scotland, **Relevant Transmission Licensee's** may issue instructions (which would be deemed to be **Emergency Instructions**) to **Scottish Network Operators**, to activate on one or more **Distribution Restoration Zone Plans**.

OC9.4.7.5 Requirements to inform **The Company** where a **Genset/Generating Unit, HVDC System** or **DC Converter** cannot operate within its safe operating limits during the **Demand** restoration process

OC9.4.7.5.1 If during the **Demand** restoration process any **GensetGenerating Unit** or **HVDC System** or **DC Converter Station** cannot, because of the **Demand** being experienced, keep within its safe operating parameters, the **Black StartRestoration Service Provider** shall, unless a **Local Joint Restoration Plan** or **Distribution Restoration Zone Plan** is in operation, inform **The Company** and relevant **Network Operator**. **The Company** or relevant **Network Operator** (as appropriate) will, where possible, either instruct **Demand** to be altered or will re-configure the **National Electricity TransmissionTotal System** or will instruct a **User** to re-configure its **System** in order to alleviate the problem being experienced by the **GensetGenerating Unit** or **HVDC System** or **DC Converter Station**. If a **Local Joint Restoration Plan** or **Distribution Restoration Zone Plan** is in operation, then the arrangements set out therein shall apply. However, **The Company** and/or **Network Operator** accepts that any decision to keep a **GensetGenerating Unit** or **HVDC System** or **DC Converter Station** operating, if outside its safe operating parameters, is one for the **Black StartRestoration Service ProvidersProvider** concerned alone and accepts that the **Black StartRestoration Service Provider** may change output on that **GensetGenerating Unit** or **HVDC System** or **DC Converter Station** if it believes it is necessary for safety reasons (whether relating to personnel or **Plant** and/or **Apparatus**). If such a change is made without prior notice, then the **Black StartRestoration Service Provider** shall inform **The Company** and/or **Network Operator** as soon as reasonably practical (unless a **Local Joint Restoration Plan** and/or **Distribution Restoration Zone Plan** is in operation in which case the arrangements set out therein shall apply). In the case of a **Distribution Restoration Zone**, where the **Network Operator** experiences situations where any **Generating Unit** or **HVDC System** or **DC Converter Station** is unable to keep within safe operating parameters and this is likely to affect the integrity and progression of the **Distribution Restoration Zone**, the **Network Operator** shall inform **The Company** without delay.

Embedded Power Stations

OC9.4.7.56 Without prejudice to the provisions of **OC9.4.7.8**, and only in the case of **Local Joint Restoration Plans** or where a **Distribution Restoration Zone** has been terminated, **Network Operators** with **Embedded Power Stations** or **Embedded HVDC Systems** or **Embedded DC Converter Stations** will comply with any directions of **The Company** to restore **Demand** to be met by the **Embedded Power Stations**, **Embedded HVDC Systems** or **Embedded DC Converter Stations**. **OC9.4.7.7 Local Joint Restoration Plan and Distribution Restoration Zone Plan Establishment**

Local Joint

OC9.4.7.7.1 Restoration Plan ~~operation~~ Establishment

OC9.4.7.6 (a) The following ~~provisions~~ process shall apply in relation to for the establishment of **Restoration Plans**:

- a) For a **Local Joint Restoration Plan**. As set out in **OC9.4.7.3**, **The Company** will identify the need to introduce or modify a **Local Joint Restoration Plan** and coordinate with the relevant parties as required in this **OC9.4.5.7.1**.
- b) For a **Distribution Restoration Zone Plan** where **The Company** and a relevant **Network Operator** agree that introducing or modifying a **Distribution Restoration Zone** may be beneficial, **The Company**, the **Relevant Transmission Licensee** (where appropriate) and the **Network Operator** shall explore the possibility of establishing a **Distribution Restoration Zone Plan** as required in this **OC9.4.5.7.1**.
- c) The **Company**, the **Relevant Transmission Licensee** (where appropriate) and the **Network Operator** will discuss and agree the detail of a **Restoration Plan** as soon as reasonably practicable after the potential requirement for a **Restoration Plan** is identified. This may involve discussions between relevant potential **Restoration Service Providers**, **The Company** and the **Network Operator**.

- d) For a **Distribution Restoration Zone Plan** an initial feasibility assessment carried out jointly by **The Company** and **Network Operator** may result in **The Company** running a procurement / tender process. If after discussions or analysis, **The Company**, the **Relevant Transmission Licensee** (where appropriate) and **Network Operator** agree a **Distribution Restoration Zone Plan** is not viable, then no further work to develop the **Distribution Restoration Zone Plan** needs to be carried out.
- e) Each **Restoration Plan** will be in relation to a specific **Anchor Plant** and may include one of more **Top Up Restoration Plants**.
- f) The preparation of each **Restoration Plan** shall include a check whether any network assets cited in each **Restoration Plan** are included in any other **Restoration Plan**, and if so, all the **Local Joint Restoration Plans** or **Distribution Restoration Zone Plans** containing common assets shall include a specific step that prohibits more than one of any of these **Restoration Plans** from being activated at any one point in time.
- g) The **Restoration Plan** will record which **Restoration Service Providers** and which **Restoration Service Provider's** sites are covered by the **Restoration Plan** and set out what is required from **The Company**, the **Network Operator**, **Relevant Transmission Licensees** and each **Restoration Service Provider** should a **System Restoration** situation arise.
- h) Each **Local Joint Restoration Plan** shall be prepared by **The Company** and each **Distribution Restoration Zone Plan** shall be prepared by the relevant **Network Operator**. In both cases the **Restoration Plan** will be agreed between **Network Operator**, **The Company**, the **Relevant Transmission Licensee** and relevant **Restoration Service Providers** to reflect the above discussions.
- i) Each page of the **Restoration Plan** shall bear a date of issue and the issue number.
- j) When a **Restoration Plan** has been prepared, it shall be sent to all parties involved for confirmation of its accuracy.
- k) The **Restoration Plan** shall then (if its accuracy has been confirmed) be signed on behalf of **The Company**, the **Network Operator**, each **Relevant Transmission Licensee** and each relevant **Restoration Service Provider** by way of written confirmation of its accuracy.
- l) Once agreed under this **OC9.4.7.5.1**, the procedure will become a **Restoration Plan** under the Grid Code and (subject to any change pursuant to this OC9) will apply between **The Company**, the **Network Operator**, the **Relevant Transmission Licensees** and the relevant **Restoration Service Providers** as if it were part of the Grid Code.
- m) A copy of each signed **Local Joint Restoration Plan** will be distributed by **The Company** to the **Network Operator**, each **Relevant Transmission Licensee** and to each **Restoration Service Provider** who is a party to it accompanied by a note indicating the date of implementation.
- n) A copy of each signed **Distribution Restoration Zone Plan** will be distributed by the **Network Operator** to **The Company**, each **Relevant Transmission Licensee** and to each **Restoration Service Provider** who is a party to it accompanied by a note indicating the date of implementation.
- o) **The Company**, **Network Operators**, the **Relevant Transmission Licensees** and **Restoration Service Providers** must make the **Restoration Plan** readily available to the relevant operational staff.
- p) Each **Restoration Plan** will include the test criteria to be satisfied by each **Restoration Service Provider's Plant and Apparatus** when subject to the testing requirements of **OC5.7.4**.

- g) If any party to a **Restoration Plan**, becomes aware that a change is needed to that **Restoration Plan**, it shall in the case of **Local Joint Restoration Plan** contact **The Company** or in the case of a **Distribution Restoration Zone Plan**, the **Network Operator** to initiate a discussion between **The Company**, or the **Network Operator** and the relevant parties to seek to agree the relevant change. The principles applying to establishing or modifying a **Restoration Plan** under this **OC9.4.7.5.1** shall apply to such discussions and to any consequent changes.

OC9.4.7.8 Restoration Plan Testing

The Company, Relevant Transmission Licensees, the Network Operator and the relevant **Restoration Service Providers** shall conduct regular joint exercises of the **Restoration Plan** to which they are parties. The objectives of such exercises include:

- To test the effectiveness of the **Restoration Plan**;
- To provide for joint training of the parties in respect of the **Restoration Plan**;
- To maintain the parties' awareness and familiarity of the **Restoration Plan**;
- To promote understanding of each party's role under the **Restoration Plan**; and
- To identify any improvement areas which should be incorporated into the **Restoration Plan**. **The Company** will propose to the parties of a **Restoration Plan** a date for the exercise to take place, to be agreed with the other parties. All the **Restoration Plan** parties will jointly share the task of planning, preparing, participating in and facilitating the exercises, which will normally be in desktop format or as otherwise agreed. The precise timing of the exercise for each **Restoration Plan** will be agreed by all parties, but will not be less than once every 3 years. These exercises shall be run as part of the wider assurance activities as provided for under **OC5.7.4**

OC9.4.7.9 Restoration Plan Provisions

The following provisions in this **OC9.4.7.5.3** apply in relation to a **Restoration Plans**. Any **Local Joint Restoration Plan** and/or **Distribution Restoration Zone Plan** comprising common **Network Operator** or **Restoration Service Provider** assets cannot be activated at the same time. However this would not preclude a **Local Joint Restoration Plan** or **Distributed Restoration Zone Plan** from being activated at the same site(s) where there is segregation between them.

- (a) For **Local Joint Restoration Plans** **The Company** is the lead operator; for **Distribution Restoration Zone Plans**, the **Network Operator** is the lead operator.
- (b) Where the lead operator, issues instructions which conflict with a **Local Joint Restoration Plan**, ~~In such cases,~~ these instructions will take precedence over the requirements of the **Local Joint Restoration Plan**, ~~(as set out in~~ **OC9.4.7.3**
- i.) When issuing such instructions, ~~The Company shall~~ the lead operator will state whether or not it wishes the remainder of the **Local Joint Restoration Plan** to apply. ~~If, notwithstanding that The Company~~ Where the lead operator has stated that it wishes the remainder of the **Local Joint Restoration Plan** to apply, the ~~Black Start Service Provider or other parties to the relevant Network Operator consider that The Company's instructions mean~~ plan may give notice that it is not possible to operate the **Local Joint Restoration Plan** as modified by those instructions, any of them may give notice to **The Company** the lead operator and the other parties to the **Local Joint Restoration Plan** to this effect and **The Company** plan
- ii.) The lead operator shall immediately consult with all parties to the **Local Joint Restoration Plan**. Unless all parties to the **Local Joint Restoration Plan** reach an agreement ~~forthwith~~ as to how the **Local Joint Restoration Plan** shall operate in those circumstances, operation in accordance with the **Restoration Plan** will terminate and parties will be relieved of their obligations under the **Restoration Plan** in accordance with **OC9.4.7.5.3(e)** below.

- iii.) The preparation of each **Distribution Restoration Zone Plan** shall include a check whether any network assets cited in a **Local Joint Restoration Plan** or another **Distribution Restoration Zone Plan** are included in the plan, and if so, all the **Local Joint Restoration Plans** or **Distribution Restoration Zone Plans** containing common assets shall include a specific step that prohibits more than one of any of these plans from being activated at any one point in time
- (c) The lead operator will advise other relevant operators of the requirement to switch their **User Systems** to segregate their **Demand** and to carry out such other actions as set out in the **Restoration Plan**. The relevant operator will then operate in accordance with the provisions of the **Restoration Plan**.
- (d) Following notification from the **Restoration Service Provider** with the **Anchor Plant** that the **Anchor Plant** is ready to accept load, the lead operator will instruct the **Anchor Restoration Service Provider** to energise part of the **Total System**. The **Anchor Restoration Service Provider** and the other relevant operators (if any) will then, in accordance with the requirements of the **Restoration Plan**, establish communication and agree the output of their **Plant** and the connection of **Demand** so as to establish a **Power Island**. During this period, the **Anchor Restoration Service Provider** together with any **Top Up Restoration Service Providers** will be required to regulate the output of their **Restoration Service Providers' Plant** and **Apparatus** to the **Demand** prevailing in the **Power Island** in which they are situated, on the basis that they will (where practicable) seek to maintain the **Target Frequency**. **Restoration Service Providers' Plant** and **Apparatus** will (where practical) also seek to follow the requirements relating to **Reactive Power** (which may include the requirement to maintain a target voltage) set out in the **Restoration Plan**.
- (e) Operation of the **Restoration Plan** shall be terminated by the lead operator either when:
 - i.) the **Restoration Plan** has been successfully implemented and the resulting **Power Island** is ready to be synchronised to another **Power Island** following instruction from **The Company**. In this case the arrangements for synchronising the **Power Island** will be set out in the **Restoration Plan**; or
 - ii.) the **Restoration Plan** has not been / is not being successfully implemented. In this circumstance, provided for in OC9.4.7.6.2(a), if an agreement is not reached on whether or not to apply the remainder of the plan or if **The Company** confirms to the other parties that it does not wish the remainder of the **Restoration Plan** to apply, the **Restoration Plan** shall be terminated. In this case **The Company** and the **Network Operator** in conjunction with the **Restoration Service Providers** shall agree and implement the most appropriate course of action which should aim to maintain supplies to as many customers as possible.

In both cases the lead operator shall notify all parties to the **Restoration Plan** accordingly.

OC9.4.7.10 **Local Joint Restoration Plan** will terminate Operation

(b) Following a **Total** or **Partial Shutdown** the following shall apply:

OC9.4.7.10.1 Where **The Company**, as part of a **Black Start System Restoration**, has given an instruction to a **Black Start Restoration Service Provider** to initiate **Start-Up**, the relevant **Genset(s)** at the **Black Start Station** or **Black Start HVDC System Restoration Service Provider's Plant** and **Apparatus** will prepare to **Start-Up** their Plant in accordance with the **Local Joint Restoration Plan**.

(c) OC9.4.7.10.2 **The Company** will advise the relevant **Network Operator** of the requirement to switch its **User System** so as to segregate its **Demand** and to carry out such other actions as set out in the **Local Joint Restoration Plan**. The relevant **Network Operator** will then operate in accordance with the provisions of the **Local Joint Restoration Plan**.

(d) OC9.4.7.10.3 **The Company** will ensure that switching carried out on the **National Electricity Transmission System** and other actions are as set out in the **Local Joint Restoration Plan**.

~~(e)~~OC9.4.7.10.4

Following notification from the **Black Start Anchor Restoration Service Provider** that ~~the Black Start Station or Black Start HVDC System~~ **their Anchor Plant** is ready to accept load, **The Company** will instruct the **Black Start Service Anchor Restoration Service Provider** to energise part of the **Total System**. The **Black Start Anchor Restoration Service Provider** and the relevant **Network Operator** will then, in accordance with the requirements of the **Local Joint Restoration Plan**, establish communication and agree the output of the relevant **Genset(s) and/or HVDC System and/or DC Converter Station Anchor Plant** and the connection of **Demand** so as to establish a **Power Island**. As part of establishing a Power Island The Company may instruct one or more Top Up Restoration Service Providers to synchronise their Plant to the System to contribute to the increase in Demand. During this period, ~~the Black Start Restoration Service Provider~~ **Providers** will be required to regulate the output of ~~the their relevant Black Start Station or Black Start HVDC System Plant~~ to the **Demand** prevailing in the **Power Island** in which it is situated, on the basis that it will (where practicable) seek to maintain the **Target Frequency**. ~~The Genset(s) at the Black Start Station or Black Start HVDC System~~ **The Restoration Service Provider's Plant and Apparatus** will (where practical) also seek to follow the requirements relating to **Reactive Power** (which may include the requirement to maintain a target voltage) set out in the **Local Joint Restoration Plan**.

- (f) Operation in accordance with the **Local Joint Restoration Plan** will be terminated by **The Company** (by notifying the relevant **Users Restoration Service Providers**) prior to connecting the **Power Island** to other **Power Islands** ~~(other than, in Scotland, as allowed for in the Local Joint Restoration Plan)~~, or to the **User System** of another **Network Operator**, or to the synchronising of **Gensets Generating Units** at other **Power Stations** or **HVDC Systems** or **DC Converter Station** ~~(other than, in Scotland, those forming part of the Local Joint Restoration Plan)~~. **Stations**. Operation in accordance with the **Local Joint Restoration Plan** will also terminate in the circumstances provided for in **OC9.4.7.6(a)** if an agreement is not reached or if **The Company** states that it does not wish the remainder of the **Local Joint Restoration Plan** to apply. **Users** will then comply with the **Bid-Offer Acceptances** or **Emergency Instructions** of **The Company**.

~~(g)~~OC9.4.7.11 Distribution Restoration Zone Operation

Following a **Total** or **Partial Shutdown** the following shall apply:

OC9.4.7.11.1 In **England and Wales** a **Distribution Restoration Zone** is activated where **The Company** issues **Emergency Instructions** to the relevant **Network Operators** to re-energise a section of their disconnected **System** using relevant **Restoration Service Provider's Plant and Apparatus** to form one or more **Power Islands**. In **Scotland**, ~~Gensets or HVDC Systems or DC Converter Station~~ included in a **Local Joint Restoration Plan**, but not at a **Black Start Station** the **Relevant Transmission Operator** will instruct the relevant **Network Operator**, following an instruction to do so from **The Company**.

OC9.4.7.11.2 It is imperative that where a **Network Operator** has a **Distribution Restoration Zone Plan** available for use, the **Anchor Plant** forming part of that **Distribution Restoration Zone** is capable of satisfying the requirements of **CC.6.3.5, CC.7.10, CC.7.11 and CC.8.1** or ~~Black Start HVDC System~~, will operate **ECC.6.3.5, ECC.7.10, ECC.7.11 and ECC.8.1** as appropriate, and that the **Network Operator** has confirmed to **The Company** that the **Distribution Restoration Zone Plan** is ready to be activated. **Network Operators** shall be required of satisfying the requirements of **CC.6.4.6** or **ECC.6.4.6** as applicable.

OC9.4.7.11.3 Where **The Company** wishes a **Network Operator** to activate a **Distribution Restoration Zone Plan**, **The Company** will issue an **Emergency Instruction** to that **Network Operator** for it to activate the relevant **Distribution Restoration Zone Plan**. In **Scotland** the instruction to a **Scottish Network Operator** to activate a **Scottish Distribution Restoration Zone Plan** would be undertaken by the relevant **Scottish Transmission Licensee**. For the avoidance of doubt, **The Company** will issue instructions to initiate **System Restoration** in **Scotland** via **STCP 06-1** which includes arrangements for the activation of **Scottish Distribution Restoration Zone Plans**.

- OC9.4.7.11.4 Upon receipt of an **Emergency Instruction** from **The Company** (or instruction from the relevant **Scottish Transmission Licensee**), the **Network Operator** will confirm and acknowledge receipt in accordance with the requirements of the BC2.9.2 and start initiating the process to activate the **Distribution Restoration Zone Plan** in accordance with the **Distribution Restoration Zone Plan**.
- OC9.4.7.11.5 Upon receipt of the **Emergency Instruction** from **The Company** (or instruction from the relevant **Scottish Transmission Licensee**) to the **Network Operator** to activate a **Distribution Restoration Zone Plan** as provided for in **OC9.4.7.7.4**, all instructions to relevant **Restoration Service Providers** party to the **Distribution Restoration Zone Plan** will be issued by the **Network Operator**.
- OC9.4.7.11.6 The operation of the **Distribution Restoration Zone** will then continue in accordance with **OC9.4.7.7** and the **Distribution Restoration Zone Plan** until the **Distribution Restoration Zone Plan** is terminated as provided for in that **Distribution Restoration Zone Plan**. Following synchronisation to another **Power Island**, the **Distribution Restoration Zone Plan** will be terminated and instructions to **Users** and **Restoration Service Providers** will revert back to the provisions of the Grid Code **Operating Codes** and **Balancing Codes**, as appropriate, covering normal operating conditions unless otherwise informed by **The Company**.
- OC9.4.7.11.7 Where **The Company** issues an **Emergency Instruction** (or in Scotland where a **Relevant Scottish Transmission Licensee** issues an instruction) to a **Network Operator** to activate a **Distribution Restoration Zone Plan**, the **Network Operator** will first issue instructions to the **Anchor Plant Owner** informing the **Anchor Plant Owner** of the requirement to prepare their **Anchor Plant** to re-energise a **Distribution Restoration Zone** (or part thereof) in accordance with the **Distribution Restoration Zone Plan**. The **Network Operator** in liaison with the **Anchor Plant Owner** will discuss when their **Anchor Plant** is expected to be available and ready to start re-energising the **Distribution Restoration Zone**. For the avoidance of doubt, the **Anchor Plant Owner** shall not start to re-energise the **Distribution Restoration Zone** until given a formal instruction by the **Network Operator** in accordance with **OC9.4.7.7.12** and this instruction shall only be given once the **Network Operator** has configured its **System** and taken the necessary additional actions to prepare the **Distribution Restoration Zone** to be re-energised. This will include any automatic switching that takes place through the action of a **Distribution Restoration Zone Control System**.
- OC9.4.7.11.8 Following activation of the **Distribution Restoration Zone Plan** in accordance with **OC9.4.7.7.6**, the **Network Operator** will then issue instructions to other relevant **Restoration Service Providers** party to the **Distribution Restoration Zone Plan** to inform them that a **Distribution Restoration Zone Plan** has been activated and to prepare their **Plant** and **Apparatus** so that it is in a state of readiness for contributing to the further planned operation of the **Distribution Restoration Zone**. All relevant **Restoration Service Providers** will inform the **Network Operator** of the indicative time of when their **Plant** and **Apparatus** will be in a state of readiness to be re-energised and/or **Synchronised** to the **Distribution Restoration Zone**. Relevant **Restoration Service Providers** shall not start to re-energise or **Synchronise** to the **Distribution Restoration Zone** until given a formal specific instruction by the **Network Operator** in accordance with **OC9.4.7.7.12**. Such instructions would only be issued to relevant **Restoration Service Providers** other than **Anchor Restoration Service Providers** once the **Network Operator** has re-energised the **Distribution Restoration Zone** (or part thereof) by issuing instructions to the **Anchor Restoration Service Provider** and the **Distribution Restoration Zone** is in a position to expand and supply more **Demand** in accordance with the **Distribution Restoration Zone Plan**. These instructions can also be issued automatically by a **Distribution Restoration Zone Control System**.

- OC9.4.7.11.9 The **Network Operator** shall inform **The Company** (and the **Relevant Scottish Transmission Licensee** in the case of a Scottish **Distribution Restoration Zone**) advising that it has contacted the appropriate **Anchor Restoration Service Provider** and **Top Up Restoration Service Providers** in accordance with the **Distribution Restoration Zone Plan** and provide an indicative time of when the **Distribution Restoration Zone** and associated **Plant** and **Apparatus** is ready to be re-energised and the expected time of when the **Anchor Restoration Service Provider** is in a position to re-energise the **Distribution Restoration Zone** (or part thereof).
- OC9.4.7.11.10 In addition to the requirements of **OC9.4.7.7.6** to **OC9.4.7.7.8**, the **Network Operator** shall start to reconfigure its **System** such that it is in an appropriate state of readiness to enable the **Anchor Plant Restoration Service Provider** to re-energise the **Distribution Restoration Zone** (or part thereof) in accordance with the **Distribution Restoration Zone Plan**. To enable this process to take place, the **Network Operator** may need to change the topology and status of its **System** which may include but shall not be limited to changing the status of circuit breakers in addition to adjusting control system and **Protection** settings. Reconfiguration of the **Network Operator's System** prior to re-energisation of the **Distribution Restoration Zone**, may be achieved by instructions carried out by manual means, switching carried out remotely from the **Network Operators Control Centre** or via fully automatic means which could include a **Distribution Restoration Zone Control System**.
- OC9.4.7.11.11 Once the **Network Operator** has reconfigured its **System** and associated **Plant** and **Apparatus** (including but not limited to **Protection** and control system settings) it will contact the **Anchor Plant Restoration Service Provider** (which could also be achieved by the **Distribution Restoration Zone Control System**) to confirm the foregoing and agree a time for the **Anchor Plant Restoration Service Provider** to operate their **Plant** so as to re-energise the **Distribution Restoration Zone** (or part thereof). Where the **Anchor Restoration Service Provider** or **Network Operator** needs to change the agreed re-energisation time as a result of an unforeseen event such as, but not limited to, a faulty item of **Plant** or **Apparatus**, safety issue or unavailability of personnel, the **Anchor Restoration Service Provider** and/or **Network Operator** will agree a revised re-energisation time.
- OC9.4.7.11.12 The **Network Operator** will inform **The Company** (or relevant **Scottish Transmission Licensee** in the case of a Scottish **Distribution Restoration Zone**) of the time when the **Anchor Restoration Service Provider** is scheduled to re-energise a section of the **Network Operator's System**. Should this scheduled time vary, the **Network Operator** will inform **The Company** (or relevant **Scottish Transmission Licensee** in the case of a Scottish **Distribution Restoration Zone**) as necessary and provide an indication of any revised re-energisation time and the reason for the change.
- OC9.4.7.11.13 At the agreed re-energisation time as detailed in **OC.9.4.7.8.11**, the **Network Operator** will contact the **Anchor Restoration Service Provider** and issue an instruction to the **Anchor Restoration Service Provider** to re-energise the **Distribution Restoration Zone** (or part thereof) unless this is achieved via fully automatic means which could include a **Distribution Restoration Zone Control System**. Following the issue of instructions to the **Anchor Restoration Service Provider**, and successful re-energisation of the **Distribution Restoration Zone** (or part thereof) the **Network Operator** will instruct other **Top Up Restoration Service Providers** in the **Distribution Restoration Zone Plan** as part of the wider restoration phase which again could be achieved through fully automatic means using a **Distribution Restoration Zone Control System**. Where a **Network Operator** has installed a **Distribution Restoration Zone Control System**, **The Company** and **Scottish Transmission Licensees** will automatically receive the outputs, operational metering signals and status indications as required under **CC.6.4.6.3 (c)** or **ECC.6.4.6.3(c)**.

OC9.4.7.11.14 Once the **Distribution Restoration Zone** (or part thereof) has been re-energised and feeding some local **Demand** or controllable **Demand** provided by a relevant **Restoration Service Provider**, the **Anchor Restoration Service Provider** will be required to follow instructions from the **Network Operator** (or via fully automatic means which could include a **Distribution Restoration Zone Control System**) as envisaged in the **Distribution Restoration Zone Plan**. The **Network Operator** and/or **Distribution Restoration Zone Control System** shall issue instructions to **Restoration Service Providers** as necessary to ensure the **Distribution Restoration Zone** continues to run in a stable manner. The **Network Operator** will restore additional **Demand** or instruct the relevant **Restoration Service Providers** to do so, when it is appropriate to do so. As part of this process, the **Network Operator** in coordination with **Restoration Service Providers** shall ensure risks to the **Network Operator's System** or the **Restoration Service Providers Plant**, that could arise through disturbances in the **Distribution Restoration Zone**, are minimised as far as reasonably practicable. This may be assisted through a planned series of re-energisation steps within the **Distribution Restoration Zone**, taking account of the capability and performance of the **Restoration Service Providers Plant** at this time.

OC9.4.7.11.15 **Demand** within the **Distribution Restoration Zone** can be restored by manual or remote controlled switching, or automatically by a **Distribution Restoration Zone Control System**. If during the **Demand** restoration process, any relevant **Restoration Service Providers Plant** or **Apparatus** cannot, because of the nature of the **Demand** being supplied, keep within its safe operating parameters, the relevant **Restoration Service Provider** shall inform the **Network Operator** without undue delay who in turn shall inform **The Company**. In the case of a **Distribution Restoration Zone** in Scotland the **Scottish Network Operator** shall inform the relevant **Scottish Transmission Licensee**.

In order to help alleviate issues the **Network Operator** or **Distribution Restoration Zone Control System** will, where possible:

- i. Instruct relevant **Restoration Service Providers** to alter their **Demand**; or
- ii. re-configure the topology of the **Distribution Restoration Zone**; or
- iii. will instruct the relevant **Restoration Service Provider** forming part of the **Distribution Restoration Zone** to re-configure its **System** in order to alleviate the problem.

The Company and **Network Operator** (and **Relevant Transmission Licensee** in Scotland) accepts that any decision to keep a relevant **Restoration Service Provider's Plant** or **Apparatus** operating, if outside its safe operating parameters, is one for the **Restoration Service Provider** concerned alone. **The Company**, the **Network Operator**, and the **Relevant Scottish Transmission Licensee** (for **Distribution Restoration Zones** in Scotland) accepts that the relevant **Restoration Service Provider's Plant** and **Apparatus** may have its operating point changed by the relevant **Restoration Service Provider** if it believes it is necessary for safety reasons (whether relating to personnel or **Plant** and/or **Apparatus**). If such a change is made without prior notice, then the relevant **Restoration Service Provider** shall inform the **Network Operator** as soon as reasonably practical.

OC9.4.7.11.16 To stabilise the voltage and **Frequency** of the **Network Operator's System** and increase the **Demand** supplied within the **Distribution Restoration Zone**, the **Network Operator** may need to instruct additional relevant **Restoration Service Providers** to **Synchronise** their **Plant** to the **Distribution Restoration Zone**, either via manual instruction or through a **Distribution Restoration Zone Control System**. For the avoidance of doubt, **The Company** may require **Transmission Licensees** in Scotland to manage the **Frequency** and voltage of **Power Islands** in Scotland as provided for in STCP 06-1 or **Network Operators** to manage the **Frequency** and voltage of **Distribution Restoration Zones** whilst recognising **The Company** has overall responsibility to the wider restoration process in the **GB Synchronous Area**.

- OC9.4.7.11.17 With the **Distribution Restoration Zone** operating as described in **OC9.4.7.7.14** and **OC9.4.7.7.15** and in accordance with the **Distribution Restoration Zone Plan**, the **Network Operator** shall then undertake a step by step process of re-energising more elements of its **System** by restoring auxiliary supplies to substations, other **Users** and the restoration of supplies to **Customers** in accordance with the **Distribution Restoration Zone Plan**. These steps may include energisation of parts of the **Transmission System** where provided for in the **Distribution Restoration Zone Plan**. During this phase, each relevant **Restoration Service Provider's Plant and Apparatus** is to be operated within its designed operational limits. The **Network Operator** and/or the **Distribution Restoration Zone Control System** shall ensure **Restoration Service Providers** are able (where applicable) to contribute to voltage and **Frequency** control and ensure that adequate positive and negative headroom is maintained on relevant **Plant and Apparatus** to enable the management of **Power Island** contingences. During this period, there may be a need to instruct relevant **Restoration Service Providers** to **Synchronise** additional **Plant and Apparatus**, or to change operating points of **Plant and Apparatus** already **Synchronised**, to balance the **Distribution Restoration Zone**.
- OC9.4.7.11.18 As the **Distribution Restoration Zone** supports increasing **Demand**, and as implementation of the **Distribution Restoration Plan** progresses, the **Network Operator** may need to update the **Protection** and control settings as the need arises.
- OC9.4.7.11.19 Once the **Distribution Restoration Zone** is in stable operation, the **Network Operator** and/or **Distribution Restoration Zone Control System** shall ensure that additional **Restoration Service Provider's Plant and Apparatus** which are **Synchronised** to the **Distribution Restoration Zone**, are operated with sufficient headroom to be able to contribute to voltage and **Frequency** control, and in accordance with the safe operating limits in accordance with **OC9.4.7.8.14**. This is an essential pre-requisite to enable the **Power Island** to withstand volatility in **Demand** and generation, **Network Operator** interaction or credible faults and disturbances.
- OC9.4.7.11.20 Expansion of a **Distribution Restoration Zone** to an unenergised **Transmission** busbar and to wider parts of the unenergised **Transmission System** could be part of the **Distribution Restoration Zone Plan** where provided for in the **Distribution Restoration Zone Plan** in addition to the requirements of OC9.5.

Expansion of Power Islands

OC9.4.7.12 **The Company** will instruct relevant **Users** to expand **Power Islands** to achieve larger sub-systems be they formed from a **Local Joint Restoration Plan** or **Distribution Restoration Zone Plan**.

OC9.4.7.12.1 As part of **System Restoration**, each **Network Operator** which:-

- (a) has an **Anchor Power Station** or an **Anchor HVDC System** or **Anchor DC Converter Station** forming part of a **Local Joint Restoration Plan**, and which has established a **Power Island**, howsoever arising within its **User System**, may in liaison with **The Company** sustain and expand these islands in accordance with the relevant provisions of OC9.5 which shall apply to this OC9.4 as if set out here; and/or
- (b) has activated one or more **Distribution Restoration Zone Plans** upon instruction from **The Company** or **Relevant Scottish Transmission Licensee**, will notify **The Company** or the **Relevant Scottish Transmission Licensee** when the **Distribution Restoration Zone** is operational and supplying local **Demand**. The **Network Operator** in liaison with **The Company** or the **Relevant Scottish Transmission Licensee** may sustain and expand these **Power Islands** with the relevant provisions of OC9.5 which shall apply to this OC9.4 as if set out here

In either case, the **Network Operator** will inform **The Company** or the **Relevant Scottish Transmission Licensee** of their actions and will not **Re-Synchronise** a **Power Island** formed under a **Distribution Restoration Zone Plan** to the **National Electricity Transmission System** without **The Company's** agreement.

OC9.4.7.13 Interconnection of Power Islands

~~OC9.4.7.7~~ ~~The Company~~ will instruct the relevant **Users** so as to interconnect **Power Islands** to achieve larger sub-systems, and ~~The Company~~ will subsequently ~~the interconnection of these~~ interconnect the expanded **Power Islands** detailed in **OC9.4.7.8** and **OC9.4.7.9** to form sub-systems ~~which will then be connected to form an integrated system, as detailed in OC9.5~~ which is a fundamental component of the **Electricity System Restoration Standard**. This should eventually achieve the re-establishment of the **Total System** or that part of the **Total System** subject to the **Partial Shutdown**, as the case may be. The interconnection of **Power Islands** and sub-systems will utilise the provisions of all or part of OC9.5 (**Re-Synchronisation of De-synchronised Power Islands**) and in such a situation such provisions will be part of the **Black Start System Restoration**.

~~OC9.4.7.8~~ As part of the **Black Start** strategy, each **Network Operator** with either an **Embedded Black Start Station** or **Embedded HVDC System** or **Embedded DC Converter Station**, which has established a **Power Island** within its **User System** or with any **Embedded Power Stations** or **Embedded HVDC Systems** or **Embedded DC Converter Stations** within its **User System**, which have become islanded, may in liaison with **The Company**, sustain and expand these islands in accordance with the relevant provisions of OC9.5 which shall apply to this OC9.4 as if set out here. They will inform **The Company** of their actions and will not **Re-Synchronise** to the **National Electricity Transmission System** or any **User's System** which is already **Synchronised** to the **National Electricity Transmission System** without **The Company's** agreement.

Return the Total System Back to Normal Operation

~~OC9.4.7.9~~¹⁴ **The Company** shall, as soon as reasonably practical, inform **Users** and the **BSCCo** when the **Total System** could return to normal operation. Any such determination by **The Company** does not mean that the provisions of Section G paragraph 3 (**Black Start System Restoration**) of the **BSC** shall cease to apply.

In making the determination that the **Total System** could return to normal operation, **The Company**, would consider, amongst other things, the following areas:

- (a) the extent to which the **National Electricity Transmission System** is contiguous and energised;
- (b) the integrity and stability of the **National Electricity Transmission System** and its ability to operate in accordance with the **Licence Standards**;
- (c) the impact that returning to normal may have on transmission constraints and the corresponding ability to maximise the **Demand** connected; and
- (d) the volume of generation, **Electricity Storage** or **Demand** not connected to the **National Electricity Transmission System**; and
- (e) the functionality of normal communication systems (~~i.e.~~ electronic data communication facilities, **Control Telephony**, etc).

In the event that the **Balancing Mechanism** has been suspended, it will not resume until the start of the **Settlement Period** determined by the **BSC Panel** in accordance with paragraph G3.1.2(d)(i) of the **BSC**.

For the avoidance of doubt, until resumption of the **Balancing Mechanism**, **The Company** is likely to continue to issue **Emergency Instructions** in accordance with BC2.9.

Users shall use reasonable endeavours to submit **Physical notifications** ten hours prior to the start of the **Settlement Period** determined by the **BSC Panel** in accordance with paragraph G3.1.2(d)(i) of the **BSC** and as notified by **The Company** to **Users**, in preparation for a return to normal operations.

In the event that the **Balancing Mechanism** has not been suspended and **The Company** has determined that the **Total System** has returned to normal operation, **The Company** shall

inform **Users** and the **BSCCo** as soon as possible of the time and date at which (in **The Company's** determination) the **Total System** returned to normal operation.

Conclusion of ~~Black Start~~System Restoration

OC9.4.7.4015 The provisions of this **OC9** shall cease to apply with effect from either:

- (a) Where the **Balancing Mechanism** was suspended, the start of the **Settlement Period** that the **Balancing Mechanism** resumed normal operation, as determined by the **BSC Panel** and notified by the **BSCCo** in accordance with the provisions of the **BSC**; or
- (b) Where the **Balancing Mechanism** was not suspended, the end of the **Settlement Period** determined and notified by the **BSCCo** (in accordance with the provisions of the **BSC**) and corresponding to the time and date that **The Company** determined that the **Total System** had returned to normal operation.

Externally Interconnected System Operators

~~OC9.4.7.11~~ During a ~~Black Start~~OC9.4.7.16 Unless an **Interconnector** has an **Anchor Restoration Contract**, **The Company** will, pursuant to the **Interconnection Agreement** with **Externally Interconnected System Operators**, agree with **Externally Interconnected System Operators** when their transmission systems can be **Re-Synchronised** to the **Total System**, if they have become separated.

~~OC9.4.7.12~~ Local Joint Restoration Plan Establishment

- ~~(a) In England and Wales, in relation to each **Black Start Station** and each **Black Start HVDC System**, **The Company**, **NGET**, the **Network Operator** and the relevant **Black Start Service Provider** will discuss and agree a **Local Joint Restoration Plan**. Where at the date of the first inclusion of this OC9.4.7.12 into the **Grid Code** a local plan covering the procedures to be covered in a **Local Joint Restoration Plan** is in existence and agreed, **The Company** will discuss this with **NGET**, the **Network Operator** and the relevant **Generator** or **HVDC System Owner** or **DC Converter Station Owner** to agree whether it is consistent with the principles set out in this OC9.4. If it is agreed to be so consistent, then it shall become a **Local Joint Restoration Plan** under this **OC9** and the relevant provisions of OC9.4.7.12(b) shall apply. If it is not agreed to be so consistent, then the provisions of OC9.4.7.12(b) shall apply as if there is no **Local Joint Restoration Plan** in place.~~

~~In respect of **Scottish Transmission Systems** where a requirement for a **Local Joint Restoration Plan** is identified, **The Company**, the **Relevant Scottish Transmission Licensee(s)**, the **Network Operator** and **Black Start Service Provider(s)** will discuss and agree a **Local Joint Restoration Plan**. In addition other **Users**, including other **Generators** or **HVDC System Owners** or **DC Converter Station Owners**, may be reasonably required by **The Company** to discuss and agree a **Local Joint Restoration Plan**.~~

- ~~(b) In England and Wales, where the need for a **Local Joint Restoration Plan** arises when there is none in place, the following provisions shall apply:~~
- ~~(i) **The Company**, **NGET**, the **Network Operator** and the relevant **Black Start Service Provider** will discuss and agree the detail of the **Local Joint Restoration Plan** as soon as the requirement for a **Local Joint Restoration Plan** is identified by **The Company**. **The Company** will notify all affected **Users**, and will initiate these discussions.~~
 - ~~(ii) Each **Local Joint Restoration Plan** will be in relation to a specific **Black Start Station** or **Black Start HVDC System**.~~
 - ~~(iii) The **Local Joint Restoration Plan** will record which **Users** and which **User Sites** are covered by the **Local Joint Restoration Plan** and set out what is required from **The Company**, **NGET** and each **User** should a **Black Start** situation arise.~~

- ~~(iv) Each **Local Joint Restoration Plan** shall be prepared by **The Company** to reflect the above discussions and agreement.~~
- ~~(v) Each page of the **Local Joint Restoration Plan** shall bear a date of issue and the issue number.~~
- ~~(vi) When a **Local Joint Restoration Plan** has been prepared, it shall be sent by **The Company** to **NGET** and the **Users** involved for confirmation of its accuracy.~~
- ~~(vii) The **Local Joint Restoration Plan** shall then (if its accuracy has been confirmed) be signed on behalf of **The Company** and on behalf of **NGET** and each relevant **User** by way of written confirmation of its accuracy.~~
- ~~(viii) Once agreed under this OC9.4.7.12, the procedure will become a **Local Joint Restoration Plan** under the **Grid Code** and (subject to any change pursuant to this OC9) will apply between **The Company** and **NGET** and the relevant **Users** as if it were part of the **Grid Code**.~~
- ~~(ix) Once signed, a copy of the **Local Joint Restoration Plan** will be distributed by **The Company** to **NGET** and each **User** which is a party to it accompanied by a note indicating the date of implementation.~~
- ~~(x) **The Company**, **NGET** and **Users** must make the **Local Joint Restoration Plan** readily available to the relevant operational staff.~~
- ~~(xi) If **The Company**, or **NGET** or any **User** which is a party to a **Local Joint Restoration Plan**, becomes aware that a change is needed to that **Local Joint Restoration Plan**, it shall (in the case of **The Company**) initiate a discussion between **The Company** and the relevant **Users** to seek to agree the relevant change. If **NGET** or a **User** becomes so aware, it shall contact **The Company** who will then initiate such discussions. The principles applying to establishing a new **Local Joint Restoration Plan** under this OC9.4.7.12 shall apply to such discussions and to any consequent changes.~~
- ~~(xii) **The Company**, **NGET**, the **Network Operator**, and the relevant **Generator**, or **HVDC System Owner** or **DC Converter Station Owner** will conduct regular joint exercises of the **Local Joint Restoration Plan** to which they are parties. The objectives of such exercises include:~~
 - ~~• To test the effectiveness of the **Local Joint Restoration Plan**;~~
 - ~~• To provide for joint training of the parties in respect of the **Local Joint Restoration Plan**;~~
 - ~~• To maintain the parties' awareness and familiarity of the **Local Joint Restoration Plan**;~~
 - ~~• To promote understanding of each parties' roles under a **Local Joint Restoration Plan**;~~
 - ~~• To identify any improvement areas which should be incorporated in to the **Local Joint Restoration Plan**.~~
 - ~~• The principles applying to the establishment of a new **Local Joint Restoration Plan** under this OC9.4.7.12 shall apply to any changes to the **Local Joint Restoration Plan**.~~

~~**The Company** will propose to the parties of a **Local Joint Restoration Plan** a date for the exercise to take place, to be agreed with the other parties. All the **Local Joint Restoration Plan** parties will jointly share the task of planning, preparing, participating in and facilitating the exercises, which will normally be in desktop format or as otherwise agreed. The precise timing of the exercise for each **Local Joint Restoration Plan** will be agreed by all parties, but will not be less than one every 8 years.—~~

- ~~(c) In respect of **Scottish Transmission Systems**, where the need for a **Local Joint**~~

Restoration Plan arises, the following provisions shall apply:

- (i) ~~The Company, the Relevant Scottish Transmission Licensee(s), the Network Operator and the relevant Black Start Service Provider will discuss and agree the detail of the Local Joint Restoration Plan as soon as the requirement for a Local Joint Restoration Plan is identified by The Company. In addition, other Scottish Users, including other Generators, HVDC System Owners and DC Converter Station Owners, may be reasonably required by The Company to discuss and agree details of the Local Joint Restoration Plan as soon as the requirement for a Local Joint Restoration Plan is identified by The Company. The Company will notify the Relevant Scottish Transmission Licensee(s) and all affected Scottish Users, and will initiate these discussions.~~
- (ii) ~~Each Local Joint Restoration Plan may be in relation to either a specific Black Start Station or a number of Black Start Stations, and may include Gensets at Power Stations other than a Black Start Station. Each Local Joint Restoration Plan could equally apply to a specific Black Start HVDC System or a number of Black Start HVDC Systems and may include HVDC Systems or DC Converter Stations other than a Black Start HVDC System. For the avoidance of doubt, this would not preclude a Local Joint Restoration Plan from comprising a combination of Power Stations, HVDC Systems or DC Converter Stations irrespective of whether they have a Black Start Capability.~~
- (iii) ~~The Local Joint Restoration Plan will record which Scottish Users and which Scottish User Sites are covered by the Local Joint Restoration Plan and set out what is required from The Company, the Relevant Scottish Transmission Licensee(s) and each Scottish User should a Black Start situation arise.~~
- (iv) ~~Each Local Joint Restoration Plan shall be prepared by The Company to reflect the above discussions and agreement.~~
- (v) ~~Each page of the Local Joint Restoration Plan shall bear a date of issue and the issue number.~~
- (vi) ~~When a Local Joint Restoration Plan has been prepared, it shall be sent by The Company to the Relevant Scottish Transmission Licensee(s) and Scottish Users involved for confirmation of its accuracy.~~
- (v) ~~The Local Joint Restoration Plan shall then (if its accuracy has been confirmed) be signed on behalf of The Company and on behalf of each relevant Scottish User and Relevant Scottish Transmission Licensee(s) by way of written confirmation of its accuracy.~~
- (vi) ~~Once agreed under this OC9.4.7.12, the procedure will become a Local Joint Restoration Plan under the Grid Code and (subject to any change pursuant to this OC9) will apply between The Company, Relevant Scottish Transmission Licensee(s) and the relevant Scottish Users as if it were part of the Grid Code.~~
- (vii) ~~Once signed, a copy of the Local Joint Restoration Plan will be distributed by The Company to the Relevant Scottish Transmission Licensee(s) and each Scottish User which is a party to it accompanied by a note indicating the date of implementation.~~
- (x) ~~The Company, the Relevant Scottish Transmission Licensee(s) and Scottish Users must make the Local Joint Restoration Plan readily available to the relevant operational staff.~~
- (xi) ~~If The Company, the Relevant Scottish Transmission Licensee(s) or any Scottish User which is a party to a Local Joint Restoration Plan, becomes aware that a change is needed to that Local Joint Restoration Plan, it shall (in the case of The Company) initiate a discussion between The Company, the Relevant Scottish Transmission Licensee(s) and the relevant Scottish Users to seek to agree the relevant change. If a Scottish User or a Relevant Scottish Transmission Licensee~~

~~becomes so aware, it shall contact The Company who will then initiate such discussions. The principles applying to establishing a new Local Joint Restoration Plan under this OC9.4.7.12 shall apply to such discussions and to any consequent changes.~~

~~(xii) The Company, the Relevant Scottish Transmission Licensee(s), the Network Operator and the relevant Black Start Service Provider will conduct regular joint exercises of the Local Joint Restoration Plan to which they are parties. The objectives of such exercises include:~~

- ~~• To test the effectiveness of the Local Joint Restoration Plan;~~
- ~~• To provide for joint training of the parties in respect of the Local Joint Restoration Plan;~~
- ~~• To maintain the parties' awareness and familiarity of the Local Joint Restoration Plan;~~
- ~~• To promote understanding of each parties' roles under a Local Joint Restoration Plan;~~
- ~~• To identify any improvement areas which should be incorporated in to the Local Joint Restoration Plan.~~
- ~~• The principles applying to the establishment of a new Local Joint Restoration Plan under this OC9.4.7.12 shall apply to any changes to the Local Joint Restoration Plan.~~

~~The Company will propose to the parties of a Local Joint Restoration Plan a date for the exercise to take place, to be agreed with the other parties. All the Local Joint Restoration Plan parties will jointly share the task of planning, preparing, participating in and facilitating the exercises, which will normally be in desktop format or as otherwise agreed. The precise timing of the exercise for each Local Joint Restoration Plan will be agreed by all parties, but will not be less than one every 8 years.~~

OC9.5 RE-SYNCHRONISATION OF DE-SYNCHRONISED POWER ISLANDS

The provisions in this OC9.5 do not apply to the parts of the **Total System** that normally operate **Out of Synchronism** with the rest of the **National Electricity Transmission System**.

Further requirements, including the provision of information, applying to **Re-synchronisation of De-synchronised IslandsPower Island** following any **Total Shutdown** or **Partial Shutdown** are detailed in OC9.5.6.

- OC9.5.1
- (a) Where parts of the **Total System** are **Out of Synchronism** with each other (each such part being termed a "**De-SynchronisedPower Island**"), ~~but there is where there has been~~ no **Total Shutdown** or **Partial Shutdown**, **The Company** will instruct **Users** to regulate generation or **Demand**, as the case may be, to enable the **De-SynchronisedPower Islands** to be **Re-Synchronised** and **The Company** will inform those **Users** when **Re-Synchronisation** has taken place.
 - (b) As part of that process, there may be a need to deal specifically with **Embedded** generation or storage in those **De-Synchronised Power Islands**. This OC9.5 provides for how such **Embedded** generation or storage should be dealt with. In Scotland, this OC9.5 also provides for how **Transmission** connected generation in **De-SynchronisedPower Islands** should be dealt with.

- (c) In accordance with the provisions of the BC, **The Company** may decide that, to enable **Re-Synchronisation**, it will issue **Emergency Instructions** in accordance with BC2.9 and it may be necessary to depart from normal **Balancing Mechanism** operation in accordance with **BC2** in issuing **Bid-Offer Acceptances**.
- (d) The provisions of this OC9.5 shall also apply during a **Black Start System Restoration** to the **Re-Synchronising** of parts of the **System** following a **Total or Partial Shutdown**, as indicated in OC9.4. In such cases, the provisions of ~~the~~ OC9.5 shall apply following completion and/or termination of the relevant **Local Joint Restoration Plan(s)** process as referred to in **OC9.4.7.6(f)** or relevant **Distribution Restoration Zone Plans** referred to in **OC9.4.7.6.2(e)**.

OC9.5.2 Options Island loading and generation data management

Generation in those **De-Synchronised Power Islands** may be dealt with as described in three different ways, more than one of OC9.5.2.1 and OC9.5.2.2. As to which may be method is utilised will vary in relation to any particular incident:-

OC9.5.2.1 Indirect Data Submission between Generators and Network Operators via The Company

- (a) In this section, OC9.5.2.1, relevant loading and other operational parameters are exchanged indirectly between Generators and/or HVDC System Owners and DC Converter Station Owners and Network Operators via The Company.
- (b) The Company, each Generator, HVDC Owner and/or DC Converter Station owner with Synchronised (or connected and available to generate although not Synchronised) Genset(s) Plant in the De-Synchronised Power Island and the Network Operator whose User System forms all or part of the De-Synchronised Power Island shall exchange information as set out in this OC9.5.2.1 to enable The Company to issue a Bid-Offer Acceptance or an Emergency Instruction to that Generator and/or HVDC System Owner and/or DC Converter Station Owner in relation to its Genset(s) in Plant in the De-Synchronised Power Island until Re-Synchronisation takes place, on the basis that it will (where practicable) seek to maintain the Target Frequency.
- (bc) The information to The Company from the Generator and/or HVDC System Owner and/or DC Converter Station owner will cover its relevant operational parameters as outlined in the Balancing Codes (BC) and from The Company to the Generator and/or HVDC System Owner and/or DC Converter Station owner will cover data on Demand and changes in Demand in the De-Synchronised Power Island.
- (ed) The information from the Network Operator to The Company will comprise data on Demand in the De-Synchronised Power Island, including data on any constraints within the De-Synchronised Power Island.
- (ee) The Company will keep the Network Operator informed of the Bid-Offer Acceptances or Emergency Instructions it is issuing to Embedded Genset(s) Generating Units and/or Embedded HVDC Systems and/or DC Converter Station Owners within the Network Operator's User System forming part of the De-Synchronised Power Island.

Direct Data Submission between Generators, HVDC System Owners, DC Converter Station Owners and Network Operators

~~(a)~~ In this section, **OC9.5.2.2**, relevant loading and other operational parameters are exchanged directly between **Generators**, and/or **HVDC System Owners** and **DC Converter Station Owners** and **Network Operators**.

~~(b)~~ **The Company** will issue an **Emergency Instruction** and/or a **Bid-Offer Acceptance**, to the **Generator** and/or **HVDC System Owner** and/or **DC Converter Station Owner** to "float" local **Demand** and maintain **Frequency** at **Target Frequency**. ~~UnderIn~~ this situation, the **Generator** and/or **HVDC System Owner** and/or **DC Converter Station owner** will be required to regulate the output of its **Genset(s)** at the ~~Power Station in question~~ **Plant** to the **Demand** prevailing in the **De-SynchronisedPower** Island in which it is situated, until **Re-Synchronisation** takes place, on the basis that it will (where practicable) seek to maintain the **Target Frequency**.

~~(bc)~~ The **Network Operator** is required to be in contact with the **Generator** ~~at the Power~~ and/or **HVDC System Operator** and/or **DC Converter Station** ~~to owner so that the~~ **Network Operator** can supply data to the **Generator** and/or **HVDC System Owner** and/or **DC Converter Station owner** on **Demand** changes within the **De-Synchronised Power** Island.

~~(ed)~~ If more than one **GensetGenerating Unit** and/or **HVDC System** and/or **DC Converter** is **Synchronised** onto the **De-SynchronisedPower** Island, or is connected to the **De-SynchronisedPower** Island and available to generate although not **Synchronised**, the **Network Operator** will need to liaise with **The Company** to agree which **Genset(s)Generating Units** and/or **HVDC Systems** and/or **DC Converter stations** will be utilised to accommodate changes in **Demand** in the **De-SynchronisedPower** Island. The **Network Operator** will then maintain contact with the relevant **Generator** ~~(or~~ **Generators(s)** and/or **HVDC System Owner(s)** and/or **DC Converter Station Owner(s)** in relation to that **Genset(s)-Plant**.

~~(de)~~ The **Generator** at the **Power Station** and/or **HVDC System Owner** and/or **DC Converter Station owner** must contact the **Network Operator** if the level of **Demand** which it has been asked to meet as a result of the **Emergency Instruction** and/or **Bid-Offer Acceptance** to "float" and the detail on **Demand** passed on by the **Network Operator**, is likely to cause problems for safety reasons (whether relating to personnel or **Plant** and/or **Apparatus**) in the operation of its **GensetGenerating Unit(s)** or **HVDC System(s)** or **DC Converter Station(s)**, in order that the **Network Operator** can alter the level of **Demand** which that **Generator** and/or **HVDC System Owner** and/or **DC Converter Station owner** needs to meet. Any decision to operate outside any relevant parameters is one entirely for the **Generator** and/or **HVDC System Owner** and/or **DC Converter Station owner**.

Control Features

- (a) A system may be established in relation to a part of the **National Electricity Transmission System** and a **Network Operator's User System**, if agreed between **The Company** and the **Network Operator** and any relevant **Generator(s)**, **HVDC System Owner** or **DC Converter Station Owner**, whereby upon a defined fault(s) occurring, manual or automatic control features will operate to protect the **National Electricity Transmission System** and relevant **Network Operator's User System** and **Genset Generator(s)**, **HVDC System Owner(s)** or **DC Converter Station Owner(s)** **Plant** and simplify the restoration of **Demand** in the **De-SynchronisedPower** Island.
- (b) In agreeing the establishment of such a system of control features, **The Company** will need to consider its impact on the operation of the **National Electricity Transmission System**.

Absence of Control Features System

If a system of control features under **OC9.5.2.3** has not been agreed as part of an **OC9 De-Synchronised Island Procedure** under **OC9.5.4** below, **The Company** may choose to utilise the procedures set out in **OC9.5.2.1** or **OC9.5.2.2**, or may instruct the **Genset(s) Generators or HVDC System Owner or DC Converter Station owners** (or some of them) in respect of the **De-Synchronised Plant** they own or operate) in the **Power Island** to **De-Synchronise**.

OC9.5.3

Choice ~~Of~~ Option

In relation to each of the methods set out in **OC9.5.2**, where a **De-Synchronised Power Island** has come into existence and where an **OC9 De-Synchronised Island Procedure** under **OC9.5.4** has been agreed, **The Company**, the **Network Operator** and the relevant **Generator(s)**, **HVDC System Owners** or **DC Converter Station owners** will operate in accordance with that **OC9 De-Synchronised IslandsIsland Procedure** unless **The Company** considers that the nature of the **De-Synchronised Island** situation is such that either:-

- (i) the **OC9 De-Synchronised Island Procedure** does not cover the situation; or
- (ii) the provisions of the **OC9 De-Synchronised Island Procedure** are not appropriate,

in which case **The Company** will instruct the relevant **Users** and the **Users** will comply with **The Company's** instructions (which in the case of **Generators** will relate to generation and/or **HVDC System Owners** and/or **DC Converter Station owners** will relate to **Active Power supplied to the Power Island Total System** and in the case of **Network Operators** will relate to **Demand**).

OC9.5.4

Agreeing Procedures

In relation to each relevant part of the **Total System**, **The Company**, the **Network Operator** and the relevant **Generator** and/or HVDC System Owner and/or DC Converter Station owner will discuss and may agree a local procedure (an "**OC9 De-Synchronised Island Procedure**").

OC9.5.4.1 ~~Where there is no relevant local procedure in place at 12th May 1997, or in the case where~~ Where the need for an **OC9 De-Synchronised Island Procedure** arises for the first time, the following provisions shall apply:

- (a) **The Company**, the **Network Operator(s)** and the relevant **Generator(s)** and/or HVDC System Owners or DC Converter Station owners will discuss the need for, and the detail of, the **OC9 De-Synchronised Island Procedure**. As soon as the need for an **OC9 De-Synchronised Island Procedure** is identified by **The Company** or a **User**, and the party which identifies such a need will notify all affected **Users** (and **The Company**, if that party is a **User**), and **The Company** will initiate these discussions.
- (b) Each **OC9 De-Synchronised Island Procedure** will be in relation to a specific **Grid Supply Point**, but if there is more than one **Grid Supply Point** ~~between The Company and the Network Operator involved~~ then the **OC9 De-Synchronised Island Procedure** may cover all relevant **Grid Supply Points**. In Scotland, the **OC9 De-Synchronised Island Procedure** may also cover parts of the **National Electricity Transmission System** connected to the **User's System(s)** and **Power Stations** and HVDC Systems and DC Converter Station owners directly connected to the **National Electricity Transmission System** which are also likely to form part of the **Power Island**.
- (c) The **OC9 De-Synchronised Island Procedure** will:
 - (i) record which **Users** and which **User Sites** are covered by the **OC9 De-Synchronised Island Procedure**;
 - (ii) record which of the ~~three~~ methods set out in OC9.5 ~~(or combination of the three)~~ shall apply, with any conditions as to applicability being set out as well;
 - (iii) set out what is required from **The Company** and each **User** should a ~~De-Synchronised Power~~ De-synchronised Power **Island** arise;
 - (iv) set out what action should be taken if the **OC9 De-Synchronised Island Procedure** does not cover a particular set of circumstances and will reflect that in the absence of any specified action, the provisions of OC9.5.3 will apply;
 - (v) in respect of **Scottish Transmission Systems**, the **OC9 De-Synchronised Island Procedure** ~~procedure~~ may be produced with and include obligations on the **Relevant Scottish Transmission Licensee(s)** ~~;~~ ; and
 - (vi) in respect of **Scottish Transmission Systems**, where the **OC9 De-Synchronised Island Procedure** includes the establishment of a De-synchronised Power Island, describe the route for establishment of the De-Synchronised Power Island.
- (d) Each **OC9 De-Synchronised Island Procedure** shall be prepared by **The Company** to reflect the above discussions.
- (e) Each page of the **OC9 De-Synchronised Island Procedure** shall bear a date of issue and the issue number.
- (f) When an **OC9 De-Synchronised Island Procedure** is prepared, it shall be sent by **The Company** to the **Users** involved for confirmation of its accuracy.
- (g) The **OC9 De-Synchronised Island Procedure** shall then be signed on behalf of **The Company** and on behalf of each relevant **User** by way of written confirmation of its accuracy.

- (h) Once agreed under this **OC9.5.4.1**, the procedure will become an **OC9 De-Synchronised Island Procedure** under the **Grid Code** and (subject to any change pursuant to this OC9) will apply between **The Company**, **Relevant Transmission Licensee** and the relevant **Users** as if it were part of the **Grid Code**.
- (i) Once signed, a copy will be distributed by **The Company** to each **User** which is a party accompanied by a note indicating the issue number and the date of implementation.
- (j) **The Company** and **Users** must make the **OC9 De-Synchronised Island Procedure** readily available to the relevant operational staff.
- (k) If a new **User** connects to the **Total System** and needs to be included with an existing **OC9 De-Synchronised Island Procedure**, **The Company** will initiate a discussion with that **User** and the **Users** which are parties to the relevant **OC9 De-Synchronised Island Procedure**. The principles applying to a new **OC9 De-Synchronised Island Procedure** under this OC9.5.4.1 shall apply to such discussions and to any consequent changes.
- (l) If **The Company**, or any **User** which is a party to an **OC9 De-Synchronised Island Procedure**, becomes aware that a change is needed to that **OC9 De-Synchronised Island Procedure**, it shall (in the case of **The Company**) initiate a discussion between **The Company** and the relevant **Users** to seek to agree the relevant change. The principles applying to establishing a new **OC9 De-Synchronised Island Procedure** under this OC9.5.4.1 shall apply to such discussions and to any consequent changes. If a **User** becomes so aware, it shall contact **The Company** who will then initiate such discussions.
- (m) If in relation to any discussions, agreement cannot be reached between **The Company** and the relevant **Users**, **The Company** will operate the **System** on the basis that it will discuss which of the ~~three~~ methods set out in **OC9.5.2.1** ~~to~~ **OC9.5.2.3** would be most appropriate at the time, if practicable. The complexities and uncertainties of recovery from a **De-Synchronised Island** means that ~~The Company will decide, having discussed the situation with the relevant Users and taking into account the fact that the three methods may not cover the situation or be appropriate, the approach which is to be followed. The Company will instruct the relevant Users and the Users will comply with The Company's instructions as provided in OC9.5.3.~~

~~OC9.5.4.2~~ — Where there is a relevant local procedure in place at 12th May 1997, the following provisions shall apply:

- ~~(a) The Company and the Network Operator and the relevant Generator(s) will discuss the existing procedure to see whether it is consistent with the principles set out in this OC9.5.~~
- ~~(b) If it is, then it shall become an OC9 De-Synchronised Island Procedure under this OC9, and the relevant provisions of OC9.5.4.1 shall apply.~~
- ~~(c) If it is not, then the parties will discuss what changes are needed to ensure that it is consistent, and once agreed, the procedure will become an OC9 De-Synchronised Island Procedure under this OC9, and the relevant provisions of OC9.5.4.1 shall apply.~~
- ~~(d) If agreement cannot be reached between The Company and the relevant Users after a reasonable period of time, the existing procedure will cease to apply and The Company will operate the System on the basis that it will discuss which of the three methods set out in OC9.5.2.1 to OC9.5.2.3 would be most appropriate at the time, if practicable. The complexities and uncertainties of recovery from a De-Synchronised Power Island means that The Company will decide, having discussed the situation with the relevant Users and taking into account the fact that the three methods may not cover the situation or be appropriate, the approach which is to be followed. The Company will instruct the relevant Users and the Users will comply with The Company's instructions as provided in OC9.5.3.~~

OC9.5.5 Where the **National Electricity Transmission System** is **Out of Synchronism** with the **Transmission System** of an **Externally Interconnected System Operator**, **The Company** will, pursuant to the **Interconnection Agreement** with that **Externally Interconnected System Operator**, agree with that **Externally Interconnected System Operator** when its **Transmission System** can be **Re-Synchronised** to the **National Electricity Transmission System**.

OC9.5.6 Further requirements regarding **Re-synchronisation** of **De-synchronised Islands** following any **Total Shutdown** or **Partial Shutdown**

Following any **Total Shutdown** or **Partial Shutdown**, **The Company** expects that it will be necessary to interconnect **Power Islands** utilising the provisions of OC9.5. The complexities and uncertainties of recovery from a **Total Shutdown** or **Partial Shutdown** requires the provisions of OC9.5 to be flexible, however, the strategies which **The Company** will, where practicable, be seeking to follow when **Re-synchronising De-synchronised Power Islands** following any **Total Shutdown** or **Partial Shutdown**, include the following:

- (a) ~~(a)~~ the provision of supplies to appropriate **Power Stations** to facilitate their synchronisation as soon as practicable;
- (b) the activation by Network Operators of one or more Distribution Restoration Zones Plans upon instruction from The Company (or Relevant Scottish Transmission Licensee).
- (b) energisation of a skeletal **National Electricity Transmission System**;
- (c) the strategic restoration of **Demand** in co-ordination with relevant **Network Operators**.

As highlighted in OC9.4.3, during a **Total Shutdown** or **Partial Shutdown** and during the subsequent recovery, which includes any period during which the procedures in this OC9.5 apply, the **Licence Standards** may not apply and the **Total System** may be operated outside normal voltage and **Frequency** standards.

OC9.5.7 To manage effectively and co-ordinate the restoration strategies of the **Total System** (any **Re-Synchronisation** of **De-Synchronised Power Islands**) following any **Total Shutdown** or **Partial Shutdown**, requires **The Company** and relevant **Users** to undertake certain planning activities as set out below:

- (a) **The Company** and **Network Operators** shall review on a regular basis the processes by which each **Power Island** will be interconnected. This is likely to cover an exchange of information regarding the typical size, location and timing requirements for **Demand** to be reconnected and also include details (ability to change/disable) of the low frequency trip relay settings of the **Demand** identified.
- (b) Each **Generator** shall provide to **The Company** information to assist **The Company** in the formulation of the restoration strategies of **Power Island** expansion. This information shall be provided in accordance with PC.A.5.7.

OC9.6 JOINT SYSTEM INCIDENT PROCEDURE

OC9.6.1 A "**Joint System Incident**" is


- (a) an **Event**, wherever occurring (other than on an **Embedded Small Power Station** or **Embedded Medium Power Station**), which, in the opinion of **The Company** or a **User**, has or may have a serious and/or widespread effect.
- (b) In the case of an **Event** on a **User(s) System(s)** (other than on an **Embedded Small Power Station** or **Embedded Medium Power Station**), the effect must be on the **National Electricity Transmission System**, and in the case of an **Event** on the **National Electricity Transmission System**, the effect must be on a **User(s) System(s)** (other than on an **Embedded Small Power Station** or **Embedded Medium Power Station**).

Where an **Event** on a **User(s) System(s)** has or may have no effect on the **National Electricity Transmission System**, then such an **Event** does not fall within **OC9** and accordingly **OC9** shall not apply to it.


- OC9.6.2 (a) (i) Each **User** (other than **Generators** which only have **Embedded Small Power Stations** and/or **Embedded Medium Power Stations**) will provide in writing to **The Company**, and
- (ii) **The Company** will provide in writing to each **User** (other than **Generators** which only have **Embedded Small Power Stations** and/or **Embedded Medium Power Stations**), a telephone number or numbers at which, or through which, senior management representatives nominated for this purpose and who are fully authorised to make binding decisions on behalf of **The Company** or the relevant **User**, as the case may be, can be contacted day or night when there is a **Joint System Incident**.
- (b) The lists of telephone numbers will be provided in accordance with the timing requirements of the **Bilateral Agreement** and/or **Construction Agreement** with that **User**, prior to the time that a **User** connects to the **National Electricity Transmission System** and must be up-dated (in writing) as often as the information contained in them changes.
- OC9.6.3 Following notification of an **Event** under **OC7**, **The Company** or a **User**, as the case may be, will, if it considers necessary, telephone the **User** or **The Company**, as the case may be, on the telephone number referred to in OC9.6.2, to obtain such additional information as it requires.
- OC9.6.4 Following notification of an **Event** under **OC7**, and/or the receipt of any additional information requested pursuant to OC9.6.3, **The Company** or a **User**, as the case may be, will determine whether or not the **Event** is a **Joint System Incident**, and, if so, **The Company** and/or the **User** may set up an **Incident Centre** in order to avoid overloading the existing, operational/control arrangements be they **The Company's** or **User's**.
- OC9.6.5 Where **The Company** has determined that an **Event** is a **Joint System Incident**, **The Company** shall, as soon as possible, notify all relevant **Users** that a **Joint System Incident** has occurred and, if appropriate, that it has established an **Incident Centre** and the telephone number(s) of its **Incident Centre** if different from those already supplied pursuant to OC9.6.2.
- OC9.6.6 If a **User** establishes an **Incident Centre** it shall, as soon as possible, notify **The Company** that it has been established and the telephone number(s) of the **Incident Centre** if different from those already supplied pursuant to OC9.6.2.
- OC9.6.7 **The Company's Incident Centre** and/or the **User's Incident Centre** will not assume any responsibility for the operation of the **National Electricity Transmission System** or **User's System**, as the case may be, but will be the focal point in **The Company** or the **User**, as the case may be, for:
- (a) the communication and dissemination of information between **The Company** and the senior management representatives of **User(s)**; or
- (b) between the **User** and the senior management representatives of **The Company**, as the case may be,
- relating to the **Joint System Incident**. The term "**Incident Centre**" does not imply a specially built centre for dealing with **Joint System Incidents**, but is a communications focal point. During a **Joint System Incident**, the normal communication channels, for operational/control communication between **The Company** and **Users** will continue to be used.
- OC9.6.8 All communications between the senior management representatives of the relevant parties with regard to **The Company's** role in the **Joint System Incident** shall be made via **The Company's Incident Centre** if it has been established.
- OC9.6.9 All communications between the senior management representatives of **The Company** and a **User** with regard to that **User's** role in the **Joint System Incident** shall be made via that **User's Incident Centre** if it has been established.
- OC9.6.10 **The Company** will decide when conditions no longer justify the need to use its **Incident Centre** and will inform all relevant **Users** of this decision.

OC9.6.11 Each **User** which has established an **Incident Centre** will decide when conditions no longer justify the need to use that **Incident Centre** and will inform **The Company** of this decision.

APPENDIX 1 – SYSTEM RESTORATION REGIONS



APPENDIX 2 – ELECTRICITY SYSTEM RESTORATION STANDARD OVERVIEW



* Other User's Auxiliaries covers CUSC Parties and Restoration Service Providers

< END OF OPERATING CODE NO. 9 >

|