

## Special Grid Code Review Panel Headline Report – 12 July 2023

### Special Grid Code Review Panel to complete GC0156 DFMR Process

The Headline Report is produced after every Panel and aims to provide an overview of the key decisions made. Minutes for this meeting will be published separately.

### Draft Final Modification Reports

---

The following Draft Final Modification Report was presented to the Panel:

#### **GC0156: Facilitating the Implementation of the Electricity System Restoration Standard**

In October 2021, BEIS issued a direction in accordance with Special Condition 2.2 of National Grid's Electricity System Operator's Transmission Licence implementing an Electricity System Restoration Standard (ESRS) which requires 60% of electricity demand to be restored within 24 hours in all regions and 100% of electricity demand to be restored within 5 days nationally. The ESO is proposing a number of changes to the Grid Code to facilitate this.

The Panel agreed that all changes required to the legal text were typographical and instructed the Code Administrator to make the change under GR.22.4(i).

Panel agreed that by majority the Original and WAGCM1 better facilitated the Grid Code Objectives than the baseline. The Panel also recommended by majority that WAGCM1 (8 out of 10 votes) was the best option. The Final Modification Report will be sent to Ofgem on 24 July 2023.

GC0156 documentation can be found [here](#)

---

### Questions or feedback?

---

**Panel Secretary:** Milly Lewis, *Code Administrator*

**Code Admin Technical Secretary:** Shazia Akhtar, *Code Administrator*

**Email:** [grid.code@nationalgrideso.com](mailto:grid.code@nationalgrideso.com)

---