


# National Electricity Transmission System Performance Report

Report to the Office of Gas and Electricity Markets (Ofgem)

2022 – 23



# Contents

|   |           |  |  |
|---|-----------|--|--|
| <b>INTRODUCTION</b>   | <b>03</b> |  |  |
| <b>Section One</b>  |           |  |  |
| <b>National Electricity Transmission System</b>                         |           |  |  |
| <b>Availability</b>   | <b>04</b> |  |  |
| Annual System Availability  |           |  |  |
| Winter Peak System Availability   |           |  |  |
| Monthly System Availability   |           |  |  |
| <b>Security</b>   | <b>05</b> |  |  |
| Number of Loss of Supply Incidents                                      |           |  |  |
| Total Estimated Unsupplied Energy                                       |           |  |  |
| Reliability of Supply   |           |  |  |
| <b>Quality of Service</b>   | <b>08</b> |  |  |
| Voltage Excursions  |           |  |  |
| Frequency Excursions  |           |  |  |
| Frequency Standard Deviation  |           |  |  |
| <b>Section Two</b>  |           |  |  |
| <b>National Grid Electricity Transmission System System Description</b> |           |  |  |
| <b>Availability</b>   | <b>10</b> |  |  |
| Annual System Availability  |           |  |  |
| Winter Peak System Availability   |           |  |  |
| Monthly System Availability   |           |  |  |
| Monthly Planned and Unplanned Unavailability                            |           |  |  |
| <b>Security</b>   | <b>12</b> |  |  |
| Number of Loss of Supply Incidents                                      |           |  |  |
| Total Estimated Unsupplied Energy                                       |           |  |  |
| Reliability of Supply   |           |  |  |
| Loss of Supply Incident Details   |           |  |  |
| <b>Section Three</b>  |           |  |  |
| <b>Scottish Power Transmission System System Description</b>            |           |  |  |
| <b>Availability</b>   | <b>16</b> |  |  |
| Annual System Availability  |           |  |  |
| Winter Peak System Availability   |           |  |  |
| Monthly System Availability   |           |  |  |
| Monthly Planned and Unplanned Unavailability                            |           |  |  |
| <b>Security</b>   | <b>19</b> |  |  |
| Number of Loss of Supply Incidents                                      |           |  |  |
| Total Estimated Unsupplied Energy                                       |           |  |  |
| Reliability of Supply   |           |  |  |
| Loss of Supply Incident Details   |           |  |  |
| <b>Section Four</b>   |           |  |  |
| <b>Scottish Hydro Electric Transmission System System Description</b>   |           |  |  |
| <b>Availability</b>   | <b>22</b> |  |  |
| Annual System Availability  |           |  |  |
| Winter Peak System Availability   |           |  |  |
| Monthly System Availability   |           |  |  |
| Monthly Planned and Unplanned Unavailability                            |           |  |  |
| <b>Security</b>   | <b>25</b> |  |  |
| Number of Loss of Supply Incidents                                      |           |  |  |
| Total Estimated Unsupplied Energy                                       |           |  |  |
| Reliability of Supply   |           |  |  |
| Loss of Supply Incident Details   |           |  |  |
| <b>Section Five</b>   |           |  |  |
| <b>Interconnectors</b>  |           |  |  |
| <b>England – France Interconnector</b>                                  | <b>28</b> |  |  |
| System Description  |           |  |  |
| Annual Availability   |           |  |  |
| Monthly Unavailability  |           |  |  |
| Outages   |           |  |  |
| <b>England – Netherlands Interconnector</b>                             | <b>30</b> |  |  |
| System Description  |           |  |  |
| Annual Availability   |           |  |  |
| Monthly Unavailability  |           |  |  |
| Outages   |           |  |  |
| <b>England – Belgium Interconnector</b>                                 | <b>32</b> |  |  |
| System Description  |           |  |  |
| Annual Availability   |           |  |  |
| Monthly Unavailability  |           |  |  |
| Outages   |           |  |  |
| <b>England – France Interconnector 2</b>                                | <b>34</b> |  |  |
| System Description  |           |  |  |
| Annual Availability   |           |  |  |
| Monthly Unavailability  |           |  |  |
| Outages   |           |  |  |
| <b>England – Norway Interconnector</b>                                  | <b>36</b> |  |  |
| System Description  |           |  |  |
| Annual Availability   |           |  |  |
| Monthly Unavailability  |           |  |  |
| Outages   |           |  |  |
| <b>Section Six</b>  |           |  |  |
| <b>Offshore Systems</b>   |           |  |  |
| System Description  |           |  |  |
| Offshore Transmission Networks  | <b>38</b> |  |  |
| <b>Availability</b>   | <b>39</b> |  |  |
| Annual System Availability  |           |  |  |
| Winter Peak System Availability   |           |  |  |
| Monthly System Availability   |           |  |  |
| Monthly Planned and Unplanned System Unavailability                     |           |  |  |
| Outage Details  |           |  |  |
| <b>GLOSSARY OF TERMS</b>  | <b>50</b> |  |  |

# National Electricity Transmission System Performance Report

## Introduction

### **This report details the performance of the National Electricity Transmission System in Great Britain for 2022-23, as required by Transmission Licence Standard Condition C17: Transmission System Security Standard and Quality of Service.**

The National Electricity Transmission System (NETS) in Great Britain is comprised of both onshore and offshore transmission networks.

The onshore transmission networks are owned by National Grid Electricity Transmission plc (NGET) in England and Wales, SP Transmission plc (SPT) in south and central Scotland and Scottish Hydro Electric Transmission plc (SHE Transmission) in the north of Scotland. There is also a 2250MW HVDC undersea link between Hunterston in Western Scotland and Flintshire Bridge in North Wales, that is jointly owned by SPT and NGET.

The offshore transmission networks are owned by Transmission Capital (TC), Blue Transmission Investments Ltd (BT), Greater Gabbard OFTO plc, Gwynt-Y-Mor OFTO plc, Thanet OFTO Ltd, Humber Gateway OFTO Ltd, West of Duddon Sands (WoDS) Transmission plc, Diamond Transmission Partners (DTP) BBE Ltd, DTP RB Ltd, DTP Galloper Ltd, DTP Walney Extension Ltd and DTP Hornsea One Ltd.

Following legal separation of the Electricity System Operator from NGET on 1st April 2019, National Grid Electricity System Operator Ltd became the National Electricity Transmission System Operator (NETSO) for the onshore and offshore transmission networks.

In accordance with Standard Licence Condition C17 (Transmission System Security Standard and Quality of

Service) of the Transmission Licence, the NETSO is required by the Office of Gas and Electricity Markets, to report on the annual performance of the National Electricity Transmission System in terms of availability, system security and quality of service.

The onshore and offshore transmission system broadly comprises circuits operating at 400, 275 and 132kV. The formal definition of the National Electricity Transmission System is contained in the NETS Grid Code and NETS Security and Quality of Supply Standard (NETS SQSS).

The fully interconnected transmission system provides a consistently high quality of supply and allows for the efficient bulk transfer of power from remote generation to demand centres.

Information relating to NG Electricity Transmission plc, SP Transmission plc, SHE Transmission plc, TC Robin Rigg OFTO Ltd, TC Barrow OFTO Ltd, TC Gunfleet Sands OFTO Ltd, TC Ormonde OFTO Ltd, TC Lincs OFTO Ltd, TC Westernmost Rough OFTO Ltd, TC Dudgeon OFTO plc, TC Beatrice OFTO Ltd, TC Rampion OFTO Ltd, TC East Anglia One OFTO Ltd, BT Walney 1 Ltd, BT Walney 2 Ltd, BT Sheringham Shoal Ltd, BT London Array Ltd, Greater Gabbard OFTO plc, Gwynt-Y-Mor OFTO plc, Thanet OFTO Ltd, Humber Gateway OFTO Ltd, WoDS Transmission plc, DTP BBE Ltd, DTP RB Ltd, DTP

Galloper Ltd, DTP Walney Extension Ltd and DTP Hornsea One Ltd have been provided by the Transmission Owners in accordance with Licence Condition D3 (Transmission System Security Standard and Quality of Service) of their Transmission Licences.

When considering the performance of the transmission networks it should be recognised that this can be influenced by both the Transmission Owners and the NETSO.

The National Electricity Transmission System is connected via interconnectors to transmission systems in Northern Ireland, Republic of Ireland, France, the Netherlands, Belgium and Norway.

The interconnectors with Northern Ireland and the Republic of Ireland fall outside the scope of this report, as they are regulated by the Northern Ireland Authority for Utility Regulation (NIAUR) and the Commission for Regulation of Utilities (CRU) respectively. The ElecLink interconnector is also excluded as it is regulated by Commission De Régulation De L'Énergie (CRE) of France.

Information relating to interconnectors with France (Interconnexion France–Angleterre IFA and IFA2), the Netherlands (BritNed), Belgium (Nemo Link) and Norway (North Sea Link) has been provided by National Grid Ventures.

# National Electricity Transmission System (GB Network)

## Availability

The definitions and criteria for system availability can be found in the Glossary of terms at the end of this report.


### Annual System Availability

**Annual System Availability of the National Electricity Transmission System for 2022-23 was: 95.24%**

**National Electricity Transmission System performance is monitored by reporting variations in Annual System Availability, Winter Peak System Availability and Monthly System Availability.**


### % Annual System Availability

| GB % Annual System Availability |         |         |         |         |
|---------------------------------|---------|---------|---------|---------|
| 2018-19                         | 2019-20 | 2020-21 | 2021-22 | 2022-23 |
| 94.55                           | 94.69   | 94.50   | 94.99   | 95.24   |




### % Winter Peak System Availability

| GB % Winter Peak System Availability |         |         |         |         |
|--------------------------------------|---------|---------|---------|---------|
| 2018-19                              | 2019-20 | 2020-21 | 2021-22 | 2022-23 |
| 97.05                                | 96.72   | 96.22   | 97.19   | 97.03   |



### % Monthly System Availability



| GB % Monthly System Availability |         |         |         |         |         |
|----------------------------------|---------|---------|---------|---------|---------|
|                                  | 2018-19 | 2019-20 | 2020-21 | 2021-22 | 2022-23 |
| Apr                              | 94.00   | 93.88   | 96.84   | 93.83   | 94.48   |
| May                              | 93.39   | 93.77   | 94.68   | 93.55   | 94.73   |
| Jun                              | 92.80   | 93.16   | 93.24   | 93.22   | 94.47   |
| Jul                              | 92.39   | 93.11   | 94.43   | 93.16   | 93.70   |
| Aug                              | 92.97   | 93.51   | 92.92   | 93.31   | 93.60   |
| Sep                              | 93.55   | 93.71   | 92.90   | 92.96   | 94.28   |
| Oct                              | 93.52   | 93.52   | 93.10   | 93.40   | 94.72   |
| Nov                              | 95.26   | 95.70   | 94.32   | 95.21   | 95.38   |
| Dec                              | 97.24   | 97.05   | 96.45   | 97.01   | 97.01   |
| Jan                              | 97.29   | 96.89   | 96.58   | 97.39   | 97.63   |
| Feb                              | 96.58   | 96.17   | 95.57   | 96.78   | 96.99   |
| Mar                              | 95.74   | 95.80   | 95.30   | 95.73   | 95.86   |


### Security

The definitions and criteria for system security can be found in the Glossary of terms at the end of this report.

**System performance is monitored by the Estimated Unsupplied Energy from the National Electricity Transmission System for each incident.**

**During 2022-23 there were 619 NETS events where transmission circuits were disconnected either automatically or by urgent manual switching. The vast majority of these events had no impact on electricity users with 16 resulting in loss of supplies to customers.**

### GB System Events




| GB System Events |         |         |         |         |         |
|------------------|---------|---------|---------|---------|---------|
|                  | 2018-19 | 2019-20 | 2020-21 | 2021-22 | 2022-23 |
| NGET             | 347     | 355     | 455     | 517     | 412     |
| SPT              | 157     | 131     | 138     | 115     | 118     |
| SHET             | 108     | 100     | 113     | 119     | 89      |
| GB               | 612     | 586     | 706     | 751     | 619     |

### Number of Loss of Supply Incidents

The chart shows the annual comparison of the number of Loss of Supply Incidents that occurred within the National Electricity Transmission System.

| GB System – Number of Incidents |         |         |         |         |         |
|---------------------------------|---------|---------|---------|---------|---------|
|                                 | 2018-19 | 2019-20 | 2020-21 | 2021-22 | 2022-23 |
| Incentivised                    | 10      | 6       | 5       | 5       | 1       |
| Non-Incentivised                | 12      | 14      | 20      | 13      | 15      |




### Total Estimated Unsupplied Energy

The total Estimated Unsupplied Energy from the National Electricity Transmission System during 2022-23 was: **43.68 MWh**

The chart shows the annual comparison of the Estimated Unsupplied Energy for Loss of Supply Incidents that occurred within the National Electricity Transmission System.

| GB System – Estimated Unsupplied Energy (MWh) |         |         |         |         |         |
|---|---------|---------|---------|---------|---------|
|   | 2018-19 | 2019-20 | 2020-21 | 2021-22 | 2022-23 |
| Incentivised                                  | 51.14   | 57.59   | 47.98   | 26.84   | 5.20    |
| Non-Incentivised                              | 34.31   | 26.10   | 76.85   | 928.03  | 38.48   |



### Reliability of Supply

The Overall Reliability of Supply for the National Electricity Transmission System during 2022-23 was: **99.99981%**

compared with 99.999612% in 2021-22 and 99.999948% in 2020-21.



## Quality of Service

Quality of service is measured with reference to system Voltage and Frequency. The criteria for reportable Voltage and Frequency Excursions can be found in the Glossary of terms at the end of this report.


### Voltage Excursions

During 2022-23 there were no reportable Voltage Excursions within the National Electricity Transmission System.

The chart below summarises the reportable Voltage Excursions that have occurred on the National Electricity Transmission System.

### GB System Voltage Excursions

| GB System – Voltage Excursions |         |         |         |         |         |
|--------------------------------|---------|---------|---------|---------|---------|
|                                | 2018-19 | 2019-20 | 2020-21 | 2021-22 | 2022-23 |
| Number of NGET Excursions      | 1       | 0       | 0       | 0       | 0       |
| Number of SPT Excursions       | 1       | 0       | 0       | 0       | 0       |
| Number of SHET Excursions      | 0       | 0       | 0       | 0       | 0       |



## GB System Voltage Excursion


| Incident Date, Time and Location | Nominal Voltage | Max Voltage | Duration |
|----------------------------------|-----------------|-------------|----------|
| None                             |                 |             |          |

### Frequency Excursions

During 2022-23, there were no reportable Frequency Excursion within the National Electricity Transmission System. The previous Frequency Excursions were in the 2019-20 and 2008-09 reporting periods.

### GB System Frequency Excursions

| GB System – Frequency Excursions |         |         |         |         |         |
|----------------------------------|---------|---------|---------|---------|---------|
|                                  | 2018-19 | 2019-20 | 2020-21 | 2021-22 | 2022-23 |
| Number of Excursions             | 0       | 1       | 0       | 0       | 0       |



## GB System Frequency Excursion



| Incident Date & Time | Statutory Limits | Frequency | Duration  |
|----------------------|------------------|-----------|-----------|
| None                 | 49.5 - 50.5Hz    | N/A       | 0 seconds |



### Frequency Standard Deviation

The chart below displays the recorded Frequency Standard Deviation from 50Hz on a weekly basis for the year 2022-23.

#### GB System – Frequency Standard Deviation



# National Grid Electricity Transmission System

## System Description

The National Grid Electricity Transmission System operates at 400, 275 and 132kV supplying electricity to England and Wales.

The system covers an area of approximately 151,000 square kilometres and consists of over 14,000 circuit kilometres of overhead line and over 650 kilometres of underground transmission cable routes interconnecting over 300 substations.

It is connected to the SP Transmission System to the north and through six HVDC

interconnectors to the Republic of Ireland, France, the Netherlands, Belgium and Norway.

There are 68 large power stations totalling 55GW of generation capacity connected to the England and Wales transmission system. The NGET system supplies 12 distribution networks via over 132GVA of installed transformer capacity and a small number of directly connected customers such as steelworks and traction supplies.

In 2022-23 the maximum recorded demand on the network was 41.62GW.


## Availability

The definitions and criteria for system availability can be found in the Glossary of terms at the end of this report.


**System performance is monitored by reporting variations in Annual System Availability, Winter Peak System Availability and Monthly System Availability. There is also a breakdown of Planned and Unplanned System Unavailability.**

### % Annual System Availability

| NGET % Annual System Availability |         |         |         |         |
|-----------------------------------|---------|---------|---------|---------|
| 2018-19                           | 2019-20 | 2020-21 | 2021-22 | 2022-23 |
| 93.45                             | 93.88   | 93.76   | 94.38   | 94.83   |




**% Winter Peak System Availability**



| 2018-19 | 2019-20 | 2020-21 | 2021-22 | 2022-23 |
|---------|---------|---------|---------|---------|
| 96.37   | 96.26   | 95.84   | 96.86   | 97.04   |

**% Monthly System Availability**




|     | 2018-19 | 2019-20 | 2020-21 | 2021-22 | 2022-23 |
|-----|---------|---------|---------|---------|---------|
| Apr | 92.91   | 92.73   | 96.41   | 93.04   | 93.80   |
| May | 92.19   | 92.92   | 93.49   | 92.56   | 94.05   |
| Jun | 91.16   | 92.08   | 92.25   | 92.25   | 93.68   |
| Jul | 91.09   | 91.78   | 94.24   | 91.91   | 92.81   |
| Aug | 91.88   | 92.25   | 91.56   | 92.58   | 93.17   |
| Sep | 92.17   | 92.74   | 92.08   | 91.85   | 93.71   |
| Oct | 92.07   | 92.39   | 92.26   | 91.68   | 93.74   |
| Nov | 94.08   | 95.60   | 94.19   | 94.11   | 95.40   |
| Dec | 96.57   | 96.84   | 95.95   | 96.65   | 97.34   |
| Jan | 96.63   | 96.38   | 96.21   | 97.05   | 97.61   |
| Feb | 95.85   | 95.51   | 95.31   | 96.22   | 97.08   |
| Mar | 95.00   | 95.38   | 95.12   | 95.32   | 95.57   |

**Monthly Planned and Unplanned System Unavailability**

The table and the chart show the monthly variation in Planned and Unplanned System Unavailability.

Unavailability is defined as (100 – Availability) %



|     | User Connection | System Construction | Maintenance | Unplanned | Total |
|-----|-----------------|---------------------|-------------|-----------|-------|
| Apr | 0.51            | 3.33                | 1.53        | 0.83      | 6.20  |
| May | 0.54            | 3.38                | 1.54        | 0.48      | 5.95  |
| Jun | 0.81            | 3.66                | 1.31        | 0.54      | 6.32  |
| Jul | 0.90            | 4.12                | 1.02        | 1.15      | 7.19  |
| Aug | 0.80            | 3.97                | 1.24        | 0.83      | 6.83  |
| Sep | 0.59            | 3.30                | 1.45        | 0.95      | 6.29  |
| Oct | 0.68            | 2.89                | 1.75        | 0.93      | 6.26  |
| Nov | 0.76            | 1.81                | 1.17        | 0.87      | 4.60  |
| Dec | 0.50            | 0.71                | 0.46        | 1.00      | 2.66  |
| Jan | 0.22            | 0.77                | 0.31        | 1.09      | 2.39  |
| Feb | 0.32            | 1.49                | 0.48        | 0.62      | 2.92  |
| Mar | 0.31            | 1.65                | 1.23        | 1.25      | 4.43  |

## Security

The definitions and criteria for system security can be found in the Glossary of terms at the end of this report.


System performance is monitored by the Estimated Unsupplied Energy from the NGET Transmission System for each incident.

During 2022-23 there were 412 NGET system events where transmission circuits were disconnected either automatically or by urgent manual switching. The vast majority of these events had no impact on electricity users with 11 resulting in loss of supplies to customers.

### Number of Loss of Supply Incidents

The chart shows the annual comparison of the number of Loss of Supply Incidents that occurred within the NGET Transmission System.

| NGET System – Number of incidents |         |         |         |         |         |
|-----------------------------------|---------|---------|---------|---------|---------|
|                                   | 2018-19 | 2019-20 | 2020-21 | 2021-22 | 2022-23 |
| Incentivised                      | 1       | 4       | 1       | 3       | 1       |
| Non-Incentivised                  | 2       | 5       | 9       | 8       | 10      |




### Total Estimated Unsupplied Energy

The total Estimated Unsupplied Energy from the NGET Transmission System during 2022-23 was: **7.10 MWh**

The chart shows the annual comparison of the Estimated Unsupplied Energy for Loss of Supply Incidents that occurred within the NGET Transmission System.

| NGET System – Estimated Unsupplied Energy (MWh) |         |         |         |         |         |
|---|---------|---------|---------|---------|---------|
|   | 2018-19 | 2019-20 | 2020-21 | 2021-22 | 2022-23 |
| Incentivised                                    | 12.06   | 54.45   | 0.00    | 26.70   | 5.20    |
| Non-Incentivised                                | 25.16   | 4.98    | 74.36   | 116.70  | 1.90    |





### Reliability of Supply


The Overall Reliability of Supply for the NGET Transmission System during 2022-23 was: **99.999997%**

compared with 99.999936% in 2021-22 and 99.999966% in 2020-21.

### Loss of Supply Incident Details

#### NGET Loss of Supply Incidents – Incentivised

| Incident Date, Time and Location  | MW Lost | Mins | MWh Unsupplied |
|---|---------|------|----------------|
| <b>24 August 2022 12:54 at Watford South 275/132kV Substation</b><br>Protection operated on SGT3A at Watford South 275kV substation and tripped the SGT3A/3B banked transformer pair. Due to existing outages and the resultant running arrangement adopted at Watford South 132kV substation, the loss of SGT3A/3B meant that around 81,000 customers were disconnected. All demand was restored via four stages of UKPN switching in 4 minutes and 18 seconds | 79.9    | 4*   | 5.20           |
| <b>Total</b>  |         |      | <b>5.20</b>    |



## NGET Loss of Supply Incidents – Non-Incentivised

| Incident Date, Time and Location   | MW Lost | Mins | MWh Unsupplied |
|--|---------|------|----------------|
| <b>15 April 2022 04:17 at Rugeley 400/25kV Substation</b><br>At Rugeley 400kV substation, Main Busbar 2 busbar protection operated, tripping all circuits selected to it. One of these circuits was SGT4 which supplies Network Rail Brereton demand, although no demand was being taken at the time of the trip. The cause of the trip was not identified. SGT3 circuit was available to supply demand at all times without the need for further action to be taken by NGET, this is a customer choice connection site.   | 0.0     | 10   | 0.00           |
| <b>21 April 2022 22:29 at Rugeley 400/25kV Substation</b><br>At Rugeley 400kV substation, Reserve Busbar 1/2 busbar protection operated, tripping all circuits selected to it. One of these circuits was SGT4 which supplies Network Rail Brereton demand, although no demand was being taken at the time of the trip. The cause of the trip was not identified. SGT3 circuit was available to supply demand at all times without the need for further action to be taken by NGET, this is a customer choice connection site.  | 0.0     | 2    | 0.00           |
| <b>24 April 2022 01:31 at Rugeley 400/25kV Substation</b><br>At Rugeley 400kV substation, Reserve Busbar 1/2 busbar protection operated, tripping all circuits selected to it. One of these circuits was SGT4 which supplies Network Rail Brereton demand, although no demand was being taken at the time of the trip. The cause of the trip was not identified. SGT3 circuit was available to supply demand at all times without the need for further action to be taken by NGET, this is a customer choice connection site.  | 0.0     | 3    | 0.00           |
| <b>17 July 2022 04:10 at Barking 132/25kV Substation</b><br>At Barking 132kV substation, Barking Grid T4B tripped. This is one of two transformers which supply Network Rail at Barking, although no demand was being taken at the time of the trip. Investigations showed the cause of the trip to be a helium balloon that had drifted too close to the live circuit. Grid T1B circuit was available to supply demand at all times without the need for further action to be taken by NGET, this is a customer choice connection site.   | 0.0     | 10   | 0.00           |
| <b>03 August 2022 17:45 at Barking 132/25kV Substation</b><br>At Barking 132kV substation, Barking Grid T4B tripped on low voltage overcurrent protection, indicating it had been overloaded. This is one of two transformers which supply Network Rail at Barking, although they are not interconnected at the LV side so the load was not being shared equally. Network Rail confirmed their network had been running in an abnormal configuration which was likely to have led to the unintentional overloading. Grid T1B circuit was available to supply demand at all times without the need for further action to be taken by NGET, this is a customer choice connection site. | 23.4    | 3    | 1.10           |
| <b>17 August 2022 17:01 at Singlewell 400/25kV Substation</b><br>At Singlewell 400kV substation, SGT1 circuit tripped. UKPN own SGT1 and NGET own the associated 400kV circuit breaker. UKPN confirmed that they were undertaking work on the out of service SGT2 circuit and had inadvertently caused SGT1 to trip. No demand was being supplied at the time.   | 0.0     | 2    | 0.00           |
| <b>30 September 2022 09:01 at Rugeley 400/25kV Substation</b><br>At Rugeley 400kV substation, SGT3 circuit tripped due to a falling branch. SGT4 circuit was available to supply demand at all times without the need for further action to be taken by NGET, this is a customer choice connection site.   | 1.5     | 2    | 0.10           |
| <b>21 December 2022 12:30 at Iron Acton 132kV Substation</b><br>At Iron Acton 132kV substation, Main Busbar 1 and Reserve Busbar 1 tripped, along with all associated circuits. Investigations confirmed that a fault had occurred on Bus Coupler circuit breaker 130. Some NGED demand was picked up immediately via lower voltage interconnections, and NGED undertook switching in very short timescales to restore the remainder of the demand..   | 37.1    | 2*   | 0.60           |
| <b>24 March 2023 14:15 at Redbridge 275/33kV Substation</b><br>At Redbridge 275/33kV substation, SGT2, mesh corner 2 and the Barking - Redbridge 2 circuit tripped. SGT2 auto-isolated and the 275kV circuit was automatically returned to service. The auto-close scheme at Redbridge 33kV substation operated within 1 second to restore demand to all disconnected customers. Investigations have found evidence that lightning struck SGT2 directly.   | 49.4    | 0    | 0.10           |
| <b>31 March 2023 05:33 at Tinsley Park 275/33kV Substation</b><br>SGT1B auxiliary transformer buchholz gas alarm operated, therefore it was necessary to switch SGT1B circuit out of service for further investigations. With SGT2B already out of service, SGT1B was the only circuit supplying the steelworks furnace demand. The steelworks shift manager confirmed there was no furnace demand being taken and agreed to the switch out of the circuit. Upon investigation it was found that the alarm was not genuine - weather conditions had caused a false alarm. This is a customer choice connection site.   | 0.0     | 762  | 0.00           |
| <b>Total</b>   |         |      | <b>1.90</b>    |

\*Minutes quoted is the overall time following staged restoration to customers.

# Scottish Power Transmission System

## System Description

The SPT Transmission System comprises approximately 4,000 circuit kilometres of overhead line and cable and 159 substations operating at 400, 275 and 132kV supplying approximately 2 million customers and covering an area of 22,951 square kilometres. It is connected to the SHE Transmission System to the north, the NGET Transmission System to the south and the Northern Ireland Transmission System via an HVDC interconnector.

There are 9 major demand customers supplied directly from the SP Transmission System with the majority of the load being taken by approximately 2 million customers connected to the SP Distribution System via 14.8GVA of installed transformer capacity. There is approximately 6.4GW of directly connected and Large Embedded generation capacity connected in the SP Transmission area, including 47 power stations directly connected to the SP Transmission system. In 2022-23 the maximum recorded demand on the network was 3.98GW.


## Availability

The definitions and criteria for system availability can be found in the Glossary of terms at the end of this report.

**System performance is monitored by reporting variations in Annual System Availability, Winter Peak System Availability and Monthly System Availability. There is also a breakdown of Planned and Unplanned System Unavailability.**


### % Annual System Availability

| SPT % Annual System Availability |         |         |         |         |
|----------------------------------|---------|---------|---------|---------|
| 2018-19                          | 2019-20 | 2020-21 | 2021-22 | 2022-23 |
| 95.31                            | 93.90   | 94.00   | 94.67   | 94.25   |






### % Winter Peak System Availability



| SPT % Winter Peak System Availability |         |         |         |         |
|---------------------------------------|---------|---------|---------|---------|
| 2018-19                               | 2019-20 | 2020-21 | 2021-22 | 2022-23 |
| 97.55                                 | 95.64   | 95.24   | 97.11   | 95.88   |

### % Monthly System Availability




| SPT % Monthly System Availability |         |         |         |         |         |
|-----------------------------------|---------|---------|---------|---------|---------|
|                                   | 2018-19 | 2019-20 | 2020-21 | 2021-22 | 2022-23 |
| Apr                               | 94.80   | 93.21   | 96.61   | 93.81   | 93.91   |
| May                               | 94.16   | 93.29   | 95.61   | 94.06   | 94.05   |
| Jun                               | 94.35   | 93.01   | 92.82   | 93.31   | 94.16   |
| Jul                               | 93.24   | 93.15   | 93.27   | 93.81   | 93.45   |
| Aug                               | 93.79   | 93.43   | 92.81   | 91.95   | 92.29   |
| Sep                               | 94.41   | 93.12   | 92.51   | 92.07   | 92.25   |
| Oct                               | 94.27   | 92.40   | 92.81   | 94.68   | 94.41   |
| Nov                               | 96.36   | 93.56   | 92.53   | 96.04   | 94.03   |
| Dec                               | 97.87   | 95.39   | 95.75   | 96.67   | 95.31   |
| Jan                               | 97.58   | 96.08   | 95.77   | 97.57   | 97.25   |
| Feb                               | 97.17   | 95.44   | 94.09   | 97.08   | 94.99   |
| Mar                               | 95.69   | 94.69   | 93.39   | 95.11   | 94.76   |

### Monthly Planned and Unplanned System Unavailability

The table and the chart show the monthly variation in Planned and Unplanned System Unavailability.

Unavailability is defined as (100 – Availability) %



| Planned and Unplanned Unavailability (%) for SP Transmission System |                 |                     |             |           |       |
|---|-----------------|---------------------|-------------|-----------|-------|
|   | User Connection | System Construction | Maintenance | Unplanned | Total |
| Apr   | 0.00            | 2.46                | 2.04        | 1.60      | 6.09  |
| May   | 0.00            | 2.30                | 1.95        | 1.70      | 5.95  |
| Jun   | 0.00            | 2.21                | 2.15        | 1.48      | 5.84  |
| Jul   | 0.00            | 2.18                | 2.76        | 1.62      | 6.55  |
| Aug   | 0.00            | 3.44                | 2.29        | 1.97      | 7.71  |
| Sep   | 0.00            | 2.64                | 2.85        | 2.26      | 7.75  |
| Oct   | 0.00            | 2.07                | 1.78        | 1.74      | 5.59  |
| Nov   | 0.00            | 2.11                | 2.40        | 1.45      | 5.97  |
| Dec   | 0.00            | 1.57                | 1.61        | 1.50      | 4.69  |
| Jan   | 0.00            | 0.63                | 0.67        | 1.45      | 2.75  |
| Feb   | 0.00            | 1.68                | 1.67        | 1.66      | 5.01  |
| Mar   | 0.00            | 1.91                | 2.19        | 1.14      | 5.24  |



## Security

The definitions and criteria for system security can be found in the Glossary of terms at the end of this report.


**System performance is monitored by the estimated unsupplied energy from the SP Transmission System for each incident.**

**During 2022-23 there were 118 SPT system events where transmission circuits were disconnected either automatically or by urgent manual switching. The vast majority of these events had no impact on electricity users with 3 resulting in loss of supply to customers.**

### Number of Loss of Supply Incidents

The chart shows the annual comparison of the number of Loss of Supply Incidents that occurred within the SP Transmission System.

|                  | 2018-19 | 2019-20 | 2020-21 | 2021-22 | 2022-23 |
|------------------|---------|---------|---------|---------|---------|
| Incentivised     | 9       | 1       | 4       | 2       | 0       |
| Non-Incentivised | 8       | 8       | 8       | 2       | 3       |




### Total Estimated Unsupplied Energy

The total Estimated Unsupplied Energy from the SP Transmission System during 2022-23 was: **3.81 MWh**

The chart shows the annual comparison of the Estimated Unsupplied Energy for Loss of Supply Incidents that occurred within the SP Transmission System.

|                  | 2018-19 | 2019-20 | 2020-21 | 2021-22 | 2022-23 |
|------------------|---------|---------|---------|---------|---------|
| Incentivised     | 39.08   | 1.99    | 47.98   | 0.14    | 0.00    |
| Non-Incentivised | 0.35    | 1.22    | 0.00    | 0.00    | 3.81    |



### Reliability of Supply

The Overall Reliability of Supply for the SP Transmission System during 2022-23 was: **99.999975%**

compared with 99.999999% in 2021-22 and 99.999688% in 2020-21.

### Loss of Supply Incident Details

#### SPT Loss of Supply Incidents – Incentivised

| SPT Loss of Supply Incidents – Incentivised | MW Lost | Mins | MWh Unsupplied |
|---|---------|------|----------------|
| <b>Total</b>                                |         |      | <b>0.00</b>    |

#### SPT Loss of Supply Incidents – Non-Incentivised

| Incident Date, Time and Location   | MW Lost | Mins | MWh Unsupplied |
|--|---------|------|----------------|
| <b>15 August 2022 06:52 at New Cumnock - Blackcraig - Black Craig South</b><br>Trip and Auto-Reclose on the New Cumnock - Blackcraig - Black Craig South circuit trip, Number 1 circuit, due to lightning. Affecting 1 customer for 19 minutes.  | 0.0     | 19   | 0.00           |
| <b>17 September 2022 22:20 at New Cumnock - Blackcraig - Black Craig South</b><br>New Cumnock -Blackcraig Main Protection & 1st Intertrip Fault. Circuit switched out of service, resulting in Blackcraig -Black Craig South circuit & Black Craig South Windfarm 33kV feeder circuit being deenergised & Windfarm remaining off until circuit restored.   | 0.0     | 438  | 0.00           |
| <b>14 November 2022 17:44 at Bathgate - Bonnybridge - Drumcross</b><br>Circuit tripped due to an extended mobile crane arm coming into contact with the double circuit 132kV overhead conductor. Bathgate - Drumcross section auto-isolated and Bonnybridge-Bathgate 1 DAR. 5,621 customers off for 11 minutes.<br>*Exceptional Event claim submitted and currently with OFGEM, SPT awaiting response regarding claim. | 18.7    | 11   | 3.81           |
| <b>Total</b>   |         |      | <b>3.81</b>    |



# Scottish Hydro Electric Transmission System

## System Description

The SHE Transmission system comprises of over 199km of 400kV, 1945km of 275kV and 2747km of 132kV overhead line and approximately 991km of AC high voltage underground transmission cables, interconnecting 151 substations. There is also an HVDC link with 163km of cable connecting Caithness to the Moray Coast. The system covers an area of approximately 55,000 square kilometres or 24% of the Great Britain land mass. It is connected to the SP Transmission system to the South and several large Offshore Transmission Owners in the Highlands.

In 2022-23 the maximum recorded demand on the network was 1.34GW. Mostly the demand is taken by approximately 0.8 million customers connected to the Scottish Hydro Electric Power Distribution network via more than 13GVA of installed transformer capacity, with 1 other major customer also supplied directly from the SHE Transmission system. There are a growing number of large generators,

with over 45 directly connected to the SHE Transmission system and many smaller units combining to produce more than 10GW capacity, of which 9.2GW is renewable.

The unreliability of supply figure can be distorted when compared against other systems at 275kV and 400kV due to the higher proportion of 132kV Transmission network and the consequent reduced power flows, however unreliability remains low in our network across all voltages.

80% of these transmission assets form the main interconnected transmission system whilst the remaining 20% radially supply the more remote areas of the territory including the outlying islands. Some connections, mainly in the more remote areas, can involve non-standard connection or running arrangements chosen by the customer and as such might experience greater risk of disruption, but on the whole reliability of the network has been very high.


## Availability

The definitions and criteria for system availability can be found in the Glossary of terms at the end of this report.


**System performance is monitored by reporting variations in Annual System Availability, Winter Peak System Availability and Monthly System Availability. There is also a breakdown of Planned and Unplanned System Unavailability.**

### % Annual System Availability

| SHE Transmission % Annual System Availability |         |         |         |         |
|---|---------|---------|---------|---------|
| 2018-19                                       | 2019-20 | 2020-21 | 2021-22 | 2022-23 |
| 97.09   | 97.83   | 97.17   | 97.07   | 97.19   |




### % Winter Peak System Availability



| 2018-19 | 2019-20 | 2020-21 | 2021-22 | 2022-23 |
|---------|---------|---------|---------|---------|
| 98.61   | 99.10   | 98.30   | 98.22   | 98.03   |

### % Monthly System Availability




|     | 2018-19 | 2019-20 | 2020-21 | 2021-22 | 2022-23 |
|-----|---------|---------|---------|---------|---------|
| Apr | 96.48   | 97.87   | 98.35   | 96.10   | 96.79   |
| May | 96.19   | 96.72   | 97.33   | 95.90   | 97.13   |
| Jun | 96.14   | 96.48   | 96.56   | 95.93   | 96.83   |
| Jul | 95.39   | 96.95   | 96.13   | 96.12   | 96.30   |
| Aug | 95.42   | 97.28   | 97.04   | 96.78   | 95.91   |
| Sep | 96.81   | 97.10   | 95.72   | 97.05   | 97.59   |
| Oct | 97.07   | 97.94   | 95.88   | 97.09   | 97.58   |
| Nov | 97.72   | 98.07   | 96.44   | 97.55   | 96.53   |
| Dec | 98.62   | 99.29   | 98.58   | 98.37   | 97.63   |
| Jan | 98.99   | 99.18   | 98.48   | 98.22   | 98.00   |
| Feb | 98.17   | 98.82   | 97.80   | 98.07   | 98.50   |
| Mar | 97.99   | 98.13   | 97.69   | 97.51   | 97.59   |

### Monthly Planned and Unplanned System Unavailability

The table and the chart show the monthly variation in Planned and Unplanned System Unavailability.

Unavailability is defined as  $(100 - \text{Availability}) \%$



|     | User Connection | System Construction | Maintenance | Unplanned | Total |
|-----|-----------------|---------------------|-------------|-----------|-------|
| Apr | 0.05            | 1.49                | 1.29        | 0.37      | 3.21  |
| May | 0.02            | 1.47                | 0.93        | 0.45      | 2.87  |
| Jun | 0.00            | 1.64                | 0.78        | 0.74      | 3.17  |
| Jul | 0.00            | 1.63                | 1.15        | 0.93      | 3.70  |
| Aug | 0.16            | 1.49                | 1.66        | 0.79      | 4.09  |
| Sep | 0.00            | 0.90                | 0.96        | 0.55      | 2.41  |
| Oct | 0.00            | 1.18                | 0.45        | 0.79      | 2.42  |
| Nov | 0.02            | 1.19                | 1.42        | 0.85      | 3.47  |
| Dec | 0.08            | 0.24                | 1.32        | 0.73      | 2.37  |
| Jan | 0.00            | 0.52                | 0.75        | 0.73      | 2.00  |
| Feb | 0.00            | 0.48                | 0.27        | 0.75      | 1.50  |
| Mar | 0.00            | 1.50                | 0.31        | 0.60      | 2.41  |





## Security

The definitions and criteria for system security can be found in the Glossary of terms at the end of this report.


**System performance is monitored by the Estimated Unsupplied Energy from the SHE Transmission System for each incident.**

**During 2022-23 there were 89 SHE Transmission system events where transmission circuits were disconnected either automatically or by urgent manual switching. The vast majority of these events had no impact on electricity users with 2 resulting in loss of supplies to customers.**

### Number of Loss of Supply Incidents

The chart shows the annual comparison of the number of Loss of Supply Incidents that occurred within the SHE Transmission System.

|                  | 2018-19 | 2019-20 | 2020-21 | 2021-22 | 2022-23 |
|------------------|---------|---------|---------|---------|---------|
| Incentivised     | 0       | 1       | 0       | 0       | 0       |
| Non-Incentivised | 2       | 1       | 3       | 3       | 2       |




### Total Estimated Unsupplied Energy

The total Estimated Unsupplied Energy from the SHE Transmission System during 2022-23 was: **32.77 MWh**

The chart shows the annual comparison of the Estimated Unsupplied Energy for Loss of Supply Incidents that occurred within the SHE Transmission System.

|                  | 2018-19 | 2019-20 | 2020-21 | 2021-22 | 2022-23 |
|------------------|---------|---------|---------|---------|---------|
| Incentivised     | 0.00    | 1.15    | 0.00    | 0.00    | 0.00    |
| Non-Incentivised | 8.80    | 19.90   | 2.49    | 811.33  | 32.77   |



### Reliability of Supply

The Overall Reliability of Supply for the SHE Transmission System during 2022-23 was: **99.999218%**

compared with 99.983546% in 2021-22 and 99.999948% in 2020-21.

### Loss of Supply Incident Details

#### SHE Transmission Loss of Supply Incidents – Incentivised

| Incident Date, Time and Location | MW Lost | Mins | MWh Unsupplied |
|----------------------------------|---------|------|----------------|
| None                             | 0.0     | 0    | 0.00           |
| <b>Total</b>                     |         |      | <b>0.00</b>    |

#### SHE Transmission Loss of Supply Incidents – Non-Incentivised

| Incident Date, Time and Location   | MW Lost | Mins | MWh Unsupplied |
|--|---------|------|----------------|
| <b>12 August 2022 - Quoich 132/11kV Grid Transformer 1</b><br>A faulty relay at Quoich 132/11kV S/S caused Grid Transformer 1 to trip and lockout. Demand was restored via DNO.  | 0.0     | 4    | 0.00           |
| <b>12 March 2023 - Fort Augustus - Quoich - Broadford - Edinbane - Dunvegan - Ardmore 132kV circuit (FQ/QQ/QB1/BE1/ED1/DA)</b><br>During a period following heavy snow, Fort Augustus - Quoich - Broadford - Edinbane - Dunvegan - Ardmore 132kV circuit tripped and locked out. Demand was partially restored in stages via DNO Generation and backfeeds. | 31.3    | 132  | 32.77          |
| <b>Total</b>   |         |      | <b>32.77</b>   |



# Interconnectors

## England – France Interconnector

### System Description

The NGET transmission system is interconnected with France between Sellindge and Les Mandarins, via a 70km cross-channel HVDC link owned and operated jointly by National Grid and Réseau de Transport d'Electricité (RTE); the French transmission system owner since 1986 and is called IFA.

The total capability of the Interconnector is 2000MW. This is made up of four 'circuits', each of 500MW. There is no redundancy of the major components making up each circuit, hence all outages affect real time capability.


### Annual Availability

Annual Availability of England – France Interconnector: **51.73%**

The chart below shows the annual comparison of availability of the England – France Interconnector.


**% Annual System Availability**

| England – France Interconnector % Annual Availability |         |         |         |         |
|---|---------|---------|---------|---------|
| 2018-19   | 2019-20 | 2020-21 | 2021-22 | 2022-23 |
| 93.86   | 91.45   | 95.40   | 61.22   | 51.73   |



## Monthly Unavailability

% England – France Interconnector Monthly Unavailability




| England – France Interconnector % Monthly Unavailability |       |
|--|-------|
|  | IFA   |
| April  | 54.45 |
| May  | 50.72 |
| June   | 51.70 |
| July   | 50.13 |
| August   | 50.00 |
| September  | 73.82 |
| October  | 73.55 |
| November   | 52.73 |
| December   | 56.28 |
| January  | 36.81 |
| February   | 6.04  |
| March  | 20.14 |
| Average  | 48.27 |

## Outages 2022-23 (April - March)

The chart refers to Planned and Unplanned Outages. In this context Planned are notified prior to Day Ahead and Unplanned are notified at Day Ahead or within the Contract Day.

The chart below shows the number of Interconnector Planned and Unplanned Outages on a per month basis.



| Interconnector Planned and Unplanned Outages |         |           |
|--|---------|-----------|
|  | Planned | Unplanned |
| April  | 3       | 7         |
| May  | 1       | 9         |
| June   | 1       | 1         |
| July   | 0       | 3         |
| August                                       | 0       | 0         |
| September                                    | 1       | 1         |
| October                                      | 0       | 3         |
| November                                     | 1       | 2         |
| December                                     | 0       | 0         |
| January                                      | 0       | 3         |
| February                                     | 2       | 2         |
| March  | 2       | 2         |
| Total  | 11      | 33        |

# England – Netherlands Interconnector

## System Description

The NGET transmission system is interconnected with The Netherlands between Isle of Grain and Maasvlakte, via a 260km subsea cable owned and operated by BritNed Development Limited (“BritNed”) since 2011. The total capability of BritNed is 1000MW and is made up of two ‘poles’, 500MW each.


## Annual Availability

Annual Availability of England – Netherlands Interconnector: **97.25%**

The chart below shows the availability of the England – Netherlands Interconnector.


| England – Netherlands Interconnector % Annual Availability |         |         |         |         |
|--|---------|---------|---------|---------|
| 2018-19  | 2019-20 | 2020-21 | 2021-22 | 2022-23 |
| 98.22  | 98.52   | 74.48   | 79.91   | 97.25   |

### % Annual System Availability



## Monthly Unavailability

% England – Netherlands Interconnector Monthly Unavailability




| England – Netherlands Interconnector<br>% Monthly Unavailability |         |
|--|---------|
|  | BritNed |
| April  | 1.69    |
| May  | 14.25   |
| June   | 0.00    |
| July   | 0.00    |
| August   | 0.27    |
| September  | 14.17   |
| October  | 0.00    |
| November   | 0.00    |
| December   | 1.34    |
| January  | 0.42    |
| February   | 0.00    |
| March  | 0.81    |
| Average  | 2.75    |

## Outages 2022-23 (April - March)

The chart refers to Planned and Unplanned Outages. In this context Planned are notified prior to Day Ahead and Unplanned are notified at Day Ahead or within the Contract Day.

The chart below shows the number of Interconnector Planned and Unplanned Outages on a per month basis.



| Interconnector Planned and Unplanned Outages |         |           |
|--|---------|-----------|
|  | Planned | Unplanned |
| April  | 0       | 1         |
| May  | 1       | 0         |
| June   | 0       | 0         |
| July   | 0       | 0         |
| August                                       | 0       | 1         |
| September                                    | 1       | 0         |
| October                                      | 0       | 0         |
| November                                     | 0       | 0         |
| December                                     | 0       | 1         |
| January                                      | 0       | 1         |
| February                                     | 0       | 0         |
| March  | 0       | 2         |
| Total  | 2       | 6         |

# England – Belgium Interconnector

## System Description

The NGET transmission system is interconnected with Belgium between Richborough and Zeebrugge, via a 140km subsea cable owned and operated by Nemo Link Limited (“Nemo Link”) since January 2019. The total capability of the link is 1000MW and is a single 1000MW monopole design.


## Annual Availability

Annual Availability of England – Belgium Interconnector: **98.09%**

The chart below shows the availability of the England – Belgium Interconnector.

### % Annual System Availability


| England – Belgium Interconnector % Annual Availability |         |         |         |         |
|--|---------|---------|---------|---------|
| 2018-19  | 2019-20 | 2020-21 | 2021-22 | 2022-23 |
| 99.86  | 96.14   | 99.22   | 99.00   | 98.09   |





## Monthly Unavailability

% England – Belgium Interconnector Monthly Unavailability




| England – Belgium Interconnector<br>% Monthly Unavailability |           |
|--|-----------|
|  | Nemo Link |
| April  | 0.00      |
| May  | 0.00      |
| June   | 0.00      |
| July   | 0.00      |
| August   | 0.00      |
| September  | 14.03     |
| October  | 0.00      |
| November   | 0.00      |
| December   | 1.08      |
| January  | 0.00      |
| February   | 8.73      |
| March  | 0.00      |
| Average  | 1.91      |

## Outages 2022-23 (April – March)

The chart refers to Planned and Unplanned Outages. In this context Planned are notified prior to Day Ahead and Unplanned are notified at Day Ahead or within the Contract Day.

The chart below shows the number of Interconnector Planned and Unplanned Outages on a per month basis.



| Interconnector Planned and Unplanned Outages |         |           |
|--|---------|-----------|
|  | Planned | Unplanned |
| April  | 0       | 0         |
| May  | 0       | 0         |
| June   | 0       | 0         |
| July   | 0       | 0         |
| August                                       | 0       | 0         |
| September                                    | 1       | 0         |
| October                                      | 0       | 0         |
| November                                     | 0       | 0         |
| December                                     | 1       | 0         |
| January                                      | 0       | 0         |
| February                                     | 1       | 0         |
| March  | 0       | 0         |
| Total  | 3       | 0         |

## England – France Interconnector 2

### System Description

The NGET transmission system is interconnected with France between Lee-on-the-Solent and Tourbe, via a 240km HVDC link owned and operated jointly by National Grid and Réseau de Transport d'Electricité (RTE); the French transmission system owner since January 2021 and is called IFA2.

The total capability of the Interconnector is 1000MW and is of a single 1000MW monopole design.


### Annual Availability

Annual Availability of England – France Interconnector 2: **95.68%**

The chart below shows the annual comparison of availability of the England – France Interconnector 2.


#### % Annual System Availability

| England – France Interconnector 2 % Annual Availability |         |         |         |         |
|---|---------|---------|---------|---------|
| 2018-19   | 2019-20 | 2020-21 | 2021-22 | 2022-23 |
| N/A   | N/A     | 96.55   | 90.34   | 95.68   |



## Monthly Unavailability

% England – France Interconnector 2 Monthly Unavailability




| England – France Interconnector 2<br>% Monthly Unavailability |             |
|---|-------------|
|   | IFA2        |
| April   | 0.00        |
| May   | 1.88        |
| June  | 15.81       |
| July  | 14.00       |
| August  | 8.24        |
| September   | 1.04        |
| October   | 0.00        |
| November  | 1.60        |
| December  | 8.25        |
| January   | 0.00        |
| February  | 0.00        |
| March   | 0.69        |
| <b>Average</b>  | <b>4.32</b> |

## Outages 2022-23 (April – March)

The chart refers to Planned and Unplanned Outages. In this context Planned are notified prior to Day Ahead and Unplanned are notified at Day Ahead or within the Contract Day.

The chart below shows the number of Interconnector Planned and Unplanned Outages on a per month basis.



| Interconnector Planned and Unplanned Outages |          |           |
|--|----------|-----------|
|  | Planned  | Unplanned |
| April  | 0        | 0         |
| May  | 0        | 2         |
| June   | 2        | 0         |
| July   | 1        | 4         |
| August                                       | 0        | 1         |
| September                                    | 0        | 2         |
| October                                      | 0        | 0         |
| November                                     | 1        | 0         |
| December                                     | 0        | 1         |
| January                                      | 0        | 0         |
| February                                     | 0        | 0         |
| March  | 0        | 1         |
| <b>Total</b>                                 | <b>4</b> | <b>11</b> |

# England – Norway Interconnector

## System Description

The NGET transmission system is interconnected with Norway between Blyth, Northumberland and Kvilldal, Rogland via a 720km HVDC link owned and operated jointly by National Grid Ventures and Statnett, the Norwegian transmission system owner.

The interconnector is called Northsealink and is a bipole design with a total capacity of 1400MW.


## Annual Availability

Annual Availability of England – Norway: **86.67%**

The chart below shows the annual comparison of availability of the England – Norway Interconnector


### % Annual System Availability

| England - Norway Interconnector % Annual Availability |         |         |         |         |
|---|---------|---------|---------|---------|
| 2018-19   | 2019-20 | 2020-21 | 2021-22 | 2022-23 |
| N/A   | N/A     | N/A     | 63.61   | 86.67   |



## Monthly Unavailability

% England – Norway Interconnector Monthly Unavailability




| England - Norway Interconnector<br>% Monthly Unavailability |              |
|---|--------------|
|   | NSL          |
| April   | 50.00        |
| May   | 57.59        |
| June  | 29.30        |
| July  | 0.00         |
| August  | 19.56        |
| September   | 0.00         |
| October   | 2.15         |
| November  | 0.00         |
| December  | 0.32         |
| January   | 0.00         |
| February  | 0.00         |
| March   | 0.54         |
| <b>Average</b>  | <b>13.33</b> |

## Outages 2022-23 (April – March)

The chart refers to Planned and Unplanned Outages. In this context Planned are notified prior to Day Ahead and Unplanned are notified at Day Ahead or within the Contract Day.

The chart below shows the number of Interconnector Planned and Unplanned Outages on a per month basis.



| Interconnector Planned and Unplanned Outages |          |           |
|--|----------|-----------|
|  | Planned  | Unplanned |
| April  | 0        | 0         |
| May  | 2        | 0         |
| June   | 0        | 1         |
| July   | 0        | 0         |
| August                                       | 2        | 1         |
| September                                    | 0        | 0         |
| October                                      | 2        | 0         |
| November                                     | 0        | 0         |
| December                                     | 0        | 1         |
| January                                      | 0        | 0         |
| February                                     | 0        | 0         |
| March  | 0        | 1         |
| <b>Total</b>                                 | <b>6</b> | <b>4</b>  |

# Offshore Systems

## System Description

The following section contains details of the currently connected offshore networks; Robin Rigg OFTO (TC), Gunfleet Sands OFTO (TC), Barrow OFTO (TC), Ormonde OFTO (TC), Lincs OFTO (TC), Westermost Rough OFTO (TC), Dudgeon OFTO (TC), Beatrice OFTO (TC), Rampion OFTO (TC), East Anglia 1 OFTO (TC), Walney 1 OFTO (BT), Walney 2 OFTO (BT), Sheringham Shoal OFTO (BT), London Array OFTO (BT), Greater Gabbard OFTO (EQ), Gwynt-Y-Mor OFTO (BBE), Thanet OFTO (BBE), Humber Gateway OFTO (BBE), West of Duddon Sands OFTO (WoDS), Burbo Bank Extension OFTO (DTP), Race Bank OFTO (DTP), Galloper OFTO (DTP), Walney Extension OFTO (DTP) and Hornsea One OFTO (DTP). The offshore network consists of 2922 kilometres of circuit, connecting to 24 offshore substations totalling over 9.3GW of generating capacity.

## Offshore Transmission Networks

| Offshore Transmission Networks  |            |                    |                   |                        |                    |                   |
|---------------------------------|------------|--------------------|-------------------|------------------------|--------------------|-------------------|
|                                 | Go Live    | Number of Circuits | Circuit Length km | Generating Capacity MW | Connection Voltage | Interfacing Party |
| <b>TC Robin Rigg</b>            | 02/03/2011 | 2                  | 28.8              | 178                    | 132kV              | DNO               |
| <b>TC Gunfleet Sands</b>        | 19/07/2011 | 1                  | 12.76             | 163.9                  | 132kV              | DNO               |
| <b>TC Barrow</b>                | 27/09/2011 | 1                  | 30.1              | 90                     | 132kV              | DNO               |
| <b>TC Ormonde</b>               | 10/07/2012 | 1                  | 44.3              | 150                    | 132kV              | DNO               |
| <b>TC Lincs</b>                 | 11/11/2014 | 2                  | 122.6             | 256                    | 400kV              | Transmission      |
| <b>TC Westermost Rough</b>      | 11/02/2016 | 1                  | 26.16             | 206.5                  | 275kV              | Transmission      |
| <b>TC Dudgeon</b>               | 13/11/2018 | 2                  | 178               | 400                    | 400kV              | Transmission      |
| <b>TC Beatrice</b>              | 04/08/2021 | 2                  | 181               | 588                    | 400kV              | Transmission      |
| <b>TC Rampion</b>               | 17/11/2021 | 2                  | 86                | 400                    | 400kV              | Transmission      |
| <b>TC East Anglia 1</b>         | 20/12/2022 | 2                  | 367.5             | 680                    | 400kV              | Transmission      |
| <b>BT Walney 1</b>              | 31/10/2011 | 1                  | 48                | 182                    | 132kV              | Transmission      |
| <b>BT Walney 2</b>              | 04/10/2012 | 1                  | 49                | 182                    | 132kV              | DNO               |
| <b>BT Sheringham Shoal</b>      | 05/07/2013 | 2                  | 88                | 315                    | 132kV              | DNO               |
| <b>BT London Array</b>          | 18/09/2013 | 4                  | 216               | 630                    | 400kV              | Transmission      |
| <b>EQ Greater Gabbard</b>       | 29/11/2013 | 3                  | 135               | 500                    | 132kV              | Transmission      |
| <b>BBE Gwynt Y Mor</b>          | 17/02/2015 | 4                  | 126.8             | 576                    | 400kV              | Transmission      |
| <b>BBE Thanet</b>               | 17/12/2014 | 2                  | 58.8              | 300                    | 132kV              | DNO               |
| <b>BBE Humber Gateway</b>       | 15/09/2016 | 2                  | 78                | 219                    | 275kV              | Transmission      |
| <b>West of Duddon Sands</b>     | 25/08/2015 | 2                  | 84.6              | 382                    | 400kV              | Transmission      |
| <b>DTP Burbo Bank Extension</b> | 27/04/2018 | 1                  | 35.3              | 258                    | 400kV              | Transmission      |
| <b>DTP Race Bank</b>            | 10/11/2019 | 2                  | 164.7             | 573                    | 400kV              | Transmission      |
| <b>DTP Galloper</b>             | 27/02/2020 | 2                  | 88.3              | 353                    | 132kV              | Transmission      |
| <b>DTP Walney Extension</b>     | 04/06/2020 | 2                  | 139               | 659                    | 400kV              | Transmission      |
| <b>DTP Hornsea One</b>          | 12/03/2021 | 2                  | 533               | 1134                   | 400kV              | Transmission      |

TC: Transmission Capital

BT: Blue Transmission Investments Limited

EQ: Equitix

BBE: Balfour Beatty & Equitix Consortium

DTP: Diamond Transmission Partners

## Availability

Offshore Transmission Systems are radial and only connect offshore generation to the wider NETS. The regulatory incentivisation of OFTO performance is different to that of onshore TOs and is based on their system availability rather than loss of supply. The OFTOs provide information for outages that originate on their system or outages that have impacted their system, for example, a generator, DNO or TO system. The system availability performance for each OFTO is then calculated after categorising the outages as either OFTO or Non-OFTO.

System performance is monitored by reporting variations in Annual System Availability, Winter Peak System Availability and Monthly System Availability. There is also a breakdown of Planned and Unplanned System Unavailability. The Annual System Availability of Offshore Networks for 2022-23 was **99.42%**

## % Annual System Availability

| Offshore Transmission Networks % Annual System Availability |         |         |         |         |         |
|---|---------|---------|---------|---------|---------|
|   | 2018-19 | 2019-20 | 2020-21 | 2021-22 | 2022-23 |
| TC Robin Rigg   | 100     | 99.87   | 99.95   | 100     | 100     |
| TC Gunfleet Sands   | 99.97   | 100     | 99.66   | 100     | 100     |
| TC Barrow   | 100     | 100     | 100     | 100     | 100     |
| TC Ormonde  | 100     | 100     | 100     | 99.93   | 99.38   |
| TC Lincs  | 100     | 99.56   | 99.44   | 99.98   | 96.63   |
| TC Westernmost Rough  | 99.73   | 100     | 100     | 99.93   | 100     |
| TC Dudgeon  | 100     | 99.31   | 99.83   | 99.92   | 99.95   |
| TC Beatrice   | N/A     | N/A     | N/A     | 99.16   | 99.32   |
| TC Rampion  | N/A     | N/A     | N/A     | 100     | 99.56   |
| TC East Anglia 1  | N/A     | N/A     | N/A     | N/A     | 100     |
| BT Walney 1   | 100     | 99.95   | 100     | 98.90   | 100     |
| BT Walney 2   | 91.42   | 100     | 100     | 100     | 100     |
| BT Sheringham Shoal   | 99.40   | 100     | 100     | 99.69   | 99.61   |
| BT London Array   | 99.94   | 99.95*  | 99.77   | 99.82   | 99.92   |
| EQ Greater Gabbard  | 99.82   | 99.78   | 99.78   | 99.98   | 94.74   |
| BBE Gwynt Y Mor   | 99.93*  | 96.10   | 86.31   | 99.21*  | 99.90   |
| BBE Thanet  | 100     | 100     | 99.84   | 100     | 99.72   |
| BBE Humber Gateway  | 100     | 99.83   | 99.76   | 98.73   | 99.72   |
| West of Duddon Sands  | 100     | 100*    | 99.50   | 99.19   | 99.09   |
| DTP Burbo Bank Extension                                    | 98.15   | 99.67   | 99.99   | 100     | 100     |
| DTP Race Bank   | N/A     | 100     | 99.26   | 100     | 99.93   |
| DTP Galloper  | N/A     | 100     | 99.95   | 100     | 99.97   |
| DTP Walney Extension  | N/A     | N/A     | 99.97   | 100     | 100     |
| DTP Hornsea One   | N/A     | N/A     | 100     | 99.93   | 99.57   |

\* Figure has been updated as an exceptional event with agreement from Ofgem.

## % Winter Peak System Availability

| Offshore Transmission Networks % Winter Peak System Availability |         |         |         |         |         |
|--|---------|---------|---------|---------|---------|
|  | 2018-19 | 2019-20 | 2020-21 | 2021-22 | 2022-23 |
| <b>TC Robin Rigg</b>   | 100     | 100     | 100     | 100     | 100     |
| <b>TC Gunfleet Sands</b>   | 100     | 100     | 100     | 100     | 100     |
| <b>TC Barrow</b>   | 100     | 100     | 100     | 100     | 100     |
| <b>TC Ormonde</b>  | 100     | 100     | 100     | 100     | 100     |
| <b>TC Lincs</b>  | 100     | 100     | 100     | 100     | 100     |
| <b>TC Westermost Rough</b>                                       | 100     | 100     | 100     | 100     | 100     |
| <b>TC Dudgeon</b>  | 100     | 100     | 100     | 99.88   | 100     |
| <b>TC Beatrice</b>   | N/A     | N/A     | N/A     | 100     | 100     |
| <b>TC Rampion</b>  | N/A     | N/A     | N/A     | 100     | 100     |
| <b>TC East Anglia 1</b>  | N/A     | N/A     | N/A     | N/A     | 100     |
| <b>BT Walney 1</b>   | 100     | 100     | 100     | 99.07   | 100     |
| <b>BT Walney 2</b>   | 100     | 100     | 100     | 100     | 100     |
| <b>BT Sheringham Shoal</b>                                       | 100     | 100     | 100     | 100     | 100     |
| <b>BT London Array</b>   | 99.99   | 99.89   | 100     | 99.64   | 100     |
| <b>EQ Greater Gabbard</b>  | 99.68   | 100     | 100     | 100     | 90.50   |
| <b>BBE Gwynt Y Mor</b>   | 99.61   | 100     | 72.84   | 99.82*  | 99.90   |
| <b>BBE Thanet</b>  | 100     | 100     | 100     | 100     | 99.51   |
| <b>BBE Humber Gateway</b>  | 100     | 99.82   | 100     | 99.17   | 99.41   |
| <b>West of Duddon Sands</b>                                      | 100     | 100     | 100     | 100     | 100     |
| <b>DTP Burbo Bank Extension</b>                                  | 100     | 100     | 100     | 100     | 100     |
| <b>DTP Race Bank</b>   | N/A     | 100     | 100     | 100     | 100     |
| <b>DTP Galloper</b>  | N/A     | 100     | 100     | 100     | 100     |
| <b>DTP Walney Extension</b>                                      | N/A     | N/A     | 99.91   | 100     | 100     |
| <b>DTP Hornsea One</b>   | N/A     | N/A     | 100     | 99.92   | 100     |

\* Figure has been updated as an exceptional event with agreement from Ofgem.



## % Monthly System Availability

| Offshore Transmission Networks % Monthly System Availability |       |       |       |       |       |       |       |       |       |       |       |       |
|--|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
|  | APR   | MAY   | JUN   | JUL   | AUG   | SEP   | OCT   | NOV   | DEC   | JAN   | FEB   | MAR   |
| <b>TC Robin Rigg</b>   | 100   | 100   | 100   | 100   | 100   | 100   | 100   | 100   | 100   | 100   | 100   | 100   |
| <b>TC Gunfleet Sands</b>                                     | 100   | 100   | 100   | 100   | 100   | 100   | 100   | 100   | 100   | 100   | 100   | 100   |
| <b>TC Barrow</b>   | 100   | 100   | 100   | 100   | 100   | 100   | 100   | 100   | 100   | 100   | 100   | 100   |
| <b>TC Ormonde</b>  | 100   | 100   | 100   | 100   | 92.74 | 100   | 100   | 100   | 100   | 100   | 100   | 100   |
| <b>TC Lincs</b>  | 100   | 100   | 100   | 60.49 | 99.85 | 100   | 100   | 100   | 100   | 100   | 100   | 100   |
| <b>TC Westernmost Rough</b>                                  | 100   | 100   | 100   | 100   | 100   | 100   | 100   | 100   | 100   | 100   | 100   | 100   |
| <b>TC Dudgeon</b>  | 99.40 | 100   | 100   | 100   | 100   | 100   | 100   | 100   | 100   | 100   | 100   | 100   |
| <b>TC Beatrice</b>   | 100   | 100   | 100   | 100   | 100   | 98.14 | 100   | 93.57 | 100   | 100   | 100   | 100   |
| <b>TC Rampion</b>  | 100   | 100   | 100   | 100   | 98.62 | 96.11 | 100   | 100   | 100   | 100   | 100   | 100   |
| <b>TC East Anglia 1</b>                                      | N/A   | N/A   | N/A   | N/A   | N/A   | N/A   | N/A   | N/A   | 100   | 100   | 100   | 100   |
| <b>BT Walney 1</b>   | 100   | 100   | 100   | 100   | 100   | 100   | 100   | 100   | 100   | 100   | 100   | 100   |
| <b>BT Walney 2</b>   | 100   | 100   | 100   | 100   | 100   | 100   | 100   | 100   | 100   | 100   | 100   | 100   |
| <b>BT Sheringham Shoal</b>                                   | 100   | 100   | 100   | 100   | 95.42 | 100   | 100   | 100   | 100   | 100   | 100   | 100   |
| <b>BT London Array</b>                                       | 100   | 99.76 | 99.44 | 100   | 100   | 99.87 | 100   | 100   | 100   | 100   | 100   | 100   |
| <b>EQ Greater Gabbard</b>                                    | 100   | 100   | 100   | 99.14 | 99.38 | 100   | 99.95 | 100   | 100   | 94.12 | 77.37 | 66.88 |
| <b>BBE Gwynt Y Mor</b>                                       | 100   | 100   | 100   | 99.66 | 100   | 100   | 99.43 | 100   | 99.71 | 100   | 100   | 100   |
| <b>BBE Thanet</b>  | 100   | 100   | 100   | 100   | 98.16 | 100   | 100   | 100   | 100   | 98.53 | 100   | 100   |
| <b>BBE Humber Gateway</b>                                    | 98.40 | 100   | 100   | 100   | 100   | 100   | 100   | 100   | 100   | 98.24 | 100   | 100   |
| <b>West of Duddon Sands</b>                                  | 96.67 | 100   | 95.54 | 100   | 100   | 96.71 | 100   | 100   | 100   | 100   | 100   | 100   |
| <b>DTP Burbo Bank Extension</b>                              | 100   | 100   | 100   | 100   | 100   | 100   | 100   | 100   | 100   | 100   | 100   | 100   |
| <b>DTP Race Bank</b>   | 100   | 100   | 99.15 | 100   | 100   | 100   | 100   | 100   | 100   | 100   | 100   | 100   |
| <b>DTP Galloper</b>  | 100   | 100   | 100   | 100   | 99.67 | 100   | 100   | 100   | 100   | 100   | 100   | 100   |
| <b>DTP Walney Extension</b>                                  | 100   | 100   | 100   | 100   | 100   | 100   | 100   | 100   | 100   | 100   | 100   | 100   |
| <b>DTP Hornsea One</b>                                       | 100   | 100   | 94.85 | 100   | 100   | 100   | 100   | 100   | 100   | 100   | 100   | 100   |

## % Monthly Planned and Unplanned Unavailability

The table shows the % monthly variation in Planned and Unplanned System Unavailability for the Offshore Transmission Networks. The unavailability has been classified by network responsibility i.e. OFTO or Non-OFTO (e.g. Generator).

|                      |                | Apr  | May  | Jun  | Jul   | Aug  | Sep  | Oct  | Nov  | Dec  | Jan | Feb | Mar  |
|----------------------|----------------|------|------|------|-------|------|------|------|------|------|-----|-----|------|
| TC Robin Rigg        | OFTO Planned   | 0    | 0    | 0    | 0     | 0    | 0    | 0    | 0    | 0    | 0   | 0   | 0    |
|                      | OFTO Unplanned | 0    | 0    | 0    | 0     | 0    | 0    | 0    | 0    | 0    | 0   | 0   | 0    |
|                      | Non-OFTO       | 0    | 0    | 2.08 | 0.82  | 0.08 | 0    | 0    | 0    | 0    | 0   | 0   | 0    |
| TC Gunfleet Sands    | OFTO Planned   | 0    | 0    | 0    | 0     | 0    | 0    | 0    | 0    | 0    | 0   | 0   | 0    |
|                      | OFTO Unplanned | 0    | 0    | 0    | 0     | 0    | 0    | 0    | 0    | 0    | 0   | 0   | 0    |
|                      | Non-OFTO       | 0    | 0    | 0    | 0     | 0    | 0    | 1.13 | 0    | 0    | 0   | 0   | 0.21 |
| TC Barrow            | OFTO Planned   | 0    | 0    | 0    | 0     | 0    | 0    | 0    | 0    | 0    | 0   | 0   | 0    |
|                      | OFTO Unplanned | 0    | 0    | 0    | 0     | 0    | 0    | 0    | 0    | 0    | 0   | 0   | 0    |
|                      | Non-OFTO       | 0    | 6.45 | 0    | 0     | 0    | 0    | 0    | 0    | 1.37 | 0   | 0   | 0    |
| TC Ormonde           | OFTO Planned   | 0    | 0    | 0    | 0     | 7.26 | 0    | 0    | 0    | 0    | 0   | 0   | 0    |
|                      | OFTO Unplanned | 0    | 0    | 0    | 0     | 0    | 0    | 0    | 0    | 0    | 0   | 0   | 0    |
|                      | Non-OFTO       | 0    | 7.56 | 0    | 0     | 0    | 0    | 0    | 0    | 0    | 0   | 0   | 0    |
| TC Lincs             | OFTO Planned   | 0    | 0    | 0    | 39.51 | 0    | 0    | 0    | 0    | 0    | 0   | 0   | 0    |
|                      | OFTO Unplanned | 0    | 0    | 0    | 0     | 0.15 | 0    | 0    | 0    | 0    | 0   | 0   | 0    |
|                      | Non-OFTO       | 0    | 0    | 0    | 0     | 0.11 | 0    | 0    | 0    | 0    | 0   | 0   | 0    |
| TC Westernmost Rough | OFTO Planned   | 0    | 0    | 0    | 0     | 0    | 0    | 0    | 0    | 0    | 0   | 0   | 0    |
|                      | OFTO Unplanned | 0    | 0    | 0    | 0     | 0    | 0    | 0    | 0    | 0    | 0   | 0   | 0    |
|                      | Non-OFTO       | 0    | 0    | 0    | 0     | 0    | 0    | 0    | 0    | 0    | 0   | 0   | 0    |
| TC Dudgeon           | OFTO Planned   | 0.60 | 0    | 0    | 0     | 0    | 0    | 0    | 0    | 0    | 0   | 0   | 0    |
|                      | OFTO Unplanned | 0    | 0    | 0    | 0     | 0    | 0    | 0    | 0    | 0    | 0   | 0   | 0    |
|                      | Non-OFTO       | 0    | 0    | 0    | 0     | 0    | 0    | 0    | 0    | 0    | 0   | 0   | 0    |
| TC Beatrice          | OFTO Planned   | 0    | 0    | 0    | 0     | 0    | 1.86 | 0    | 6.43 | 0    | 0   | 0   | 0    |
|                      | OFTO Unplanned | 0    | 0    | 0    | 0     | 0    | 0    | 0    | 0    | 0    | 0   | 0   | 0    |
|                      | Non-OFTO       | 1.52 | 0.04 | 0    | 0     | 0    | 0    | 0    | 0    | 0    | 0   | 0   | 0    |
| TC Rampion           | OFTO Planned   | 0    | 0    | 0    | 0     | 1.38 | 3.89 | 0    | 0    | 0    | 0   | 0   | 0    |
|                      | OFTO Unplanned | 0    | 0    | 0    | 0     | 0    | 0    | 0    | 0    | 0    | 0   | 0   | 0    |
|                      | Non-OFTO       | 0    | 0    | 0    | 0     | 0    | 0    | 0    | 0    | 0    | 0   | 0   | 0    |
| TC East Anglia 1     | OFTO Planned   | N/A  | N/A  | N/A  | N/A   | N/A  | N/A  | N/A  | N/A  | 0    | 0   | 0   | 0    |
|                      | OFTO Unplanned | N/A  | N/A  | N/A  | N/A   | N/A  | N/A  | N/A  | N/A  | 0    | 0   | 0   | 0    |
|                      | Non-OFTO       | N/A  | N/A  | N/A  | N/A   | N/A  | N/A  | N/A  | N/A  | 0    | 0   | 0   | 0    |
| BT Walney 1          | OFTO Planned   | 0    | 0    | 0    | 0     | 0    | 0    | 0    | 0    | 0    | 0   | 0   | 0    |
|                      | OFTO Unplanned | 0    | 0    | 0    | 0     | 0    | 0    | 0    | 0    | 0    | 0   | 0   | 0    |
|                      | Non-OFTO       | 0.24 | 0    | 0    | 0     | 0    | 0    | 0    | 0    | 0    | 0   | 0   | 0    |
| BT Walney 2          | OFTO Planned   | 0    | 0    | 0    | 0     | 0    | 0    | 0    | 0    | 0    | 0   | 0   | 0    |
|                      | OFTO Unplanned | 0    | 0    | 0    | 0     | 0    | 0    | 0    | 0    | 0    | 0   | 0   | 0    |
|                      | Non-OFTO       | 0.23 | 0    | 0    | 0     | 0    | 0    | 0    | 0    | 0    | 0   | 0   | 0    |

**% Monthly Planned and Unplanned Unavailability**

|                          |                | Apr  | May  | Jun  | Jul  | Aug   | Sep  | Oct  | Nov | Dec  | Jan  | Feb   | Mar   |
|--------------------------|----------------|------|------|------|------|-------|------|------|-----|------|------|-------|-------|
| BT Sheringham Shoal      | OFTO Planned   | 0    | 0    | 0    | 0    | 4.58  | 0    | 0    | 0   | 0    | 0    | 0     | 0     |
|                          | OFTO Unplanned | 0    | 0    | 0    | 0    | 0     | 0    | 0    | 0   | 0    | 0    | 0     | 0     |
|                          | Non-OFTO       | 0    | 0    | 0    | 0    | 0     | 0    | 0    | 0   | 0    | 0    | 0     | 0     |
| BT London Array          | OFTO Planned   | 0    | 0    | 0.56 | 0    | 0     | 0    | 0    | 0   | 0    | 0    | 0     | 0     |
|                          | OFTO Unplanned | 0    | 0.24 | 0    | 0    | 0     | 0.13 | 0    | 0   | 0    | 0    | 0     | 0     |
|                          | Non-OFTO       | 0    | 0    | 0    | 9.19 | 20.36 | 6.25 | 0    | 0   | 0    | 0    | 0     | 0     |
| EQ Greater Gabbard       | OFTO Planned   | 0    | 0    | 0    | 0.86 | 0.62  | 0    | 0.05 | 0   | 0    | 0    | 0     | 0     |
|                          | OFTO Unplanned | 0    | 0    | 0    | 0    | 0     | 0    | 0    | 0   | 0    | 5.88 | 22.63 | 33.12 |
|                          | Non-OFTO       | 0    | 0    | 0    | 0    | 0     | 0    | 0    | 0   | 0    | 0    | 0     | 0     |
| BBE Gwynt Y Mor          | OFTO Planned   | 0    | 0    | 0    | 0    | 0     | 0    | 0.57 | 0   | 0.29 | 0    | 0     | 0     |
|                          | OFTO Unplanned | 0    | 0    | 0    | 0.34 | 0     | 0    | 0    | 0   | 0    | 0    | 0     | 0     |
|                          | Non-OFTO       | 0    | 0    | 0    | 0    | 0     | 0    | 0    | 0   | 0    | 0    | 0     | 0     |
| BBE Thanet               | OFTO Planned   | 0    | 0    | 0    | 0    | 1.84  | 0    | 0    | 0   | 0    | 1.47 | 0     | 0     |
|                          | OFTO Unplanned | 0    | 0    | 0    | 0    | 0     | 0    | 0    | 0   | 0    | 0    | 0     | 0     |
|                          | Non-OFTO       | 0    | 0    | 0    | 0    | 0     | 0    | 0    | 0   | 0    | 0    | 0     | 0     |
| BBE Humber Gateway       | OFTO Planned   | 1.60 | 0    | 0    | 0    | 0     | 0    | 0    | 0   | 0    | 1.76 | 0     | 0     |
|                          | OFTO Unplanned | 0    | 0    | 0    | 0    | 0     | 0    | 0    | 0   | 0    | 0    | 0     | 0     |
|                          | Non-OFTO       | 0    | 0    | 0    | 0    | 0     | 0    | 0    | 0   | 0    | 0    | 0     | 0     |
| West of Duddon Sands     | OFTO Planned   | 3.33 | 0    | 0    | 0    | 0     | 0    | 0    | 0   | 0    | 0    | 0     | 0     |
|                          | OFTO Unplanned | 0    | 0    | 4.46 | 0    | 0     | 3.29 | 0    | 0   | 0    | 0    | 0     | 0     |
|                          | Non-OFTO       | 0    | 0    | 0    | 0    | 0     | 0    | 0    | 0   | 0    | 0    | 0     | 0     |
| DTP Burbo Bank Extension | OFTO Planned   | 0    | 0    | 0    | 0    | 0     | 0    | 0    | 0   | 0    | 0    | 0     | 0     |
|                          | OFTO Unplanned | 0    | 0    | 0    | 0    | 0     | 0    | 0    | 0   | 0    | 0    | 0     | 0     |
|                          | Non-OFTO       | 0    | 0    | 0    | 0    | 0     | 0    | 0    | 0   | 0    | 0    | 0     | 0     |
| DTP Race Bank            | OFTO Planned   | 0    | 0    | 0.85 | 0    | 0     | 0    | 0    | 0   | 0    | 0    | 0     | 0     |
|                          | OFTO Unplanned | 0    | 0    | 0    | 0    | 0     | 0    | 0    | 0   | 0    | 0    | 0     | 0     |
|                          | Non-OFTO       | 0    | 0    | 0    | 0    | 0     | 0    | 0    | 0   | 0    | 0    | 0     | 0     |
| DTP Galloper             | OFTO Planned   | 0    | 0    | 0    | 0    | 0.33  | 0    | 0    | 0   | 0    | 0    | 0     | 0     |
|                          | OFTO Unplanned | 0    | 0    | 0    | 0    | 0     | 0    | 0    | 0   | 0    | 0    | 0     | 0     |
|                          | Non-OFTO       | 0    | 0    | 0    | 0    | 0     | 0    | 0    | 0   | 0    | 0    | 0     | 0     |
| DTP Walney Extension     | OFTO Planned   | 0    | 0    | 0    | 0    | 0     | 0    | 0    | 0   | 0    | 0    | 0     | 0     |
|                          | OFTO Unplanned | 0    | 0    | 0    | 0    | 0     | 0    | 0    | 0   | 0    | 0    | 0     | 0     |
|                          | Non-OFTO       | 0    | 0    | 0    | 0    | 0     | 0    | 0    | 0   | 0    | 0    | 0     | 0     |
| DTP Hornsea One          | OFTO Planned   | 0    | 0    | 5.15 | 0    | 0     | 0    | 0    | 0   | 0    | 0    | 0     | 0     |
|                          | OFTO Unplanned | 0    | 0    | 0    | 0    | 0     | 0    | 0    | 0   | 0    | 0    | 0     | 0     |
|                          | Non-OFTO       | 0    | 0    | 0    | 0    | 0     | 0    | 0    | 0   | 0    | 0    | 0     | 0     |

## Outage Details

Offshore system outages are calculated using MW of offshore transmission capacity unavailable not generation lost.

### TC Robin Rigg

| Outage Date and Time  | Reason   | Days, Hours and Mins | MWh         |
|---|----------|----------------------|-------------|
| <b>06 June 2022 09:11</b><br>Robin Rigg East Windfarm restricted to 90MW. ENW planned works on Harker - Robin Rigg West - Sellafield - Stainburn 2 132kV circuit.   | Non-OFTO | 1d 6h 19m            | 2668        |
| <b>05 July 2022 09:51</b><br>Robin Rigg East Windfarm restricted to 0MW/0MVA due to ENW outage to reconfigure the network for tower works on Harker – Robin Rigg East – Sellafield – Siddick 1 132kV circuit. | Non-OFTO | 2h 56m               | 258         |
| <b>06 July 2022 10:45</b><br>Robin Rigg East Windfarm restricted to 0MW/0MVA due to ENW outage to reconfigure the network for tower works on Harker – Robin Rigg East – Sellafield – Siddick 1 132kV circuit. | Non-OFTO | 9h 27m               | 832         |
| <b>02 August 2022 08:48</b><br>Robin Rigg East wind farm restricted to 0MW/0MVA due to ENW outage to open Isolator on Harker – Robin Rigg East – Sellafield – Siddick 1 132kV circuit.                        | Non-OFTO | 46m                  | 67          |
| <b>02 August 2022 15:54</b><br>Robin Rigg East wind farm restricted to 0MW/0MVA due to ENW outage to close Isolator on Harker – Robin Rigg East – Sellafield – Siddick 1 132kV circuit.                       | Non-OFTO | 28m                  | 41          |
| <b>Total</b>  |          |                      | <b>3866</b> |

### TC Gunfleet Sands

| Outage Date and Time  | Reason   | Days, Hours and Mins | MWh         |
|---|----------|----------------------|-------------|
| <b>12 October 2022 08:46</b><br>Planned DNO outage to maintain their onshore circuit breaker 305 at Clacton Grid. | Non-OFTO | 8h 24m               | 1377        |
| <b>11 March 2023 08:36</b><br>GT outage requested by generator.   | Non-OFTO | 5h 53m               | 260         |
| <b>Total</b>  |          |                      | <b>1637</b> |

### TC Barrow

| Outage Date and Time  | Reason   | Days, Hours and Mins | MWh         |
|---|----------|----------------------|-------------|
| <b>25 May 2022 14:17</b><br>ENW outage on Trimpell No1 / BOW circuit for maintenance on Heysham disconnecter 106. | Non-OFTO | 1d 23h 58m           | 4317        |
| <b>15 December 2022 00:45</b><br>CB 190 opened due to ENW issue at Trimpell.                                      | Non-OFTO | 1h 43m               | 155         |
| <b>15 December 2022 16:13</b><br>CB 190 opened for restoration switching by ENW at Trimpell.                      | Non-OFTO | 8h 27m               | 761         |
| <b>Total</b>  |          |                      | <b>5232</b> |

## TC Ormonde

| Outage Date and Time  | Reason   | Days, Hours and Mins | MWh          |
|---|----------|----------------------|--------------|
| <b>30 May 2022 11:49</b><br>ENW outage on Trimpell No2 / OEL cct for maintenance on Heysham disconnecter 406. | Non-OFTO | 2d 8h 13m            | 8433         |
| <b>23 August 2022 08:09</b><br>OFTO planned full site outage for SCADA upgrade and GT1 OLTC maintenance.      | OFTO     | 1d 10h 02m           | 5105         |
| <b>24 August 2022 18:11</b><br>OFTO planned outage for GT1 OLTC maintenance.                                  | OFTO     | 16h 15m              | 1056         |
| <b>25 August 2022 10:30</b><br>OFTO Planned Outage for GT2 OLTC maintenance                                   | OFTO     | 1d 5h 55m            | 1945         |
| <b>Total</b>  |          |                      | <b>16538</b> |

## TC Lincs

| Outage Date and Time  | Reason   | Days, Hours and Mins | MWh          |
|---|----------|----------------------|--------------|
| <b>18 July 2022 08:36</b><br>Full outage for 400kV outdoor sealing end repair. Waiting for determination of exceptional event request.  | OFTO     | 12d 5h 59m           | 77906        |
| <b>16 August 2022 08:27</b><br>Bird strike on the Harmonic Filter 3 capacitor bank. Filter trip results in an intertrip to CCT1 export circuit.   | OFTO     | 2h 22m               | 286          |
| <b>16 August 2022 10:49</b><br>Bird strike on the Harmonic Filter 3 capacitor bank resulting in an intertrip to CCT1 export circuit at 08:27h. Export circuit was made available at 10:49. Generator technical issue delayed full restoration until 12:41h. | Non-OFTO | 1h 52m               | 226          |
| <b>Total</b>  |          |                      | <b>78417</b> |

## TC Westermost Rough

| Outage Date and Time | Reason | Days, Hours and Mins | MWh         |
|----------------------|--------|----------------------|-------------|
| <b>None</b>          |        |                      |             |
| <b>Total</b>         |        |                      | <b>None</b> |

## TC Dudgeon

| Outage Date and Time  | Reason | Days, Hours and Mins | MWh         |
|---|--------|----------------------|-------------|
| <b>05 April 2022 07:06</b><br>Removal of shunt reactor of circuit 2 for warranty repair. Outage of CCT 2. Waiting for determination of exceptional event request. | OFTO   | 8h 40m               | 1733        |
| <b>Total</b>  |        |                      | <b>1733</b> |

## TC Beatrice

| Outage Date and Time  | Reason   | Days, Hours and Mins | MWh          |
|---|----------|----------------------|--------------|
| <b>01 April 2022 00:00</b><br>GT2 Transformer restriction at generator request as under generator managed warranty. OFTO assessment had no restriction. | Non-OFTO | 10d 17h 39m          | 6439         |
| <b>14 May 2022 12:59</b><br>GT1 Stuck tap-changer. De-energised to comply with ESQCR, thus excluded.  | Non-OFTO | 24m                  | 118          |
| <b>19 May 2022 09:48</b><br>GT1 Stuck tap-changer. De-energised to comply with ESQCR, thus excluded.  | Non-OFTO | 13m                  | 64           |
| <b>21 September 2022 08:33</b><br>GT1 oil top up - transfer agreement snagging works.   | OFTO     | 1d 2h 44m            | 7860         |
| <b>27 November 2022 18:41</b><br>GT2 radiator replacement - transfer agreement snagging works.  | OFTO     | 3d 20h 35m           | 27220        |
| <b>Total</b>  |          |                      | <b>41699</b> |

## TC Rampion

| Outage Date and Time  | Reason | Days, Hours and Mins | MWh          |
|---|--------|----------------------|--------------|
| <b>09 August 2022 08:03</b><br>Export cable testing, transfer agreement snagging works. Circuit1 outage.  | OFTO   | 10h 50m              | 2058         |
| <b>10 August 2022 07:06</b><br>Export cable testing, transfer agreement snagging works. Circuit2 outage.  | OFTO   | 10h 43m              | 2036         |
| <b>12 September 2022 09:21</b><br>Outage requested by NGET due to proximity works to OFTO circuits. Bolney – Twineham CCT1 Outage. Exceptional event request submitted as licence does not consider this an excluded event. Waiting for confirmation. | OFTO   | 1d 9h 45m            | 6075         |
| <b>14 September 2022 08:18</b><br>Outage requested by NGET due to proximity works to OFTO circuits. Bolney – Twineham CCT2 Outage. Exceptional event request submitted as licence does not consider this an excluded event. Waiting for confirmation. | OFTO   | 1d 4h 33m            | 5139         |
| <b>Total</b>  |        |                      | <b>15309</b> |

## TC East Anglia 1

| Outage Date and Time | Reason | Days, Hours and Mins | MWh      |
|----------------------|--------|----------------------|----------|
| <b>None</b>          |        |                      | 0        |
| <b>Total</b>         |        |                      | <b>0</b> |

## BT Walney 1

| Outage Date and Time  | Reason | Days, Hours and Mins | MWh        |
|---|--------|----------------------|------------|
| <b>03 April 2022 18:09</b><br>Trip caused by Orsted voltage set point change. | OFTO   | 1h 42m               | 286        |
| <b>Total</b>  |        |                      | <b>286</b> |

## BT Walney 2

| Outage Date and Time  | Reason   | Days, Hours and Mins | MWh        |
|---|----------|----------------------|------------|
| <b>19 April 2021 08:45</b><br>Planned outage by DNO for maintenance of their equipment. | Non-OFTO | 1h 03m               | 176        |
| <b>27 July 2021 09:26</b><br>Planned outage by DNO for asset investigation.             | Non-OFTO | 38m                  | 106        |
| <b>Total</b>  |          |                      | <b>282</b> |

## BT Sheringham Shoal

| Outage Date and Time   | Reason | Days, Hours and Mins | MWh          |
|--|--------|----------------------|--------------|
| <b>15 August 2022 05:25</b><br>Maintenance of Salle onshore 1 and OS1 offshore circuits. | OFTO   | 2d 20h 13m           | 10744        |
| <b>Total</b>   |        |                      | <b>10744</b> |

## BT London Array

| Outage Date and Time   | Reason   | Days, Hours and Mins | MWh           |
|--|----------|----------------------|---------------|
| <b>04 May 2022 10:33</b><br>SGT2A protection relay replacement.  | OFTO     | 6h 58m               | 1003          |
| <b>04 May 2022 10:36</b><br>SGT2A protection relay replacement (SGT2B switching time).                 | OFTO     | 24m                  | 58            |
| <b>04 May 2022 16:58</b><br>SGT2A protection relay replacement (SGT2B switching time).                 | OFTO     | 33m                  | 79            |
| <b>06 June 2022 06:17</b><br>SGT1A tap changer maintenance and GT1 maintenance.                        | OFTO     | 15h 08m              | 2179          |
| <b>06 June 2022 06:51</b><br>SGT1A tap changer maintenance and GT1 maintenance (SGT1B switching time). | OFTO     | 59m                  | 142           |
| <b>06 June 2022 19:56</b><br>SGT1A tap changer maintenance and GT1 maintenance (SGT1B switching time). | OFTO     | 1h 28m               | 211           |
| <b>19 July 2022 12:57</b><br>GT4 33kV busduct replacement.   | Non-OFTO | 12d 11h 02m          | 43063         |
| <b>01 August 2022 00:00</b><br>GT4 33kV busduct replacement.   | Non-OFTO | 2d 11h 53m           | 9007          |
| <b>05 August 2022 09:14</b><br>GT3 33kV busduct replacement.   | Non-OFTO | 14d 2h 43m           | 48775         |
| <b>19 August 2022 14:28</b><br>GT1 33kV busduct replacement.   | Non-OFTO | 10d 21h 25m          | 37644         |
| <b>01 September 2022 11:01</b><br>GT2 33kV busduct replacement.  | Non-OFTO | 8d 4h 51m            | 28346         |
| <b>11 September 2022 17:55</b><br>Birdstrike in filter 1A, tripping circuit 1 offshore.                | OFTO     | 4h 12m               | 605           |
| <b>Total</b>   |          |                      | <b>171112</b> |

## Equitix Greater Gabbard

| Outage Date and Time                           | Reason | Days, Hours and Mins | MWh              |
|--|--------|----------------------|------------------|
| <b>26 July 2022</b><br>6 Yearly maintenance.   | OFTO   | 9h 40m               | 3201.60          |
| <b>22 August 2022</b><br>6 Yearly maintenance. | OFTO   | 15h 30m              | 2289.60          |
| <b>27 October 2022</b><br>Fault investigation. | OFTO   | 4h 03m               | 175.20           |
| <b>26 January 2023</b><br>Busduct fault.       | OFTO   | 18d 1h 12m           | 71737.92         |
| <b>22 February 2023</b><br>Unplanned OFTO.     | OFTO   | 40d 6h 58m           | 160143.48        |
| <b>Total</b>                                   |        |                      | <b>237547.80</b> |

## BBE Gwynt-Y-Mor

| Outage Date and Time                                     | Reason | Days, Hours and Mins | MWh           |
|--|--------|----------------------|---------------|
| <b>01 April 2021 00:01</b><br>52.8% Export cap on SSEC3. | OFTO   | 71d 6h 20m           | 114259        |
| <b>10 June 2022 06:21</b><br>SSEC3 cable repair.         | OFTO   | 42d 12h 31m          | 115448        |
| <b>20 July 2022 13:33</b><br>SGT2 - due to SVC2 trip.    | OFTO   | 3h                   | 861           |
| <b>01 October 2022 04:38</b><br>SGT1 - due to SVC1 trip. | OFTO   | 8h 27m               | 2425          |
| <b>12 December 2022 13:15</b><br>SGT2 low oil trip.      | OFTO   | 4h 14m               | 928           |
| <b>Total</b>   |        |                      | <b>233921</b> |

## BBE Thanet

| Outage Date and Time  | Reason | Days, Hours and Mins | MWh         |
|---|--------|----------------------|-------------|
| <b>16 August 2022 07:40</b><br>OFTO 6 yearly maintenance EC1. | OFTO   | 15h 14m              | 2285        |
| <b>18 August 2022 07:07</b><br>OFTO 6 yearly maintenance EC2. | OFTO   | 9h 58m               | 1822        |
| <b>17 January 2023 08:08</b><br>Cable sheath testing EC1.     | OFTO   | 11h 51m              | 1777        |
| <b>19 January 2023 07:19</b><br>Cable sheath testing EC2.     | OFTO   | 9h 58m               | 1495        |
| <b>Total</b>  |        |                      | <b>7379</b> |

## BBE Humber Gateway

| Outage Date and Time   | Reason | Days, Hours and Mins | MWh         |
|--|--------|----------------------|-------------|
| <b>28 April 2022 09:07</b><br>Circuit 2, CSE temporary repair.   | OFTO   | 22h 58m              | 2503        |
| <b>10 January 2023 07:20</b><br>Circuit 2, CSE temporary repair. | OFTO   | 1d 4h 05m            | 2869        |
| <b>Total</b>   |        |                      | <b>5372</b> |

## West of Duddon Sands

| Outage Date and Time   | Reason | Days, Hours and Mins | MWh          |
|--|--------|----------------------|--------------|
| <b>19 April 2022 08:46</b><br>Maintenance of SGT1 and return of harmonic filter 1.                                 | OFTO   | 2d 7h 24m            | 9152         |
| <b>08 June 2022 10:19</b><br>Circuit 2 taken out of service to investigate filter imbalance.                       | OFTO   | 1h 57m               | 322          |
| <b>26 June 2022 20:20</b><br>Circuit 2 tripped following offshore pressure release device operation.               | OFTO   | 3d 0h 17m            | 11941        |
| <b>15 September 2022 07:16</b><br>REF injection testing as part of root cause analysis following July 2021 outage. | OFTO   | 2d 6h 49m            | 9056         |
| <b>Total</b>   |        |                      | <b>30471</b> |



## DTP Burbo Bank Extension

| Outage Date and Time | Reason | Days, Hours and Mins | MWh      |
|----------------------|--------|----------------------|----------|
| None                 |        |                      | 0        |
| <b>Total</b>         |        |                      | <b>0</b> |

## DTP Race Bank

| Outage Date and Time                             | Reason | Days, Hours and Mins | MWh            |
|--|--------|----------------------|----------------|
| <b>28 June 2022 11:23</b><br>Protection Testing. | OFTO   | 8h 24m               | 1910.42        |
| <b>29 June 2022 13:18</b><br>Protection Testing. | OFTO   | 6h 35m               | 1497.25        |
| <b>Total</b>                                     |        |                      | <b>3407.67</b> |

## DTP Galloper

| Outage Date and Time                               | Reason | Days, Hours and Mins | MWh        |
|--|--------|----------------------|------------|
| <b>09 August 2022 10:54</b><br>Protection Testing. | OFTO   | 1h 40m               | 627        |
| <b>10 August 2022 10:14</b><br>Protection Testing. | OFTO   | 4h 26m               | 236        |
| <b>Total</b>                                       |        |                      | <b>863</b> |

## DTP Walney Extension

| Outage Date and Time | Reason | Days, Hours and Mins | MWh      |
|----------------------|--------|----------------------|----------|
| None                 |        |                      | 0        |
| <b>Total</b>         |        |                      | <b>0</b> |

## DTP Hornsea One

| Outage Date and Time   | Reason | Days, Hours and Mins | MWh          |
|--|--------|----------------------|--------------|
| <b>15 June 2022 10:24</b><br>Transfer Agreement Orsted snagging works. | OFTO   | 1d 3h 50m            | 6269         |
| <b>16 June 2022 14:14</b><br>Transfer Agreement Orsted snagging works. | OFTO   | 8d 18h 17m           | 9903         |
| <b>25 June 2022 08:31</b><br>Protection relay replacement.             | OFTO   | 3d 11h               | 18694        |
| <b>Total</b>   |        |                      | <b>34866</b> |

This glossary provides explanations and definitions for common terms used throughout this report.

### System Availability

System availability is reduced whenever a circuit is taken out of operation for either planned purposes or following a fault.

Planned outages are required for system construction and new user connections in addition to the maintenance necessary to retain a high level of system reliability to ensure that licence standards of security are met.

System Availability is calculated by the formula:

$$\left( \frac{\text{The sum for all circuits of hours available}}{\text{(No. of circuits) x (No. of hours in period)}} \right) \times 100\%$$

A circuit is defined as equipment on the transmission system, e.g. overhead line, transformer or cable which either connects two bussing points or connects two or more circuit breakers/disconnectors, excluding busbars.

Winter Peak Availability is defined as the average System Availability over the three months of December, January and February.

### System Unavailability

System Unavailability is calculated by the formula:

$$(100 - \text{Availability}) \%$$

Unavailability falls into 4 categories, 3 of which are planned and the other unplanned:

#### Maintenance Outages

are planned outages required for maintenance;

#### System Construction Outages

are planned outages required to construct or modify assets which are not provided for the exclusive benefit of specific users;

#### User Connection Outages

are planned outages required to construct or modify assets which are provided to facilitate connection for the exclusive benefit of specific system users; and

**Unplanned Unavailability** is due to outages occurring as a result of plant or equipment failure, i.e. outages required and taken at less than 24 hours' notice.

### Offshore System Availability

OFTO availability is calculated using the formula:

$$\left( \frac{\text{Total MWh system is capable of delivering} - \text{MWh unavailable}}{\text{Total MWh system is capable of delivering}} \right) \times 100\%$$

### NETS Grid Code and NETS Security and Quality of Supply Standard

The NETS Grid Code and NETS Security and Quality of Supply Standard (NETS SQSS) define the required security level to which the system is planned. The required security level at a substation increases with the amount of demand connected to the substation

and so the planned level of demand security is normally higher for 400kV and 275kV transmission voltages than for 132kV. Additionally, the 132kV network is, in parts, less interconnected than the higher voltage systems and so losses of 132kV transmission circuits (for example due to weather related transient faults) are more likely to lead to temporary losses of supply.

### Loss of Supply Incidents

A loss of supply incident is defined as any incident on the transmission system that results in an actual unsupplied energy incident to a customer or customers including pumped storage units operating in pump mode.

All transmission system incidents that resulted in a loss of supplies are reported individually giving the date, time and location of the event, duration, demand lost, an estimate of unsupplied energy and relevant factual information relating to the event.

Since 1st April 2013, loss of supply incidents is governed by the Energy Not Supplied (ENS) scheme. The scheme aims to incentivise the Transmission Licensees to minimise the impact of any loss of supply to their customers, that is, to restore supplies as soon as possible after an incident.

## Loss of Supply Incidents – Incentivised

An Incentivised loss of supply event is an event on the Licensee’s Transmission System that causes electricity not to be supplied to a customer, subject to the exclusions defined in the Special Conditions of the Transmission Licence.

## Loss of Supply Incidents – Non Incentivised

The Non-Incentivised category covers loss of supply incidents that are less than 3 minutes in duration, the energy not supplied is calculated and recorded but not included in the incentivised energy not supplied figure and is reported separately. The Non-Incentivised category also applies to connection arrangements that are chosen by the customer and often have a level of design and operational security below that normally required to satisfy the NETS SQSS. This may be reflected in a reduced cost of the connection. In some cases, customers have also chosen to secure their supplies using their own generation to compensate for this reduced level of transmission security. Loss of supply initiated on a DNO network are not included within this category.

## Overall Reliability of Supply

The Overall Reliability of Supply for a transmission system is calculated using the formula:

$$\left[ 1 - \left( \frac{\text{Estimated Unsupplied Energy}}{\text{Total energy that would have been supplied by the transmission system}} \right) \right] \times 100\%$$

## Voltage Excursions

The Electricity Safety, Quality and Continuity Regulations 2002 permit variations of voltage not exceeding 10% above and below the nominal at voltages of 132kV and above and not exceeding 6% at lower voltages. Any voltage excursions in excess of 15 minutes will be reported.

The NETS Grid Code reflects these limits and imposes a further constraint for the 400kV system in that voltages can only exceed +5% for a maximum of 15 minutes.

Consumers may expect the voltage to remain within these limits, except under abnormal conditions e.g. a system fault outside of the limits specified in the NETS SQSS.

Normal operational limits are agreed and monitored individually at connection points with customers to ensure that voltage limits are not exceeded following the specified credible fault events described in NETS SQSS.

## Frequency Excursions

The Electricity Safety, Quality and Continuity Regulations 2002 permit variations in frequency not exceeding 1% above and below 50Hz: a range of 49.5 to 50.5Hz. Any frequency excursions outside these limits for 60 seconds or more will be reported.

The system is normally managed such that frequency is maintained within operational limits of 49.8 and 50.2Hz.

Frequency may, however, move outside these limits under fault conditions or when abnormal changes to operating conditions occur. Losses of generation between 1320 and 1800MW are considered abnormal and a maximum frequency change of 0.8Hz may occur, although operation is managed so that the frequency should return within the lower statutory limit of 49.5Hz within 60 seconds.

