

Stability Mid-Term Market

Round 1 (2025/26)

Eligibility Criteria

Disclaimer

Information that is supplied in this document as part of this EOI is supplied in good faith. The information contained in the Y-1 Stability Mid Term EOI Pack and in any related written or oral communication is believed to be correct at the time of issue, but National Grid Electricity System Operator (ESO) will not accept any liability for its accuracy, adequacy or completeness and no warranty is given as such. Any reliance by a Tenderer or any third party on the information provided by ESO as part of this EOI Pack is at the Tenderer's and/or third party's risk.

Version Control

Version number	Date	Notes
V1	03/10/2023	Initial version published at EOI. Please note this document is subject to amends at ITT stage based on any feedback received through the EOI consultation.

This document presents the eligibility criteria that each proposed solution must fulfil to participate in the first round of the Stability Mid-term Market:

- Solutions must be able to provide the inertia service at 0MW export if they are GBGF-S¹ technology. For GBGF-I technology, the asset must be able to provide contracted inertia irrespective of its MW output.
- All solutions must meet the relevant Grid Forming requirements for either GBGF-I or GBGF-S in ECC.6.3.19
- Solutions must either be directly connected to the transmission system or if Embedded must have a User System Entry Point of 132kV.
 - Solutions connected to Tertiary Windings of Supergrid Transformers and Grid Parks are considered Directly Connected
- The proposed solution must be able to meet minimum 90% inertia availability (e.g., 7,884 hours of a 12-month contract).
 - In cases where there is a late start for the solution, this will apply pro-rota from when the solution is available.
- Solutions must have an existing connection agreement (whether already connected or due to connect in time for contract start).
 - These connections could be “firm” or “non-firm”² such that all the tender criteria are satisfied.
 - Bidders will need to evidence their connection agreement as part of their tender submission.
 - The connection agreement must enable the proposed solution in full.

¹ This criterion permits the temporary injection/absorption of Active Power to enable the provision of Active Inertia Power during system changes.

² Non-Firm contracts contain restrictions that limit a user being able to export their full capacity under certain conditions. The non-firm period can either be temporary (staged contract) or permanent.

- Solutions that are part of an Active Network Management (ANM) scheme will not be eligible to partake in this tender.
- Solutions must not be fitted with RoCoF protection relays or any other equipment which may impede their ability to supply Active RoCoF Response Power.³

³ Providers are expected to engage with the relevant DNO to understand the impact that any Grid Forming equipment may have upon their network. Providers should also clarify the impact of meeting these criteria upon the relevant DNO's networks and provide clarity to the ESO on any Loss of Mains protection (including intertrips) equipment they have fitted. It is the expectation that DNO connected solutions would be fitted with an intertrip to provide Loss of Mains protection. Loss of Mains protection settings will impact upon the eligibility of solutions to partake in this tender.