The Electrical Standards for SHE
Transmission's area are non-maintained versions of National Grid Technical
Specifications that are applicable to the SHE
Transmission System only. These specific versions are not subject to National Grid change control and all queries about their applicability and content should be directed to SHE Transmission in the first instance. (Should Users require the change controlled versions of the GB Transmission System National Grid Technical Specifications please see the National Grid Extranet or Livelink system where applicable).



National Grid Technical Specification

NGTS 3.2.9 Issue 1 May 1996 Post Insulators for Substations

CONTROLLED

CONTENTS	Pag
Foreword	. 1
Scope	. 1
References	
General Requirements	
Performance Requirements	
Testing	
Approval Procedure	. 2
Site Specific Data in the Tender	
Document	. 2
Appendix A	. з
Appendix B	

Authorised for Issue by:

MBHumphin

M B Humphries General Manager Technology and Science Division

© The National Grid Company plc 1996

No part of this publication may be reproduced, stored in a retrieval system, or transmitted in any form or by any means electronic, mechanical, photocopying, recording or otherwise, without the written permission of the NGC obtained from the issuing location.

Registered Office National Grid House Kirby Corner Road Coventry CV4 8JY

Registered in England and Wales No. 2366977

Published by:

The National Grid Company plc Burymead House Portsmouth Road Guildford, Surrey GU2 5BN

POST INSULATORS FOR SUBSTATIONS

FOREWORD

This Document defines the requirements for high voltage post type insulators to be used on The National Grid Company plc's (NGC) system.

1 SCOPE

This Specification details the functional and performance requirements for cylindrical post insulators of ceramic material with external metal fittings for use on 145, 300 and 420 kV 50 Hz systems.

2 REFERENCES

2.1 National/International Standards

This Specification makes reference to, and should be read in conjunction with the documents listed below. Where a British Standard (BS) is equivalent or identical to an International Electrotechnical Commission (IEC), both references are given.

IEC 273 (BS 3297)	Dimensions of indoor and outdoor post insulators and post insulator units for systems with nominal voltages greater than 1000 V.
IEC 815	Guide for the selection of insulators in respect of polluted conditions.
IEC 168	Tests on indoor and outdoor post insulators of ceramic material or glass for systems with nominal voltages greater than 1000 V.
IEC 437	Radio interference tests on high voltage insulators.

2.2 National Grid Techical Specifications

The following NGTS documentation is relevant to Switchgear and should be read in conjunction with this document as appropriate:

NGTS 1 Overview, National Grid System.

NGTS 2.2 Switchgear for The National Grid System.

3 GENERAL REQUIREMENTS

3.1 All post insulators to be installed on the National Grid System shall satisfy NGTS 2.2 and the test requirements in IEC 168.

4 PERFORMANCE REQUIREMENTS

- 4.1 Post insulators shall conform with IEC 273 accommodating the minimum creepage distance and the pollution performance stated in NGTS 2.2.
- 4.2 For replacement in substations built in accordance with The Central Electricity Generating Board (CEGB) Transmission Plant Standards, or where extension of such substations in accordance with CEGB Transmission Plant Standards is specified, Appendix B shall apply unless otherwise agreed by NGC.

5 TESTING

- 5.1 All testing shall be carried out in accordance with NGTS 1 Appendix B with the following additions:
- 5.1.1 All new designs of ceramic post insulators shall be subjected to type tests in accordance with IEC 168 Section 6.1 Type Tests.
- 5.1.2 All ceramic post insulators supplied for use by the National Grid Company plc, shall be subject to testing in accordance with NGTS 2.2 (Routine tests) and IEC 168 Section 6.2 (Sample Tests) and Section 6.2 (Routine Tests).

6 APPROVAL PROCEDURE

The requirements for the approval of post insulators are detailed in NGTS 2.2 Appendix A, and shall be completed by the Supplier in support of approval.

7 SITE SPECIFIC DATA IN THE TENDER DOCUMENT

- (i) Substation voltage.
- (ii) Any requirements for Appendix B insulators.

APPENDIX A

MANUFACTURER DESIGN, PRODUCTION PERIOD AND RATING

		- 1 1	
1	Manufacturer ceramic post		. militar a caracteristic de la caracteristic
2	Manufacturing period		
3	National Grid Approved dia number		
4	Overall length	mm	· · · · · · · · · · · · · · · · · · ·
5	Number of posts per unit		
6	Nominal creepage distance	mm	
7	Minimum creepage distance	mm	
8	Minimum mechanical failing load, cantilever	kN	· · · · · · · · · · · · · · · · · · ·
9	Minimum mechanical failing load, torsion	kN	
10	Minimum mechanical failing load, tension	kN	
11	Lightning impulse withstand voltage	kV	
12	Power frequency withstand voltage, dry	kV	· · · · · · · · · · · · · · · · · · ·
13	Power frequency withstand voltage, wet	kV	
14	Switching impulse withstand voltage, wet	kV	
15	Top cap hole size, and PCD	mm	
16	Base unit hole size and PCD	mm	
17	Total weight	kg	<u> </u>
18	Flange fixing material used		· · · · · · · · · · · · · · · · · · ·

NGTS 3.2.9 Page 4 Issue 1 May 1996

APPENDIX B

DIMENSIONAL/MECHANICAL REQUIREMENTS - INSULATORS WHERE SPECIFIED FOR USE IN SUBSTATIONS BUILT IN ACCORDANCE WITH CEGB TRANSMISSION PLANT STANDARDS

	145 kV	300 kV	400 kV	
Overall Length	1473 mm	2946 mm	3835 mm	
Live End Fixings (tapped holes)	M16-127 mm PCD	M20-178 mm PCD	M20-178 mm PCD	
Earth End Fixings (Clearance holes)	18 mm- 127 mm PCD	8 X 22 mm on 245 mm PCD.	(H/D) 8 X 22 mm on 356 mm PCD (M/D) 8 X 22 mm on 365 mm PCD (L/D) 8 X 22 mm on 254 mm PCD	
Minimum cantilever failing load-Underhung	3.5 kN	9.0 kN	(H/D) 15.5 kN (M/D) 9.0 kN (L/D) 6.7 kN	
Upright	4.5 kN	9 kN	(H/D) 15.5 kN (M/D) 10.0 kN (L/D) 6.7 kN	
Routine cantilever test load Underhung	2.1 kN	3.2 kN (indoor) 5.4 kN (outdoor)	(H/D) 9.3 kN (M/D) 5.4 kN (L/D) 4.0 kN	
Upright	4.5 kN	5.4 kN (indoor and outdoor)	(H/D) 9.3 kN (M/D) 6.0 kN (L/D) 4.0 kN	
Minimum tensile failing load	65 kN	90 kN	(H/D) 150 kN (M/D) 90 kN (L/D) 90 kN	
Minimum torsional failing load	4.5 kN	8.5 kN	(H/D) 8.5 kN (M/D) 8.5 kN (L/D) 8.5 kN	
Sample torsional test load	2.7 kN	4.0 kN	(H/D) 4.0 kN (M/D) 4.0 kN (L/D) 4.0 kN	

H/D = Heavy Duty.

M/D = Medium Duty.

L/D = Light Duty.

,