

Public

Special CUSC Panel Headline Report January 2025

The Headline Report is produced after every Panel and aims to provide an overview of the key decisions made. Minutes for this meeting will be published separately.

Change of Governance Routes: Request for Urgency

CMP405 TNUoS Locational Demand Signals for Storage

Currently Locational Demand signals are floored at £0/KWh to avoid a perverse operational incentive to increase import over periods with tight system margin at Peak demand. However, the DCLF Model shows that, in areas dominated by intermittent generation, there are significant benefits from importing during periods of peak wind generation as illustrated by the Year-Round Tariffs. This modification seeks to separate out the demand Year-Round locational signals from Peak Security locational Signals and charge (reward) Storage which imports during times other than Triads.

The Panel by majority agreed that CMP405 met the Authority’s Urgency criteria (a), and therefore recommended urgent treatment. Panel’s recommendation was sent on 10 January 2025 seeking an Authority decision by 5pm on 16 January 2025.

CMP405 documentation can be found [here](#)

CMP423 Generation Weighted Reference Node

Currently the MW/Km for a node is calculated based on its relativity to the centre of Demand. CMP423 seeks to change this so that the MW/Km is calculate based on its relativity to the centre of Generation.

The Panel by majority agreed that CMP423 did not meet the Authority’s Urgency criteria (a), and therefore did not recommend urgent treatment. Panel’s recommendation was sent on 10 January 2025 seeking an Authority decision by 5pm on 16 January 2025.

CMP423 documentation can be found [here](#)

Public

CMP432 Improve “Locational Onshore Security Factor” for TNUoS Wider Tariffs.

This modification seeks to improve the cost reflectivity of the “Locational Onshore Security Factor”, so that Wider locational TNUoS charges better reflect the way Transmission Owners plan for a secure network based on the Security and Quality of Supply Standard requirements.

The Panel by majority agreed that CMP432 met the Authority’s Urgency criteria (a), and therefore recommended urgent treatment. Panel’s recommendation was sent on 10 January 2025 seeking an Authority decision by 5pm on 16 January 2025.

CMP432 documentation can be found [here](#)

Key Activities ahead of next panel

Modification Proposal Deadline for January Panel: 16 January 2025

Papers Day: 23 January 2025

CUSC Panel – 31 January 2025

Questions or feedback?

Panel Secretary: *Catia Gomes Code Administrator*

Panel Technical Secretary: *Ren Walker, Code Administrator*

Email: cusc.team@nationalenergyso.com
