



Future of Reactive Power Webinar

14 October 2021

Agenda

Welcome, Housekeeping
and Introductions

Progress to Date

Technical Need

Project Delivery Plan

Summary of Survey Results

Overview of Market Analysis Work

Long Term Strategy

Questions and Answers

Next Steps and Close

Yuting Dai

Yuting Dai

David Gregory

Afry – Rob Lee, Espen Døvlø

Yingyi Wang

Eleanor Horn, Vicci Page

Jon McDonald

Vicci Page

Vicci Page

Submit your questions, go to:

www.menti.com

Code: 9324 9081

Progress To Date

Yuting Dai




The Journey Of Work Done So Far And What Next

Submit your questions, go to:

www.menti.com

Code: 9324 9081



Submit your questions, go to:

www.menti.com

Code: 9324 9081

Technical Need

David Gregory



Technical Need – Background

Submit your questions, go to:

www.menti.com

Code: 9324 9081

- The Transmission System is to be designed and operated to the requirements of the Security and Quality of Supply Standard (SQSS) (a licence requirement)
- For voltage this requires:
 - Maintenance of pre and post-fault voltage levels against set criteria
 - The need to guard against the risk of voltage collapse
- These requirements are currently achieved by:
 - The control of mandatory reactive power capability provided by generation as per the Grid Code
 - The installation and control of reactive compensation equipment (both static and dynamic) by TOs
 - Operational measures (tap changing, circuit switching, etc.)
 - Provision of Reactive Capability by commercial providers who are not bound by the requirements of the Grid Code and subject to commercial contracts
- Note due to the reactive nature of the Power System it is not possible to transmit large volumes of Reactive Power across the System. It is therefore necessary to supply reactive power locally

Technical Need – Key Areas

The key focus points for the technical analysis are:

Definition of requirements :

- **Size** : quantity of MVAR needed (absorption or injection) to maintain voltages at acceptable levels
- **Location** : by the nature of reactive power, its impacts are highly locational, and a key question is what do we capture in the requirement and how?
 - Should effectiveness be used, or is another metric more appropriate?
 - Should reactive power requirement zones be defined, with a requirement in a zone being quoted?
 - Should reactive power requirement be defined node-by-node?
 - Is there another way of capturing the locational requirement?

Service design :

- Current thoughts are that the service design will be to access sufficient reactive power to meet the SQSS voltage requirements, both steady state and step-change;
 - SQSS defines steady state as all operating quantities being considered as constant
 - SQSS step-change applies after the end of the *transient time phase*, typically 5 seconds after an initiating event
- Voltage stability is a different system need and service to be procured through the stability market, our reactive procurement work will be coordinated with stability procurement to ensure an efficient and optimised approach


Submit your questions, go to:

www.menti.com


Code: 9324 9081

Project Delivery Plan

Rob Lee and Espen Døvlø




Reactive power for management of voltage is critical for a stable system



CURRENT ARRANGEMENTS

NGESO has a number of tools to manage the system, we are exploring how a market might encourage more efficient provision & new providers




* No decisions have been made on the treatment of existing providers at this point in time

Overall project deliverables

Submit your questions, go to:


www.menti.com

Code: 9324 9081




Feasibility study of market design

Economic modelling in BID3 based on FES scenarios



Recommendation

Process to develop and select high level market design




Project Timeline

Submit your questions, go to:

www.menti.com

Code: 9324 9081




Submit your questions, go to:

www.menti.com

Code: 9324 9081

Summary of Survey Results

Yingyi Wang







Market Survey- Respondents Overview

Submit your questions, go to:

www.menti.com

Code: 9324 9081



- FoRP market survey closed with 105 opens and 76 responses from 1 TO, 1 DNO, 58 providers, and 16 interest groups.
- More than half of the providers are potential providers who look forward to taking part in the future.
- Regards to the connection type of responded units, the survey result shows a well balance between transmission connected and distribution connected.
- Wind, Storage, Thermal are the top 3 technology types responded the market survey (based on the number of units).

Market Survey - Technical Capabilities Summary

Submit your questions, go to:

www.menti.com

Code: 9324 9081


| | Storage | Wind | Thermal/ Gas | Hydro | Pump Storage/ Long Duration Storage | Solar | Biomass | Synchronous Condenser |
|--|---|---------------------------------------|--|--|---|---------|---|--------------------------|
| Static/ Dynamic | Dynamic/ Some units can do both | Dynamic | Dynamic | Dynamic | Dynamic | Dynamic | Dynamic | Dynamic |
| Need produce MW to provider MVAR? | No | Depends | Depends | Yes | No | No | Yes | No |
| Reactive power is provided with inertia or SCL | Some units can provide inertia and SCL | No | Yes, both | Yes, both | Yes, both | No | Yes, some units can provide with inertia, some both | Yes |
| Have extra capacity above Grid Code | N/A | Some units have excess capacity | Some units have excess capacity | No (based on survey feedback) | No (based on survey feedback) | N/A | Some units have excess capacity | N/A |

Market Survey - Commercial Preference

Submit your questions, go to:


www.menti.com

Code: 9324 9081



In order to send signals to existing providers while incentivising new investment for either new equipment or retrofits, there should be a right balance between short term and long-term procurement process.

For the short-term market, daily auction is the most popular option.



As to the price format, most providers felt they were not ready to answer this question or had no preference at this stage (especially the new players or future providers). This indicates that more information needs to be provided.

Market Survey - Market's Expectation on new market design

Submit your questions, go to:

www.menti.com

Code: 9324 9081

Right balance between long-term and short-term markets

Avoid bundling with inertia

More eligibility criteria to participating

Avoid fixed price and be cost reflective

Specific service requirement definition

Clarity on what the effectiveness mean and how it is derived

Should be mandatory

Open to all types of providers

Move towards to real-time procurement

Attractive price signal

Clear locational requirements

sufficient lead-time for new built assets

Smaller minimum size (e.g. KVAR)

Bundling services to avoid salami-slicing

Track record of prices

Transparency

Coordination DSO-TSO

Allow stacking with other services

Efficient tender processes with good support

Abolish mandatory

Market Survey - Blockers & Insights for next step

Submit your questions, go to:

www.menti.com

Code: 9324 9081

| | Blocker | Insights for our next step |
|-------------------------------------|--|---|
| General | <ul style="list-style-type: none"> Not a defined product, commercial opportunity and requirements are unclear Large minimum unit size Poor tender process support High cost of provision | <ul style="list-style-type: none"> Specific product/ service design More transparent locational requirements Further exploration on the minimum unit size setting Correctly valuing the reactive power service to send a value signal |
| Storage | <ul style="list-style-type: none"> High opportunity cost | <ul style="list-style-type: none"> Correctly valuing the reactive power service to send a value signal |
| Wind | <ul style="list-style-type: none"> Who has control of the power factor is unclear (offshore wind) | <ul style="list-style-type: none"> Clarify participation rules for offshore wind generators and OFTOs in a reactive market |
| Thermal | <ul style="list-style-type: none"> Unbundled product design is not ideal | <ul style="list-style-type: none"> Explore if procurement strategy and stacking rules can lower the barrier for them |
| Hydro | <ul style="list-style-type: none"> Hard to provide sync-comp services without upgrading | <ul style="list-style-type: none"> No data available for transmission connected hydro- need further exploration |
| Pump storage/ Long duration storage | <ul style="list-style-type: none"> High opportunity cost Undeliverable if the services are contracted separately | <ul style="list-style-type: none"> Correctly valuing the reactive power service to send a value signal |
| Solar | <ul style="list-style-type: none"> Not designed to produce reactive power, need extra investment to upgrade | <ul style="list-style-type: none"> Further investigation on this type of technology |
| DER | <ul style="list-style-type: none"> DNO connection agreements/ DUoS Charge Minimum unit size | <ul style="list-style-type: none"> Engage with DNO and implement impact analysis Understand effectiveness of DER |
| Fill the gap | | <ul style="list-style-type: none"> Further investigation on Nuclear, HVDC Explore network assets participation rules |

Submit your questions, go to:

www.menti.com

Code: 9324 9081

Overview of Market Analysis Work

Eleanor Horn

Vicci Page

Understanding The Supply Side Of A Reactive Power Market

Submit your questions, go to:

www.menti.com


Code: 9324 9081

To support the market design of a reactive power market and recommendations on next steps for a reactive power market in GB we need to assess the **potential capability of providers to participate in a market and to access new MVar capability that we don't currently access.**

What is the potential size of the market?



MVar Heatmap of GB



Provider Case Studies

Asynchronous Machines

- Wind
- Solar PV
- Battery Storage

Synchronous Machines

- Gas
- Biofuel
- Hydro/Pumped Storage
- Nuclear

MVar specific tech

- 3rd party solutions
- HVDC
- Network assets

What are the technical routes to participation?



What are the commercial routes to participation?

Case Studies

Submit your questions, go to:

www.menti.com

Code: 9324 9081

- Aimed at helping to support new and existing providers in their understanding of Reactive Power provision, including issues/blockers, associated costs and maturity levels
- Drafts will be shared for feedback / input from providers (example below)
- Once finalised we will publish them on the Reactive pages of the website

CASE STUDIES

Synchronous condenser with flywheel



Characteristics

Spider diagram

- A synchronous condenser (SC) is an AC-driven synchronous motor able to spin freely without load. It can provide system-critical services such as reactive power, inertia and additional short circuit levels to the electrical grid.
 - A flywheel can be added to the SC to provide additional inertia provision
- Advantages and enablers
 - Good provision of system stability services, especially inertia with flywheel
 - Fast enough to meet dynamic response requirements
 - Mature technology
- Barriers and disadvantages
 - Relatively high level of losses and mechanical wear

| | Base case | High range | Low range |
|---|--|---------------|---------------|
| Typical unit size (MVA _r) | 125 | 200 | 50 |
| Capex (£/kVA _r) | 248 | 324 | 172 |
| Opex (£/kVA _r /year) | 14 | 21 | 8 |
| Availability dependencies | Must be running to provide MVA _r | | |
| Reactive capability (Typical MVA _r range per MW) | See unit size | See unit size | See unit size |
| Static only or dynamic? (Reactive Power) | Dynamic | | |
| Additional range available outside ORPS range | | | |
| Short circuit levels (MVA fault current at 100ms/MW) | 4 | 5 | 3 |
| Typical inertia provision (MW _s) ¹ | 500-2000 | 2000 | 250 |
| Maturity | <input checked="" type="radio"/> <input type="radio"/> <input type="radio"/> | | |

¹Only includes capacity able to respond within 5ms of a fault


Submit your questions, go to:

www.menti.com

Code: 9324 9081

Long Term Strategy

Jon McDonald



Operability Strategy

Submit your questions, go to:

www.menti.com

Code: 9324 9081

Voltage management


- Increasing requirement
- Decreasing capability from traditional providers

Pathfinders

- Delivering long term solutions
- Ensures compliance

Potential Reactive Market

- Additional capability to meet residual need




Submit your questions, go to:

www.menti.com

Code: 9324 9081

Questions and Answers

Vicci Page / All



Next Steps and Close

Vicci Page



Next Steps and Close

- Slides and the recording will be published next week
- FAQ documents will be published after the webinar and updated on the future of balancing services webpage <https://www.nationalgrideso.com/industry-information/balancing-services/reactive-power-services/reactive-reform-market-design>
- We want your input to our work and will reach out to you directly but do please contact us to get involved and provide your input
- Please give us your feedback on the webinar, please use this [form](#)
- Contact us via our Future of Balancing Services email address: box.futureofbalancingservices@nationalgrideso.com

Thank you all for joining the call.

