


# Space Weather




Andrew Richards – Severe Risk Analyst  
April 2013

# Coronal Mass Ejection - CME

---




## CME propagation




# Solar Cycles

- Sun follows a cycle, roughly 11 years
- Cycle 24 much lower than predicted
- Cycle 24 maximum possibly during 2012
- 2 to 4 years after maximum most active for solar storms
- Large storms not strongly correlated with the cycle




# Sunspot Numbers 1600 onwards

- Cycle 24 was predicted to be weakest for 100 years
- It's turned out even weaker than predicted
- Low activity cycles have occurred before




## Past Events affecting Electrical Networks

- 
- 1859 Carrington Event: Largest known storm
  - 1921 New York Railroad Storm: Damaged equipment and fires
  - 1940 Easter Sunday Storm: First Power Grid effects
  - 1989 Quebec Blackout: First major storm of the Electricity Grid Age
  - 2003 Halloween Storm: Malmö, Sweden blackout. Transformers in South Africa damaged

# Geomagnetically Induced Current - GIC


- Geomagnetic Disturbance
- Induce Electric fields inside Earth's crust
- GICs flow out of earth, along transmission lines
- Earth themselves again through transformer neutrals
- Slowly varying, quasi-DC currents



## Effects on the system

---


- Magnetic flux leakage from core
  - Overheating, gassing, shutdown
  - Potentially catastrophic failure
- Increased reactive power consumption
  - Voltage instability
  - Power outages
- Distorted output waveform
  - Higher harmonics present
  - Protective relays triggered
  - Control assets switched out





# Risk Factors

- Geographic Location
  - Further north
  - Geological structure – down to 800km
  - Coastal effects
  - Edge of system
- Longer lines
- Higher voltage
- Transformer design



## Risk Levels of Possible Effects

---

- Widespread damage/destruction of high voltage transformers
  - Major disruption to electricity network
  - Recovery time of years

## Risk Levels of Possible Effects

---

- Widespread damage/destruction of high voltage transformers
  - Major disruption to electricity network **Effectively zero chance**
  - Recovery time of years

## Risk Levels of Possible Effects

---

- Widespread damage/destruction of high voltage transformers
  - Major disruption to electricity network **Effectively zero chance**
  - Recovery time of years
- Damage to small number of high voltage transformers
  - Little or no effect on end users
  - Possibly one or two nodes disconnected for some weeks

## Risk Levels of Possible Effects

---

- Widespread damage/destruction of high voltage transformers
  - Major disruption to electricity network **Effectively zero chance**
  - Recovery time of years
- Damage to small number of high voltage transformers
  - Little or no effect on end users **1 in 100 years**
  - Possibly one or two nodes disconnected for some weeks

## Risk Levels of Possible Effects

---

- Widespread damage/destruction of high voltage transformers
  - Major disruption to electricity network **Effectively zero chance**
  - Recovery time of years
- Damage to small number of high voltage transformers
  - Little or no effect on end users **1 in 100 years**
  - Possibly one node disconnected for some weeks
- Reactive Power demands lead to widespread voltage disturbances

## Risk Levels of Possible Effects

---

- Widespread damage/destruction of high voltage transformers
  - Major disruption to electricity network **Effectively zero chance**
  - Recovery time of years
- Damage to small number of high voltage transformers
  - Little or no effect on end users **1 in 100 years**
  - Possibly one node disconnected for some weeks
- Reactive Power demands lead to widespread voltage disturbances **1 in 30 years**

## Risk Levels of Possible Effects

---

- Widespread damage/destruction of high voltage transformers
  - Major disruption to electricity network **Effectively zero chance**
  - Recovery time of years
- Damage to small number of high voltage transformers
  - Little or no effect on end users **1 in 100 years**
  - Possibly one node disconnected for some weeks
- Reactive Power demands lead to widespread voltage disturbances **1 in 30 years**
  - Possible local power outages



## Risk Levels of Possible Effects

---

- Widespread damage/destruction of high voltage transformers
  - Major disruption to electricity network **Effectively zero chance**
  - Recovery time of years
- Damage to small number of high voltage transformers
  - Little or no effect on end users **1 in 100 years**
  - Possibly one node disconnected for some weeks
- Reactive Power demands lead to widespread voltage disturbances **1 in 30 years**
  - Possible local power outages **1 in 50 years**


# Categorisation of Disturbances

Category	Frequency	Description	Action
Category 1	4 or 5 per 11 year cycle	Media Interest. No effects on system	None
Category 2	2 or 3 per 11 year cycle	Minor Disturbance. Small voltage fluctuations seen on system.	MAGIC deployed. Heightened Awareness. Within NG normal working parameters
Category 3	1 per 11 year cycle	Storm. Voltage disturbances needing to be managed.	MAGIC deployed. Notice of system disturbance issued. Extra reactive power support. All transformers at high risk substations switched in.
Category 4	1 in 30 year event	Major Storm. Very high reactive power demands. Likelihood of high voltage disturbance. Possibility of Bucholtz alarms on a few high risk transformers	DECC informed. Silver Command convened. All-in procedure. Circuits returned to service. All transformers connected. Extra generation synchronised. Extra reactive support. Interconnectors set to float.
Category 5	1 in 100 year event	Extreme storm. Carrington-like. Very high reactive power demands. Possibility of local voltage collapse. Likelihood of thermal damage to 10 - 20 transformers..	DECC informed. Silver Command convened. All-in procedure. Circuits returned to service. All transformers connected. Extra generation synchronised. Extra reactive support. Interconnectors set to float.

# Sunspots

---


- 18 October 2003



# Sunspots

---


- 19 October 2003



# Sunspots

---


- 20 October 2003



# Sunspots

---


- 21 October 2003



# Sunspots

---


- 22 October 2003



# Sunspots

---

- 23 October 2003






# ENLIL Model

2012-05-13T00:00

2012-05-13T00 +0.00 day


● Earth



ENLIL-2.7 lowres-2123-a3b1f WSA\_V2.2 GONG-2123


com/cweatr-oid/256x30x80x1.2123-a3b1f.16-mcp1urn1cd-1.g53q5d2.gong-2012-05-13T00 2012-05-13

# Arrival at ACE satellite




## Mitigating the Risk: Operational

- Forecasting and Monitoring
- Increase reserves: more generation on line
- Stability of network: greater connectivity
- Share stress: utilise all available transformers
- Identify problem areas: specially designed tools




## Mitigating the Risk: Design

- New transformers since 1999 have high GIC tolerance
- Increased transformer spares
- Highly connected network
- Redundancy of transformers at substations
- Short transmission line lengths
- No voltages above 400 kV




Effect of DC on Transformer Cores



# National Grid / BGS MAGIC Webtool Magnetometer records

nationalgrid



# National Grid / BGS MAGIC Webtool nationalgrid Network Model display

Monitoring and Analysis of GI... SpaceWeather.com -- News... Integrated Space Weather Ar... Environment Agency - Target... Google

www.geomag.bgs.ac.uk/magic/v2/gic\_frame.html

British Geological Survey  
NATURAL ENVIRONMENT RESEARCH COUNCIL

MAG C nationalgrid

Magnetic Activity Solar Wind 3-day Forecast GIC Estimates Home

Last time map updated: 07/11/2012 13:54:39 UT

Largest 5 GIC in last 15 minutes: Largest 5 GIC in the last hour:

Short code	GIC (A)	Time	Short code	GIC (A)
PEMB41	3.8	13:54	PEMB41	3.8
ECCL11	3.5	13:39	PEMB41	3.7
JUNB1A	3.1	13:39	ECCL11	3.5
CLYS21	2.8	13:54	ECCL11	3.5
ELVA2B	2.8	13:24	PEMB41	3.5

Key: Network GIC

- 132kV (black line)
- 275kV (red line)
- 400kV (blue line)
- GIC < 5A (green circle)
- 5A < GIC < 25A (orange circle)
- GIC > 25A (red circle)

[Animation for last 4 hours](#)

**Map Controls**

Layers for different levels of GIC can be selected by clicking on the cross in top right corner of map.

Hover over any node to display the transformer code and GIC value


WARNING: Currently VERY slow in Internet Explorer. Firefox and Chrome are much faster.

Geomagnetic Activity Solar Wind Events Magnetic Activity Forecast Estimated Grid GIC

National Grid Demand ...cdf Cancelled

start Monitoring and Analy... 13:58

# Monitoring of Transformers



# Cooperation for Cycle 24



Lancaster University  
Manchester University  
Cardiff University

NOAA  
NASA  
NERC (UK)  
NERC (US)

National Grid UK  
(4 SUNBURST sensors)  
National Grid US  
(2 SUNBURST sensors)



Scottish Power  
DECC  
Cabinet Office





# Q&A

[andrew.richards@nationalgrid.com](mailto:andrew.richards@nationalgrid.com)