

Special Operational Forum



Balancing the System on Difficult Days
Tuesday 20th January 2015

Agenda

10:30	Welcome and Introduction	Audrey Ramsay
10:45	Case Study 1: Low demand & High Wind	Audrey Ramsay
11:15	Managing High Voltage	Mat Hofton
11:45	Case Study 2: High demand & low wind	Simon Williams
12:15	CLOSE	
	Lunch	

Case Study 1: Low Demand & High Wind


1st – 2nd January 2015: Overnight minimum period

Why is this scenario significant?



- Adds operational complexity

- Can create Negative System Sell




Background




Demand (1st – 2nd January 2015)

- Demand dropped below 26GW.
- Approx 1GW lower than 2nd Jan 2014
- Exacerbated by embedded wind



Wind 1st – 3rd January 2015

- Forecast to just below 7GW overnight
- ~80% metered total wind
- Output lower due to National Grid actions




Transmission Issues




SCOTEX

- Intact boundary
- Transfer exceeding boundary capability
- Significant action required to reduce exports
- But, requirement to keep some conventional plant in Scotland due to volts



High Voltage

- Increased requirement for generation overnight with lower demand
- 5 machines traded/BOAd to secure system



Margin Requirements




Response & Reserve

Service Name			Physical Supply	Typical MW
Positive Regulating Reserve			Headroom on Gen	1200MW
Short Term Operating Reserve	BMU Instructed/LF	1300MW	OCGTs Pumped Storage	1800MW
	Non-BM	500MW	Demand Embedded Gen	
Low Frequency Response	Dynamic	520MW	Automatic Delivery By Gen / Demand	910MW
	Static (LF)	390MW		
Demand				
High Frequency Response			Automatic Delivery By Gen / Demand	600MW
Negative Regulating Reserve			Synch Footroom on Gen	900MW

ENCC Actions: 1st – 2nd January 2015




System Operating Plan



- ENCC issue a System Operating Plan at 06:49 1st January
- Over 6GW oversupply expected at this point
- 6 more SOPs produced until Final at 22:24
- Only 400MW oversupply expected at this point
- Final SOP includes ENCC expected adjustments (BOAs)


ENCC Actions




- 200MW traded on Interconnector
- Over 1GW bids taken to manage Scotex
- 500MW traded
- 5 machines required on for voltage requirements
- Bids/offers taken to create headroom and footroom

ENCC Actions – 1st January 2015

ENCC spend 01-Jan-2015




ENCC Actions – 2nd January 2015



ENCC Actions – 15th September 2014

ENCC spend 15-Sep-2014




What could have helped?



Being balanced?

- Meeting contracted position would help
- Market was very long across the minimum period requiring significant number of actions by ENCC



Less restriction on Scotex?

- Reinforcement underway
 - HVDC Link
 - Series Compensation
 - East-West Reinforcement
- Reduction in volume of bids for System
- But
 - These would move to Energy in this example.




Increased reactive on windfarms?

- More availability of reactive capability on windfarms would help to reduce reliance on conventional units in some areas.





More flexibility on plant?

- Low SEL plant with Leading MVAR range helps.
- Demand turn-up service would be of benefit.
- Flexibility was available but at negative bid price to move from MEL.
- Some conventional generators taken at negative Bid on 2nd Jan have moved to positive Bid.
- But.....
- Negative bid to move from MEL remains on some conventional generators.



Holding more response on wind?



- 33 Windfarms have a Mandatory Service Agreement in place to provide Frequency Response
- 20 Windfarms submit prices to National Grid for FR provision
- Prices submitted by windfarms are higher than conventional but are being used for response.


Any Questions?

Contact

Audrey Ramsay

Audrey.Ramsay@nationalgrid.com

Transmission System Voltage



Mathew Hofton – Market Requirements Manager


Background

- Historically voltage issues predictable: during minimum demand periods at extremities of the network
- Period of occurrence increasing
- Wider area of the network
- Increase in embedded generation making minimum demand increasingly difficult to predict
- Experiencing high voltage challenges across the network this winter – minimum demand in October was c. 19GW
- Exposure to trip of dispatched generation is increasing risk
- Risk of withdrawal of reactive range
- Major challenge and huge focus on voltage management

Causes of high volts

- Low loaded cables and transmission lines over night
- Limited generation close to load centres
- Decline in reactive demand, Q/P ratio
- Increasing levels of embedded generation
- Transmission and Distribution networks look increasingly capacitive (undergrounding of lines)
- Interconnectors

Current Voltage Profile Issues




11/05/2014 Event


- Transmission System Performance Report
- High Voltage Excursion Event – S. West, S. Wales, south coast England (02:15 11 May 2014)
 - The event was caused by a number of factors coinciding:
 - Pembroke-Walham circuit could not be switched out due to low fault levels and a protection issue.
 - One of Pembroke machines ordered on tripped during loading
 - Indian Queens unit 1 was not available
 - Demand for the period was 800MW lower than studied
 - High voltage profile was already being observed in South West peninsula, South Wales and South Central England.

11/05/14 Event

- All of the above lead to long voltage excursions in many areas, most notably:



Cost of MW to provide MVAr




- Generator Contracts
- Reactive Equipment Switching & Simultaneous tapping of Supergrid Transformers
- Circuit Switching - high gain cables and OHLs switched out of service sometimes up to 18 circuits
- Facilitating commissioning of reactive equipment

The Embedded picture going forward


Embedded Generation Installed Capacity Scenario.

Source: 2013 Electricity Ten Year Statement




Solar PV

- Daytime min weekend demand is expected to become a greater risk 2015/16 onwards
- Dependent on the rate of solar PV growth – currently around 4GW
- National Grid has limited direct experience
- Initial information from some DNOs suggest existing installations have no useable reactive range
- As such arrangements are being explored to manage these contributions at times of high system voltage, if no alternative management strategy exists





Sunshine duration



**no. of domestic PV FiT installations
(per 100,000 households)**

Decline of Reactive Demand continuing



- Year on year reduction in reactive power demand and Q/P ratio
- Net MVAR export from DNO to Transmission System
- Understanding this trend is an industry wide challenge

Possible reason for reduction

- Embedded Wind / PV Generation
- Changes to DNO network characteristics (more cables) and operating regime
- Demand reduction (recession, council street-lighting policy)
- Changing air conditioning operation overnight
- Low energy light bulbs
- Energy efficiency measures

GBSO & TO Short Term Actions

- Relocate 200MVAR Reactor from Sundon to Ninfield in July 2012 – Completed
- Delivery of 2011 strategy of investments- *In progress.*
- Contract generators to provide additional MVAR support – *Completed*
 - *14/15: Marchwood, Medway, Grain, Damhead, Longannet, Didcot, Sutton Bridge, Pembroke*
- Explore Filter Bank and alternate operating modes on Interconnectors – *Interim agreement reached on reducing filters on French Interconnector*
- Opportunities for additional circuit switchouts being explored – *Completed*
- Increased focus on studies during periods of low demand – *Daily study and handover of minimum demand issues being produced- processes to align long term planning.*

GBSO & TO Medium Term Actions

- In conjunction with DNO's, work to understand the decline in reactive power and identify future actions
- Modifications to Grid Code to cap the level of reactive power being supported at the interface to the DNOs – *Ongoing in conjunction with draft European Code proposals to limit reactive power transfer from DNO's at low demand periods*
- Working closer with the DNOs on system planning and operation
- Since 2011 in E&W, 11 new shunt reactors have been in delivery, with 4 commissioned, 7 further by end 2015, which the GBSO has been facilitating
- In E&W a prioritised delivery of a further 8 reactors across 2015 and 2016 was sanctioned as part of a programme of actions to address a 2800MVA_r deficit in absorption identified by end 2016
- Identified an investment of 720MVA_r by Scottish TOs by 2017
- There is a limit however to the pace, space and technical viability of concentrations of shunt reactors of this scale on the transmission system.

Any Questions?

Contact

Mathew Hofton

Mathew.Hofton@nationalgrid.com


Case Study 2: High Demand & Low Supply



29th October 2014


Demand (29th October 2014)

- Daily peak = 47.2GW
- Add Reserve and Contingency required to give a generation requirement at Day Ahead = 48.7GW
- Short Market
 - At Day Ahead, 3.4GW Offers required to meet demand
 - By 4 hours ahead this had dropped to 1.2GW Offers required
- Normal Peak winter demand ~ 53GW



Wind 29th October 2014

- Forecast at ~1GW at peak
- ~14% metered total wind
- Low embedded wind and hence higher demand
- Outturned at ~1.5GW




Generation availability


- Margins were forecast to be tight across the week after clock-change
- Several units had not returned from planned maintenance



Weekly Margin Forecast




Annual Margin Forecast




Darkness Peak Plans

- Detailed plans are produced at regular intervals from 24 Hours ahead of real time
- The focus of these plans is to ensure Operating Margin can be met
- These are the basis for issuing System Warnings
- Plant is scheduled in cost order with the aim of minimising overall cost
- NGET do not plan to minimise System buy/sell prices
 - A short run expensive unit may have an overall lower run cost than a long run unit with a lower offer cost
 - Other plant characteristics (SEL, RURs etc.) also have an effect on overall run cost

29/10/14 – Plant Margin Position




ENCC Actions – 29th October 2014



ENCC Actions – 15th September 2014

ENCC spend 15-Sep-2014



29/10/14 - Summary

- Plant Margins were satisfactory throughout the planning process
- No System Warnings were issued
- Circuit Outage restricting Dinorwig generation
- 1 Additional Unit instructed on at £400/MWh with the marginal unit used priced at £850/MWh
- Contingency Units were priced between £350/MWh and £575/Mwh (overall run costs at SEL higher than the units instructed)
- Other changes were MEL changes throughout the day
- Reduction in available plant occurs as long notice plant becomes unusable

Any Questions?

Contact

Simon Williams

Simon.J.Williams@nationalgrid.com